

**SOURCE TEST REPORT FOR  
2025 1<sup>ST</sup> QUARTER LEACHATE AND CONDENSATE  
VAPOR SAMPLING AT THE  
CHIQUITA CANYON LANDFILL  
FACILITY ID: 119219**

Prepared For:

**SCS Engineers – Chiquita Canyon Landfill**  
3900 Kilroy Airport Way, Suite 100  
Long Beach, California 90806

For Submittal To:

**South Coast Air Quality Management District**  
21865 Copley Drive  
Diamond Bar, California 91765-4178

Prepared By:

**Montrose Air Quality Services, LLC**  
1631 E. St. Andrew Pl.  
Santa Ana, California 92705  
(714) 279-6777

Pete San Juan

Test Date: **March 20, 2025**  
Production Date: **April 18 2025**  
Document Number: **W002AS-053154-RT-7193**

## CONFIDENTIALITY STATEMENT

***Except as otherwise required by law or regulation, this information contained in this communication is intended exclusively for the individual or entity to which it is addressed. This communication may contain information that is proprietary, privileged or confidential or otherwise legally exempt from disclosure. If you are not the named addressee, you are not authorized to read, print, retain, copy, or disseminate this message or any part of it.***

## REVIEW AND CERTIFICATION

All work, calculations, and other activities and tasks performed and presented in this document were carried out by me or under my direction and supervision. I hereby certify that, to the best of my knowledge, Montrose operated in conformance with the requirements of the Montrose Quality Management System and ASTM D7036-04 during this test project.

Signature:  Date: 4/18/2025

Name: Pete SanJuan Title: Client Project Manager

I have reviewed, technically and editorially, details, calculations, results, conclusions, and other appropriate written materials contained herein. I hereby certify that, to the best of my knowledge, the presented material is authentic, accurate, and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

Signature:  Date: 4/18/2025

Name: Surya Adhikari Title: Senior Reporting QC Specialist

## TABLE OF CONTENTS

| <u>SECTION</u>  | <u>PAGE</u> |
|---|-------------|
| 1.0 INTRODUCTION .....  | 5           |
| 2.0 FACILITY AND SOURCE INFORMATION .....   | 6           |
| 2.1 PROCESS EQUIPMENT INFORMATION .....   | 6           |
| 3.0 TEST INFORMATION AND METHODOLOGY .....  | 7           |
| 3.1 SCAQMD METHOD 1.1 – SAMPLING AND VELOCITY TRAVERSSES FOR STATIONARY SOURCES ..... | 7           |
| 3.2 SCAQMD METHOD 2.1 – VELOCITY AND VOLUMETRIC FLOW RATE .....                       | 8           |
| 3.3 SCAQMD METHOD 3.1 – GAS ANALYSIS FOR DRY MOLECULAR WEIGHT AND EXCESS AIR .....    | 8           |
| 3.4 SCAQMD METHOD 4.1 – DETERMINATION OF MOISTURE CONTENT IN STACK GASES .....        | 8           |
| 3.5 SCAQMD METHOD 307-91 – HYDROGEN SULFIDE AND REDUCED SULFUR COMPOUNDS .....        | 8           |
| 3.6 EPA METHOD TO-15 – VOLATILES AND HYDROCARBON COLLECTED IN SUMMA CANISTER .....    | 8           |
| 4.0 RESULTS .....   | 9           |

### LIST OF APPENDICES

|   |     |
|---|-----|
| A TEST DATA .....                                       | 11  |
| A.1 Sample Location Data .....                          | 12  |
| A.2 Velocity, Moisture and Flow Rate Data .....         | 22  |
| A.3 Organics and Sulfur Field and Laboratory Data ..... | 42  |
| A.4 Quality Assurance Data .....                        | 86  |
| B GENERAL EMISSIONS CALCULATIONS .....                  | 98  |
| C QUALITY ASSURANCE .....                               | 101 |
| C.1 Quality Assurance Program Summary .....             | 102 |
| C.2 SCAQMD and STAC Certifications .....                | 108 |
| C.3 Individual QI Certifications .....                  | 111 |
| C.4 Statement of No Conflict of Interest .....          | 115 |
| D FACILITY PERMIT .....                                 | 117 |

### LIST OF TABLES

|   |    |
|---|----|
| 3-1 TEST PROCEDURES .....                                   | 7  |
| 4-1 H <sub>2</sub> S AND TOTAL REDUCED SULFUR RESULTS ..... | 9  |
| 4-2 TRACE ORGANICS SPECIES RESULTS .....                    | 10 |

## 1.0 INTRODUCTION

Montrose Air Quality Services, LLC (MAQS) was contacted by SCS Engineers (SCS) to conduct quarterly sampling at various locations on the vapor ventilation system located at the Chiquita Canyon Landfill (Chiquita), in Castaic, California. Testing was conducted to comply with Condition 72 of the Modified Stipulated Order for Abatement (SOFA) issued to Chiquita by the South Coast Air Quality Management District (SCAQMD) on April 24, 2024. The tests were conducted according to the test protocol (MAQS Document Number W002AS-056454-PP-1074) and source test protocol evaluation (S/T ID: P24228). The Montrose test team consisted of Pete San Juan and Kyle Thomas. Pete San Juan was the on-site qualified individual for MAQS. MAQS qualifies as an independent testing laboratory under SCAQMD Rule 304 (no conflict of interest) and is certified by the SCAQMD to conduct testing for criteria pollutants according to District Methods.

Equipment and facility information is provided in Section 2.0. Source test information is detailed in Section 3.0. Test results are provided in Section 4.0. Supplemental information is contained in the Appendices.

## 2.0 FACILITY AND SOURCE INFORMATION

The facility address is:

Physical Address: Chiquita Canyon Landfill  
29201 Henry Mayo Drive  
Castaic, California 91384

Sampling of leachate and condensate vapors was conducted from the following locations:

- The tank vents or manifolds which are representative of a set of tanks;
- The header/manifold from each leachate tank farm or manifold including Tank Farm #2, Tank Farm #6, Tank Farm #7A, Tank Farm #7B, Tank Farm #9A, and Tank Farm #9B, inlet to Zeeco Flare, Flare Station Pre-H<sub>2</sub>S treatment, and Flare Station Post-H<sub>2</sub>S treatment. Testing was performed upstream of the piping connection to the LFG Collection and Conveyance System where landfill gas may affect results.

## 2.1 PROCESS EQUIPMENT INFORMATION

Vapors created from the volatilization of chemicals in the head space in the leachate tanks at tank farms #2, #6, #7A, #7B, #9A and #9B are transferred under vacuum through the wellhead and into the landfill gas collection system then to the flare station for combustion. The pressure and temperature of the vapors in the piping varies based on ambient temperatures during normal operation. The facility operates 24 hours per day.

### 3.0 TEST INFORMATION AND METHODOLOGY

The pollutants measured and test methodology are summarized in Table 3-1. Volume flow rate measurements were performed before the sample collection.

The field sampling procedures utilized during the test program are described below. The published reference methods provide greater detailed descriptions than in this section. The purpose of this section is to provide an overview of the sampling methods and any variations. The sampling procedures are based on SCAQMD, and EPA Reference Methods.

**TABLE 3-1  
TEST PROCEDURES  
TEST PROGRAM OVERVIEW  
CHIQUITA CANYON LANDFILL  
LEACHATE AND CONDENSATE VAPOR SAMPLING**

| Parameter                | Sample Medium     | Analytical Technique  | Reference Method | Number of Replicates |
|--------------------------|-------------------|-----------------------|------------------|----------------------|
| Flow Rate/Temperature    | Pitot Tube / TC   | Differential Pressure | SCAQMD 2.1       | 1 for each location  |
| Moisture                 | Wet Bulb/Dry Bulb | Psychrometric Chart   | SCAQMD 4.1       | 1 for each location  |
| H <sub>2</sub> S and TRS | Summa Can         | GC/SCD                | SCAQMD 307-91    | 1 for each location  |
| TO-15 (Rule 1150.1)      | Summa Can         | GC/MS                 | EPA TO-15        | 1 for each location  |

#### 3.1 SCAQMD METHOD 1.1 – SAMPLING AND VELOCITY TRAVERSES FOR STATIONARY SOURCES

A preliminary source test site assessment was performed prior to the source test in order to determine applicable sample point traverse locations. The stack diameter, and the distance from sample ports to disturbances (bends, flanges, etc.), both upstream and downstream, were measured. This information is utilized to determine the minimum number of sampling points per traverse, and the distance from the inner stack wall to each sample point location. All sample locations were located according to the minimum requirements of SCAQMD Method 1.1. Additionally, this method considers cyclonic flow patterns and in-situ stratified pollutant concentrations. Cyclonic flow tests were performed at locations where flow was measurable.

### **3.2 SCAQMD METHOD 2.1 – VELOCITY AND VOLUMETRIC FLOW RATE**

The velocity of the gas stream was determined by using an "S" type or standard pitot tube, a low flow electronic manometer, and type "K" thermocouple with a digital temperature measuring device. The calibrated pitot tube is connected to the calibrated electronic Air Data Multimeter (ADM) manometer and leak checked. A temperature and delta P is obtained at each traverse point, and a duct static pressure is measured and recorded. The dry volumetric flow rate is determined from the gas velocity data, stack pressure, stack gas moisture content, stack gas molecular weight, and cross-sectional area of duct.

### **3.3 SCAQMD METHOD 3.1 – GAS ANALYSIS FOR DRY MOLECULAR WEIGHT AND EXCESS AIR**

Leachate and condensate vapor gases were analyzed by GC for O<sub>2</sub> and CO<sub>2</sub>.

### **3.4 SCAQMD METHOD 4.1 – DETERMINATION OF MOISTURE CONTENT IN STACK GASES**

Moisture was measured using a wet bulb/dry bulb and calculated with a psychrometric chart.

### **3.5 SCAQMD METHOD 307-91 – HYDROGEN SULFIDE AND REDUCED SULFUR COMPOUNDS**

Samples for determination of hydrogen sulfide and speciated reduced sulfur compounds were collected in Summa canisters. The samples were analyzed by GC/SCD by AtmAA, Inc., in Calabasas, California, following SCAQMD Method 307-91 protocol. The samples are analyzed within 24 hours of sampling.

### **3.6 EPA METHOD TO-15 – VOLATILES AND HYDROCARBON COLLECTED IN SUMMA CANISTER**

Samples were collected in glass silicate lined Summa canisters. The samples were analyzed by AtmAA Inc., located in Calabasas, California for volatile organics listed in SCAQMD Rule 1150.1 Table 1 list.

Sampling Procedure:

One summa can per location was filled with sample gas using an evacuated cylinder. The sampling probe was connected to the can with Teflon tubing. The samples were collected at a fixed point halfway into the sampling duct.

## 4.0 RESULTS

The emission results are presented in Tables 4-1 and 4-2. Site schematics are presented in Appendix A.1.

**TABLE 4-1**  
**H<sub>2</sub>S AND TOTAL REDUCED SULFUR RESULTS**  
**CHIQUITA CANYON LANDFILL**  
**LEACHATE AND CONDENSATE VAPOR SAMPLING**  
**MARCH 20, 2025**

| Parameter/Units               | Tank Farm 6 | Tank Farm 9A | Tank Farm 9B | Tank Farm 2 | Tank Farm 7A | Tank Farm 7B | ZEECO | Flare Station Pre-H <sub>2</sub> S | Flare Station Post-H <sub>2</sub> S |
|-------------------------------|-------------|--------------|--------------|-------------|--------------|--------------|-------|------------------------------------|-------------------------------------|
| N <sub>2</sub> , %            | 77.59       | 74.80        | 77.27        | 74.00       | 76.26        | 75.93        | 29.74 | 17.50                              | 18.76                               |
| H <sub>2</sub> O, %           | 1.24        | 0.68         | 0.76         | 0.61        | 0.86         | 0.86         | 4.36  | 2.68                               | 2.64                                |
| Flow Rate, scfm               | 230         | 190          | 281          | 58          | 214          | 224          | 1,164 | 1,761                              | 1,731                               |
| Temperature, °F               | 81          | 78           | 76           | 77          | 79           | 79           | 165   | 90                                 | 90                                  |
| O <sub>2</sub> , %            | 21.82       | 21.17        | 21.88        | 20.66       | 21.52        | 21.29        | 6.75  | 4.04                               | 3.64                                |
| CO <sub>2</sub> , %           | 0.14        | 2.64         | 0.14         | 2.30        | 0.14         | 1.92         | 36.30 | 42.98                              | 43.53                               |
| <b>Sulfur Compounds</b>       |             |              |              |             |              |              |       |                                    |                                     |
| H <sub>2</sub> S, ppm         | <0.10       | 10.5         | <0.10        | <.10        | <0.10        | 0.69         | 209   | 301                                | <0.40                               |
| Carbonyl Sulfide, ppm         | <0.10       | <0.10        | <0.10        | 0.12        | <0.10        | <.10         | 0.71  | 1.07                               | 0.98                                |
| Methyl Mercaptan, ppm         | 0.12        | 14.60        | <0.10        | 1.46        | <0.10        | 4.45         | 104   | 170                                | <0.40                               |
| Ethyl Mercaptan, ppm          | <0.10       | 0.22         | <0.10        | <.10        | <0.10        | <.10         | 1.64  | 2.43                               | <0.40                               |
| Dimethyl Sulfide, ppm         | 3.54        | 49.90        | 1.76         | 62.30       | 1.60         | 28.90        | 284   | 502                                | 495                                 |
| Carbon Disulfide, ppm         | <0.10       | <0.10        | <0.10        | <.10        | <0.10        | <.10         | <0.40 | <0.40                              | 0.45                                |
| i-Propyl Mercaptan, ppm       | <0.10       | 0.17         | <0.10        | <.10        | <0.10        | <.10         | 1.72  | 3.28                               | <0.40                               |
| t-Butyl Mercaptan, ppm        | <0.10       | <0.10        | <0.10        | <.10        | <0.10        | <.10         | <0.40 | <0.40                              | <0.40                               |
| n-Propyl Mercaptan, ppm       | <0.10       | <0.10        | <0.10        | 0.85        | <0.10        | 0.34         | 4.31  | 7.01                               | 7.57                                |
| s-Butyl Mercaptan, ppm        | <0.10       | 0.76         | <0.10        | 0.94        | <0.10        | 0.29         | 4.98  | 9.24                               | 9.27                                |
| i-Butyl Mercaptan, ppm        | <0.10       | <0.10        | <0.10        | <.10        | <0.10        | <.10         | <0.40 | <0.40                              | <0.40                               |
| Dimethyl Disulfide, ppm       | <0.10       | 0.30         | <0.10        | 1.33        | <0.10        | 0.34         | 0.99  | 2.22                               | 57.0                                |
| Tetrahydrothiophene, ppm      | <0.10       | 0.38         | <0.10        | 0.93        | <0.10        | 0.16         | 2.07  | 3.87                               | 4.51                                |
| Unidentified S Compounds, ppm | <0.10       | 2.18         | <0.10        | 5.14        | 0.14         | 1.16         | 10.3  | 16.4                               | 87.3                                |
| <b>Total Sulfur Compounds</b> |             |              |              |             |              |              |       |                                    |                                     |
| Total Sulfur, ppm             | 3.66        | 79.24        | 1.76         | 74.38       | 1.73         | 36.64        | 624.2 | 1019.7                             | 719.4                               |

SCS Engineers – Chiquita Canyon Landfill  
2025 1<sup>st</sup> Quarter Leachate and Condensate Vapor Sampling

**TABLE 4-2**  
**TRACE ORGANICS SPECIES RESULTS**  
**CHIQUITA CANYON LANDFILL**  
**LEACHATE AND CONDENSATE VAPOR SAMPLING**  
**MARCH 20, 2025**

| Sample Location:       | Tank Farm 6 | Tank Farm 9A | Tank Farm 9B | Tank Farm 2 | Tank Farm 7A | Tank Farm 7B | Zeeco | Flare Station Pre-H <sub>2</sub> S | Flare Station Post-H <sub>2</sub> S |
|------------------------|-------------|--------------|--------------|-------------|--------------|--------------|-------|------------------------------------|-------------------------------------|
| Test No.:              | 1           | 1            | 1            | 1           | 1            | 1            | 1     | 1                                  | 1                                   |
| Start Time:            | 815         | 855          | 855          | 900         | 935          | 935          | 935   | 1010                               | 1010                                |
| Flow Rate, scfm:       | 230         | 190          | 281          | 58          | 214          | 224          | 1,164 | 1,761                              | 1,731                               |
| Species                | ppb         | ppb          | ppb          | ppb         | ppb          | ppb          | ppb   | ppb                                | ppb                                 |
| Hydrogen sulfide:      | <           | 100          | 10,500       | <           | 100          | <            | 100   | 685                                | 209,000                             |
| Benzene:               | 765         |              | 15,400       |             | 358          |              | 421   | 6,500                              | 81,900                              |
| Benzyl Chloride:       | <           | 30           | <            | 30          | <            | 45           | <     | 45                                 | <                                   |
| Chlorobenzene:         | <           | 25           | <            | 25          | <            | 25           | <     | 40                                 | <                                   |
| Dichlorobenzenes*:     | <           | 40           | <            | 40          | <            | 40           | <     | 40                                 | <                                   |
| 1,1-dichloroethane:    | <           | 30           | <            | 30          | <            | 45           | <     | 60                                 | <                                   |
| 1,2-dichloroethane:    | <           | 30           | <            | 30          | <            | 51.6         | <     | 45                                 | <                                   |
| 1,1-dichloroethylene:  | <           | 30           | <            | 30          | <            | 45           | <     | 45                                 | <                                   |
| Dichloromethane:       | <           | 60           | <            | 60          | <            | 100          | <     | 100                                | <                                   |
| 1,2-dibromoethane:     | <           | 15           | <            | 15          | <            | 25           | <     | 25                                 | <                                   |
| Perchloroethylene:     | <           | 15           | <            | 15          | <            | 25           | <     | 25                                 | <                                   |
| Carbon Tetrachloride:  | <           | 35           | <            | 35          | <            | 60           | <     | 60                                 | <                                   |
| Toluene:               | 58.3        | 905          | 59.0         | 3,190       | 96.0         | 409          | 8,910 | 12,400                             | 11,800                              |
| 1,1,1-trichloroethane: | <           | 20           | <            | 20          | <            | 35           | <     | 35                                 | <                                   |
| Trichloroethene:       | <           | 20           | <            | 20          | <            | 35           | <     | 35                                 | <                                   |
| Chloroform:            | <           | 20           | <            | 20          | <            | 35           | <     | 35                                 | <                                   |
| Vinyl Chloride:        | <           | 20           | <            | 20          | <            | 35           | <     | 35                                 | <                                   |
| M+P-xylenes:           | 36.1        | 309          | 49.5         | 1,535       | 71.6         | 156          | 4,580 | 5,360                              | 5,440                               |
| O-xylene:              | <           | 25           | 105          | <           | 25           | 569          | <     | 40                                 | 65.4                                |
|                        |             |              |              |             |              |              | <     | 4,500                              | <                                   |
|                        |             |              |              |             |              |              | <     | 4,500                              | <                                   |

< - indicates that the species was not detected in the sample above the analytical detection limit for this species.

The values reported is the detection limit for the species and the actual concentration is lower.

\*Total amount containing meta, para, and ortho isomers.

Due to high concentration of certain chemicals present in the sample (such as benzene etc.), affected samples were diluted for the analysis which resulted the elevated detection limits.

## **APPENDIX A TEST DATA**

## **Appendix A.1 Sample Location Data**


## METHOD 1 DATA SHEET INLET SAMPLE LOCATION

Client: SCS Field Services

Date: 3/20/25

Location: Chiquita TF 6

Performed By: SJ, KT



| Diameter (inches)             | <u>6.00</u>  | Sample Point | % of Diameter | Dist from Wall (inches) | Dist from Port (inches) |
|-------------------------------|--------------|--------------|---------------|-------------------------|-------------------------|
| Upstream (inches)             | <u>48.00</u> | 1            | 4.4           | 0.5                     | 0.5                     |
| Downstream (inches)           | <u>48.00</u> | 2            | 14.6          | 0.9                     | 0.9                     |
| Coupling (in.)                | <u>0.00</u>  | 3            | 29.6          | 1.8                     | 1.8                     |
| Stack Area (ft <sup>2</sup> ) | <u>0.196</u> | 4            | 70.4          | 4.2                     | 4.2                     |
|                               |              | 5            | 85.4          | 5.1                     | 5.1                     |
|                               |              | 6            | 95.6          | 5.5                     | 5.5                     |

# METHOD 1 DATA SHEET INLET SAMPLE LOCATION




Client: SCS Field Services

Date: 3/20/25

Location: Chiquita TF 9A

Performed By: SJ, KT



|                               |              |
|-------------------------------|--------------|
| Diameter (inches)             | <u>12.00</u> |
| Upstream (inches)             | <u>96.00</u> |
| Downstream (inches)           | <u>96.00</u> |
| Coupling (in.)                | <u>0.00</u>  |
| Stack Area (ft <sup>2</sup> ) | <u>0.785</u> |

| Sample Point | % of Diameter | Dist from Wall (inches) | Dist from Port (inches) |
|--------------|---------------|-------------------------|-------------------------|
| 1            | 4.4           | 0.5                     | 0.5                     |
| 2            | 14.6          | 1.8                     | 1.8                     |
| 3            | 29.6          | 3.6                     | 3.6                     |
| 4            | 70.4          | 8.4                     | 8.4                     |
| 5            | 85.4          | 10.2                    | 10.2                    |
| 6            | 95.6          | 11.5                    | 11.5                    |

# METHOD 1 DATA SHEET

## INLET SAMPLE LOCATION


**MONTROSE**  
AN ECOLAB COMPANY

Client: SCS Field Services

Date: 3/20/25

Location: Chiquita TF 9B

Performed By: SJ, KT



| Diameter (inches)             | <u>12.00</u> | Sample Point | % of Diameter | Dist from Wall (inches) | Dist from Port (inches) |
|-------------------------------|--------------|--------------|---------------|-------------------------|-------------------------|
| Upstream (inches)             | <u>96.00</u> | 1            | 4.4           | 0.5                     | 0.5                     |
| Downstream (inches)           | <u>96.00</u> | 2            | 14.6          | 1.8                     | 1.8                     |
| Coupling (in.)                | <u>0.00</u>  | 3            | 29.6          | 3.6                     | 3.6                     |
| Stack Area (ft <sup>2</sup> ) | <u>0.785</u> | 4            | 70.4          | 8.4                     | 8.4                     |
|                               |              | 5            | 85.4          | 10.2                    | 10.2                    |
|                               |              | 6            | 95.6          | 11.5                    | 11.5                    |

# METHOD 1 DATA SHEET

## INLET SAMPLE LOCATION




Client: SCS Field Services

Date: 3/20/25

Location: Chiquita TF 2

Performed By: SJ, KT



|                               |              |
|-------------------------------|--------------|
| Diameter (inches)             | <u>6.00</u>  |
| Upstream (inches)             | <u>48.00</u> |
| Downstream (inches)           | <u>48.00</u> |
| Coupling (in.)                | <u>0.00</u>  |
| Stack Area (ft <sup>2</sup> ) | <u>0.196</u> |

| Sample Point | % of Diameter | Dist from Wall (inches) | Dist from Port (inches) |
|--------------|---------------|-------------------------|-------------------------|
| 1            | 4.4           | 0.5                     | 0.5                     |
| 2            | 14.6          | 0.9                     | 0.9                     |
| 3            | 29.6          | 1.8                     | 1.8                     |
| 4            | 70.4          | 4.2                     | 4.2                     |
| 5            | 85.4          | 5.1                     | 5.1                     |
| 6            | 95.6          | 5.5                     | 5.5                     |

# METHOD 1 DATA SHEET INLET SAMPLE LOCATION



Client: SCS Field Services

Date: 3/20/25

Location: Chiquita TF 7A

Performed By: SJ, KT

| Diameter (inches)   | <u>12.00</u>  |                         |                         |                         |                         |   |     |     |     |   |      |     |     |   |      |     |     |   |      |     |     |   |      |      |      |   |      |      |      |
|---|---------------|-------------------------|-------------------------|-------------------------|-------------------------|---|-----|-----|-----|---|------|-----|-----|---|------|-----|-----|---|------|-----|-----|---|------|------|------|---|------|------|------|
| Upstream (inches)   | <u>96.00</u>  |                         |                         |                         |                         |   |     |     |     |   |      |     |     |   |      |     |     |   |      |     |     |   |      |      |      |   |      |      |      |
| Downstream (inches)   | <u>96.00</u>  |                         |                         |                         |                         |   |     |     |     |   |      |     |     |   |      |     |     |   |      |     |     |   |      |      |      |   |      |      |      |
| Coupling (in.)  | <u>0.00</u>   |                         |                         |                         |                         |   |     |     |     |   |      |     |     |   |      |     |     |   |      |     |     |   |      |      |      |   |      |      |      |
| Stack Area (ft <sup>2</sup> )   | <u>0.785</u>  |                         |                         |                         |                         |   |     |     |     |   |      |     |     |   |      |     |     |   |      |     |     |   |      |      |      |   |      |      |      |
| <table border="1"><thead><tr><th>Sample Point</th><th>% of Diameter</th><th>Dist from Wall (inches)</th><th>Dist from Port (inches)</th></tr></thead><tbody><tr><td>1</td><td>4.4</td><td>0.5</td><td>0.5</td></tr><tr><td>2</td><td>14.6</td><td>1.8</td><td>1.8</td></tr><tr><td>3</td><td>29.6</td><td>3.6</td><td>3.6</td></tr><tr><td>4</td><td>70.4</td><td>8.4</td><td>8.4</td></tr><tr><td>5</td><td>85.4</td><td>10.2</td><td>10.2</td></tr><tr><td>6</td><td>95.6</td><td>11.5</td><td>11.5</td></tr></tbody></table> |               | Sample Point            | % of Diameter           | Dist from Wall (inches) | Dist from Port (inches) | 1 | 4.4 | 0.5 | 0.5 | 2 | 14.6 | 1.8 | 1.8 | 3 | 29.6 | 3.6 | 3.6 | 4 | 70.4 | 8.4 | 8.4 | 5 | 85.4 | 10.2 | 10.2 | 6 | 95.6 | 11.5 | 11.5 |
| Sample Point  | % of Diameter | Dist from Wall (inches) | Dist from Port (inches) |                         |                         |   |     |     |     |   |      |     |     |   |      |     |     |   |      |     |     |   |      |      |      |   |      |      |      |
| 1   | 4.4           | 0.5                     | 0.5                     |                         |                         |   |     |     |     |   |      |     |     |   |      |     |     |   |      |     |     |   |      |      |      |   |      |      |      |
| 2   | 14.6          | 1.8                     | 1.8                     |                         |                         |   |     |     |     |   |      |     |     |   |      |     |     |   |      |     |     |   |      |      |      |   |      |      |      |
| 3   | 29.6          | 3.6                     | 3.6                     |                         |                         |   |     |     |     |   |      |     |     |   |      |     |     |   |      |     |     |   |      |      |      |   |      |      |      |
| 4   | 70.4          | 8.4                     | 8.4                     |                         |                         |   |     |     |     |   |      |     |     |   |      |     |     |   |      |     |     |   |      |      |      |   |      |      |      |
| 5   | 85.4          | 10.2                    | 10.2                    |                         |                         |   |     |     |     |   |      |     |     |   |      |     |     |   |      |     |     |   |      |      |      |   |      |      |      |
| 6   | 95.6          | 11.5                    | 11.5                    |                         |                         |   |     |     |     |   |      |     |     |   |      |     |     |   |      |     |     |   |      |      |      |   |      |      |      |

## METHOD 1 DATA SHEET INLET SAMPLE LOCATION




Client: SCS Field Services

Date: 3/20/25

Location: Chiquita TF 7B

Performed By: SJ, KT



|                               |               |
|-------------------------------|---------------|
| Diameter (inches)             | <u>12.00</u>  |
| Upstream (inches)             | <u>180.00</u> |
| Downstream (inches)           | <u>180.00</u> |
| Coupling (in.)                | <u>0.00</u>   |
| Stack Area (ft <sup>2</sup> ) | <u>0.785</u>  |

| Sample Point | % of Diameter | Dist from Wall (inches) | Dist from Port (inches) |
|--------------|---------------|-------------------------|-------------------------|
| 1            | 4.4           | 0.5                     | 0.5                     |
| 2            | 14.6          | 1.8                     | 1.8                     |
| 3            | 29.6          | 3.6                     | 3.6                     |
| 4            | 70.4          | 8.4                     | 8.4                     |
| 5            | 85.4          | 10.2                    | 10.2                    |
| 6            | 95.6          | 11.5                    | 11.5                    |

# METHOD 1 DATA SHEET

## INLET SAMPLE LOCATION




Client: SCS Field Services

Date: 3/20/25

Location: Chiquita Zeeco Flare Inlet

Performed By: SJ, KT



|                               |               |
|-------------------------------|---------------|
| Diameter (inches)             | <u>12.00</u>  |
| Upstream (inches)             | <u>180.00</u> |
| Downstream (inches)           | <u>180.00</u> |
| Coupling (in.)                | <u>0.00</u>   |
| Stack Area (ft <sup>2</sup> ) | <u>0.785</u>  |

| Sample Point | % of Diameter | Dist from Wall (inches) | Dist from Port (inches) |
|--------------|---------------|-------------------------|-------------------------|
| 1            | 4.4           | 0.5                     | 0.5                     |
| 2            | 14.6          | 1.8                     | 1.8                     |
| 3            | 29.6          | 3.6                     | 3.6                     |
| 4            | 70.4          | 8.4                     | 8.4                     |
| 5            | 85.4          | 10.2                    | 10.2                    |
| 6            | 95.6          | 11.5                    | 11.5                    |

# METHOD 1 DATA SHEET

## INLET SAMPLE LOCATION




Client: SCS Field Services

Date: 3/20/25

Location: Flare Station Pre-H2S

Performed By: SJ, KT



# METHOD 1 DATA SHEET

## INLET SAMPLE LOCATION



Client: SCS Field Services

Date: 3/20/25

Location: Flare Station Post-H2S

Performed By: SJ, KT

The diagram shows a vertical rectangular pipe section. A horizontal line extends from the right side of the pipe, labeled "24 inches" with an arrow. The pipe has a small square port at the bottom edge. To the left of the pipe, the letter "O" is written. Two vertical double-headed arrows are positioned on the left side of the pipe, each labeled ">7.50 Diameters".

| Diameter (inches)             | <u>24.00</u>  | Sample Point | % of Diameter | Dist from Wall (inches) | Dist from Port (inches) |
|-------------------------------|---------------|--------------|---------------|-------------------------|-------------------------|
| Upstream (inches)             | <u>180.00</u> | 1            | 3.2           | 0.8                     | 0.8                     |
| Downstream (inches)           | <u>180.00</u> | 2            | 10.5          | 2.5                     | 2.5                     |
| Coupling (in.)                | <u>0.00</u>   | 3            | 19.4          | 4.7                     | 4.7                     |
| Stack Area (ft <sup>2</sup> ) | <u>3.142</u>  | 4            | 32.3          | 7.8                     | 7.8                     |
|                               |               | 5            | 67.7          | 16.2                    | 16.2                    |
|                               |               | 6            | 80.6          | 19.3                    | 19.3                    |
|                               |               | 7            | 89.5          | 21.5                    | 21.5                    |
|                               |               | 8            | 96.8          | 23.2                    | 23.2                    |

## **Appendix A.2**

### **Velocity, Moisture and Flow Rate Data**

**MONTROSE AQS**  
**Duct Moisture by Wet bulb/Dry bulb Measurements**

Facility: Chiquita Canyon Landfill  
 CEM I.D. : T-4

TEST DATE: March 20, 2025

BY: PSJ

$$B_{ws} = \frac{e_a''}{P_a}$$

$$e_a'' = e'' - \frac{(P_a - e'') [T_{dry} - T_{wet}]}{2800 - 1.3 \times T_{wet}}$$

|                    | Static           |                           |                |                  |                  |                |                 |          |
|--------------------|------------------|---------------------------|----------------|------------------|------------------|----------------|-----------------|----------|
|                    | P <sub>bar</sub> | Pressure                  | P <sub>a</sub> | T <sub>dry</sub> | T <sub>wet</sub> | e <sub>a</sub> | B <sub>ws</sub> | e''      |
|                    |                  | (in. of H <sub>2</sub> O) |                |                  |                  |                |                 |          |
| Tank Farm 6        | 29.03            | -4.50                     | 28.7011        | 81               | 61               | 0.3562         | 1.24            | 0.56307  |
| Tank Farm 9A       | 29.03            | -0.007                    | 29.0315        | 78               | 55               | 0.198489       | 0.68            | 0.439506 |
| Tank Farm 9B       | 29.03            | -0.009                    | 29.0313        | 76               | 55               | 0.219448       | 0.76            | 0.439506 |
| Tank Farm 2        | 29.03            | -0.006                    | 29.0316        | 77               | 54               | 0.178052       | 0.61            | 0.419127 |
| Tank Farm 7A       | 29.03            | -0.005                    | 29.0316        | 79               | 57               | 0.249873       | 0.86            | 0.480303 |
| Tank Farm 7B       | 29.03            | -0.005                    | 29.0316        | 79               | 57               | 0.249873       | 0.86            | 0.480303 |
| Zeeco              | 29.03            | -2.800                    | 28.8261        | 165              | 100              | 1.256142       | 4.36            | 1.91137  |
| Flare Station Pre  | 29.03            | -0.020                    | 29.0305        | 90               | 76               | 0.778127       | 2.68            | 0.923801 |
| Flare Station Post | 29.03            | 5.200                     | 29.4144        | 90               | 76               | 0.776138       | 2.64            | 0.923801 |

**DATA AND WORKSHEET**  
**RUN NUMBER 1**

| <b>TEST CONSTANTS</b>             |                              |                        |            |               |
|-----------------------------------|------------------------------|------------------------|------------|---------------|
| Station:                          | Chiquita Canyon Landfill     |                        |            |               |
| Unit:                             | Tank Farm 6                  |                        |            |               |
| Performed By:                     | 3/20/2025                    |                        |            |               |
| Cp:                               | 0.84                         |                        |            |               |
| T <sub>ref</sub> :                | 60                           | °F                     |            |               |
| Stack Area:                       | 0.196                        | ft <sup>2</sup>        |            |               |
| <b>TEST VARIABLES</b>             |                              |                        |            |               |
| Start Date:                       | 3/20/25                      |                        |            |               |
| Start/End Time:                   | 8:15                         | 8:45                   |            |               |
| Test Condition:                   | Normal                       |                        |            |               |
| Barom. Pressure:                  | 29.03                        |                        |            |               |
| Pstack:                           | -4.50                        | iwg                    |            |               |
| Pstack:                           | 28.70                        | "Hg                    |            |               |
| MW Wet:                           | 28.66                        | lb/lb-mole             |            |               |
| MW Dry:                           | 28.79                        | lb/lb-mole             |            |               |
| <b>Moisture</b>                   |                              |                        |            |               |
| Moisture Content:                 | 1.24 %                       | From WbDb              |            |               |
| <b>Fuel Gas Composistion Data</b> |                              |                        |            |               |
| O <sub>2</sub> :                  | 21.82 %                      | From canister analysis |            |               |
| CO <sub>2</sub> :                 | 0.14 %                       | From canister analysis |            |               |
| N <sub>2</sub> :                  | 77.59 %                      | From canister analysis |            |               |
| CH <sub>4</sub> :                 | 0.14 %                       | From canister analysis |            |               |
| <b>METHOD 2.1 DATA</b>            |                              |                        |            |               |
| Point                             | dP<br>(in. H <sub>2</sub> O) | sqrt(dP)               | Temp<br>°F | Vel.<br>(fps) |
| 1                                 | 0.130                        | 0.3606                 | 81         | 20.96         |
| 2                                 | 0.150                        | 0.3873                 | 81         | 22.52         |
| 3                                 | 0.100                        | 0.3162                 | 81         | 18.39         |
| 4                                 | 0.090                        | 0.3000                 | 81         | 17.44         |
| 5                                 | 0.120                        | 0.3464                 | 81         | 20.14         |
| 6                                 | 0.110                        | 0.3317                 | 81         | 19.28         |
| 1                                 | 0.120                        | 0.3464                 | 81         | 20.14         |
| 2                                 | 0.160                        | 0.4000                 | 81         | 23.26         |
| 3                                 | 0.150                        | 0.3873                 | 81         | 22.52         |
| 4                                 | 0.170                        | 0.4123                 | 81         | 23.97         |
| 5                                 | 0.150                        | 0.3873                 | 81         | 22.52         |
| 6                                 | 0.160                        | 0.4000                 | 81         | 23.26         |
| Average                           | 0.1329                       | 0.3646                 | 81         | 21.20         |
| Flow Rate:                        | 250                          | wacfm                  |            |               |
| Flow Rate:                        | 230                          | scfm                   |            |               |
| Flow Rate:                        | 227                          | dscfm                  |            |               |

**DATA AND WORKSHEET**  
**RUN NUMBER 1**

| <b>TEST CONSTANTS</b>                           |                              |          |            |               |
|---|------------------------------|----------|------------|---------------|
| Station: Chiquita Canyon Landfill               |                              |          |            |               |
| Unit: Tank Farm 9A                              |                              |          |            |               |
| Performed By: 3/20/2025                         |                              |          |            |               |
| Cp: 0.84  |                              |          |            |               |
| T <sub>ref</sub> : 60 °F                        |                              |          |            |               |
| Stack Area: 0.785 ft <sup>2</sup>               |                              |          |            |               |
| <b>TEST VARIABLES</b>                           |                              |          |            |               |
| Start Date: 3/20/25                             |                              |          |            |               |
| Start/End Time: 8:55 9:25                       |                              |          |            |               |
| Test Condition: Normal                          |                              |          |            |               |
| Barom. Pressure: 29.03                          |                              |          |            |               |
| Pstack: -0.007 iwg                              |                              |          |            |               |
| Pstack: 29.03 "Hg                               |                              |          |            |               |
| MW Wet: 28.92 lb/lb-mole                        |                              |          |            |               |
| MW Dry: 29.00 lb/lb-mole                        |                              |          |            |               |
| <b>Moisture</b>                                 |                              |          |            |               |
| Moisture Content: 0.68 % From WbDb              |                              |          |            |               |
| <b>Fuel Gas Composistion Data</b>               |                              |          |            |               |
| O <sub>2</sub> : 21.17 % From canister analysis |                              |          |            |               |
| CO <sub>2</sub> : 2.64 % From canister analysis |                              |          |            |               |
| N <sub>2</sub> : 74.80 % From canister analysis |                              |          |            |               |
| CH <sub>4</sub> : 0.75 % From canister analysis |                              |          |            |               |
| <b>METHOD 2.1 DATA</b>                          |                              |          |            |               |
| Point   | dP<br>(in. H <sub>2</sub> O) | sqrt(dP) | Temp<br>°F | Vel.<br>(fps) |
| 1   | 0.005                        | 0.0707   | 78         | 4.06          |
| 2   | 0.007                        | 0.0837   | 78         | 4.80          |
| 3   | 0.006                        | 0.0775   | 78         | 4.45          |
| 4   | 0.006                        | 0.0775   | 78         | 4.45          |
| 5   | 0.008                        | 0.0894   | 78         | 5.13          |
| 6   | 0.005                        | 0.0707   | 78         | 4.06          |
| 1   | 0.005                        | 0.0707   | 78         | 4.06          |
| 2   | 0.006                        | 0.0775   | 78         | 4.45          |
| 3   | 0.005                        | 0.0707   | 78         | 4.06          |
| 4   | 0.007                        | 0.0837   | 78         | 4.80          |
| 5   | 0.003                        | 0.0548   | 78         | 3.14          |
| 6   | 0.005                        | 0.0707   | 78         | 4.06          |
| Average   | 0.0056                       | 0.0748   | 78         | 4.29          |
| Flow Rate: 202 wacfm                            |                              |          |            |               |
| Flow Rate: 190 scfm                             |                              |          |            |               |
| Flow Rate: 188 dscfm                            |                              |          |            |               |

**DATA AND WORKSHEET**  
**RUN NUMBER 1**

| <b>TEST CONSTANTS</b>                           |                              |          |            |               |
|---|------------------------------|----------|------------|---------------|
| Station: Chiquita Canyon Landfill               |                              |          |            |               |
| Unit: Tank Farm 9B                              |                              |          |            |               |
| Performed By: 3/20/2025                         |                              |          |            |               |
| Cp: 0.84  |                              |          |            |               |
| T <sub>ref</sub> : 60 °F                        |                              |          |            |               |
| Stack Area: 0.785 ft <sup>2</sup>               |                              |          |            |               |
| <b>TEST VARIABLES</b>                           |                              |          |            |               |
| Start Date: 3/20/25                             |                              |          |            |               |
| Start/End Time: 8:55 9:25                       |                              |          |            |               |
| Test Condition: Normal                          |                              |          |            |               |
| Barom. Pressure: 29.03                          |                              |          |            |               |
| Pstack: -0.009 iwg                              |                              |          |            |               |
| Pstack: 29.03 "Hg                               |                              |          |            |               |
| MW Wet: 28.64 lb/lb-mole                        |                              |          |            |               |
| MW Dry: 28.72 lb/lb-mole                        |                              |          |            |               |
| <b>Moisture</b>                                 |                              |          |            |               |
| Moisture Content: 0.76 % From WbDb              |                              |          |            |               |
| <b>Fuel Gas Composition Data</b>                |                              |          |            |               |
| O <sub>2</sub> : 21.88 % From canister analysis |                              |          |            |               |
| CO <sub>2</sub> : 0.14 % From canister analysis |                              |          |            |               |
| N <sub>2</sub> : 77.27 % From canister analysis |                              |          |            |               |
| CH <sub>4</sub> : 0.14 % From canister analysis |                              |          |            |               |
| <b>METHOD 2.1 DATA</b>                          |                              |          |            |               |
| Point   | dP<br>(in. H <sub>2</sub> O) | sqrt(dP) | Temp<br>°F | Vel.<br>(fps) |
| 1   | 0.013                        | 0.1140   | 76         | 6.56          |
| 2   | 0.013                        | 0.1140   | 76         | 6.56          |
| 3   | 0.013                        | 0.1140   | 76         | 6.56          |
| 4   | 0.010                        | 0.1000   | 76         | 5.76          |
| 5   | 0.013                        | 0.1140   | 76         | 6.56          |
| 6   | 0.012                        | 0.1095   | 76         | 6.31          |
| 1   | 0.012                        | 0.1095   | 76         | 6.31          |
| 2   | 0.012                        | 0.1095   | 76         | 6.31          |
| 3   | 0.013                        | 0.1140   | 76         | 6.56          |
| 4   | 0.012                        | 0.1095   | 76         | 6.31          |
| 5   | 0.011                        | 0.1049   | 76         | 6.04          |
| 6   | 0.012                        | 0.1095   | 76         | 6.31          |
| Average   | 0.0121                       | 0.1102   | 76         | 6.34          |
| Flow Rate: 299 wacfm                            |                              |          |            |               |
| Flow Rate: 281 scfm                             |                              |          |            |               |
| Flow Rate: 279 dscfm                            |                              |          |            |               |

**DATA AND WORKSHEET**  
**RUN NUMBER 1**

| <b>TEST CONSTANTS</b>                           |                              |            |               |      |
|---|------------------------------|------------|---------------|------|
| Station: Chiquita Canyon Landfill               |                              |            |               |      |
| Unit: Tank Farm 2                               |                              |            |               |      |
| Performed By: 3/20/2025                         |                              |            |               |      |
| Cp: 0.84  |                              |            |               |      |
| T <sub>ref</sub> : 60 °F                        |                              |            |               |      |
| Stack Area: 0.196 ft <sup>2</sup>               |                              |            |               |      |
| <b>TEST VARIABLES</b>                           |                              |            |               |      |
| Start Date: 3/20/25                             |                              |            |               |      |
| Start/End Time: 9:00 9:30                       |                              |            |               |      |
| Test Condition: Normal                          |                              |            |               |      |
| Barom. Pressure: 29.03                          |                              |            |               |      |
| Pstack: -0.006 iwg                              |                              |            |               |      |
| Pstack: 29.03 "Hg                               |                              |            |               |      |
| MW Wet: 28.30 lb/lb-mole                        |                              |            |               |      |
| MW Dry: 28.37 lb/lb-mole                        |                              |            |               |      |
| <b>Moisture</b>                                 |                              |            |               |      |
| Moisture Content: 0.61 % From WbDb              |                              |            |               |      |
| <b>Fuel Gas Composistion Data</b>               |                              |            |               |      |
| O <sub>2</sub> : 20.66 % From canister analysis |                              |            |               |      |
| CO <sub>2</sub> : 2.30 % From canister analysis |                              |            |               |      |
| N <sub>2</sub> : 74.00 % From canister analysis |                              |            |               |      |
| CH <sub>4</sub> : 0.14 % From canister analysis |                              |            |               |      |
| <b>METHOD 2.1 DATA</b>                          |                              |            |               |      |
| Point   | dP<br>(in. H <sub>2</sub> O) | Temp<br>°F | Vel.<br>(fps) |      |
| 1   | 0.006                        | 0.0775     | 77            | 4.49 |
| 2   | 0.007                        | 0.0837     | 77            | 4.85 |
| 3   | 0.007                        | 0.0837     | 77            | 4.85 |
| 4   | 0.009                        | 0.0949     | 77            | 5.50 |
| 5   | 0.010                        | 0.1000     | 77            | 5.80 |
| 6   | 0.013                        | 0.1140     | 77            | 6.61 |
| 1   | 0.008                        | 0.0894     | 77            | 5.18 |
| 2   | 0.009                        | 0.0949     | 77            | 5.50 |
| 3   | 0.007                        | 0.0837     | 77            | 4.85 |
| 4   | 0.005                        | 0.0707     | 77            | 4.10 |
| 5   | 0.009                        | 0.0949     | 77            | 5.50 |
| 6   | 0.010                        | 0.1000     | 77            | 5.80 |
| Average   | 0.0082                       | 0.0906     | 77            | 5.25 |
| Flow Rate: 62 wacfm                             |                              |            |               |      |
| Flow Rate: 58 scfm                              |                              |            |               |      |
| Flow Rate: 58 dscfm                             |                              |            |               |      |

**DATA AND WORKSHEET**  
**RUN NUMBER 1**

| <b>TEST CONSTANTS</b>             |                              |                        |            |               |
|-----------------------------------|------------------------------|------------------------|------------|---------------|
| Station:                          | Chiquita Canyon Landfill     |                        |            |               |
| Unit:                             | Tank Farm 7A                 |                        |            |               |
| Performed By:                     | 3/20/2025                    |                        |            |               |
| Cp:                               | 0.84                         |                        |            |               |
| T <sub>ref</sub> :                | 60                           | °F                     |            |               |
| Stack Area:                       | 0.785                        | ft <sup>2</sup>        |            |               |
| <b>TEST VARIABLES</b>             |                              |                        |            |               |
| Start Date:                       | 3/20/25                      |                        |            |               |
| Start/End Time:                   | 9:35                         | 10:05                  |            |               |
| Test Condition:                   | Normal                       |                        |            |               |
| Barom. Pressure:                  | 29.03                        |                        |            |               |
| Pstack:                           | -0.005                       | iwg                    |            |               |
| Pstack:                           | 29.03                        | "Hg                    |            |               |
| MW Wet:                           | 28.23                        | lb/lb-mole             |            |               |
| MW Dry:                           | 28.32                        | lb/lb-mole             |            |               |
| <b>Moisture</b>                   |                              |                        |            |               |
| Moisture Content:                 | 0.86 %                       | From WbDb              |            |               |
| <b>Fuel Gas Composistion Data</b> |                              |                        |            |               |
| O <sub>2</sub> :                  | 21.52 %                      | From canister analysis |            |               |
| CO <sub>2</sub> :                 | 0.14 %                       | From canister analysis |            |               |
| N <sub>2</sub> :                  | 76.26 %                      | From canister analysis |            |               |
| CH <sub>4</sub> :                 | 0.14 %                       | From canister analysis |            |               |
| <b>METHOD 2.1 DATA</b>            |                              |                        |            |               |
| Point                             | dP<br>(in. H <sub>2</sub> O) | sqrt(dP)               | Temp<br>°F | Vel.<br>(fps) |
| 1                                 | 0.005                        | 0.0707                 | 79         | 4.11          |
| 2                                 | 0.007                        | 0.0837                 | 79         | 4.86          |
| 3                                 | 0.006                        | 0.0775                 | 79         | 4.50          |
| 4                                 | 0.009                        | 0.0949                 | 79         | 5.52          |
| 5                                 | 0.008                        | 0.0894                 | 79         | 5.20          |
| 6                                 | 0.007                        | 0.0837                 | 79         | 4.86          |
| 1                                 | 0.006                        | 0.0775                 | 79         | 4.50          |
| 2                                 | 0.008                        | 0.0894                 | 79         | 5.20          |
| 3                                 | 0.006                        | 0.0775                 | 79         | 4.50          |
| 4                                 | 0.005                        | 0.0707                 | 79         | 4.11          |
| 5                                 | 0.009                        | 0.0949                 | 79         | 5.52          |
| 6                                 | 0.008                        | 0.0894                 | 79         | 5.20          |
| Average                           | 0.0069                       | 0.0833                 | 79         | 4.84          |
| Flow Rate:                        | 228                          | wacfm                  |            |               |
| Flow Rate:                        | 214                          | scfm                   |            |               |
| Flow Rate:                        | 212                          | dscfm                  |            |               |

**DATA AND WORKSHEET**  
**RUN NUMBER 1**

| <b>TEST CONSTANTS</b>             |                              |                        |            |               |
|-----------------------------------|------------------------------|------------------------|------------|---------------|
| Station:                          | Chiquita Canyon Landfill     |                        |            |               |
| Unit:                             | Tank Farm 7B                 |                        |            |               |
| Performed By:                     | 3/20/2025                    |                        |            |               |
| Cp:                               | 0.84                         |                        |            |               |
| T <sub>ref</sub> :                | 60                           | °F                     |            |               |
| Stack Area:                       | 0.785                        | ft <sup>2</sup>        |            |               |
| <b>TEST VARIABLES</b>             |                              |                        |            |               |
| Start Date:                       | 3/20/25                      |                        |            |               |
| Start/End Time:                   | 9:35                         | 10:05                  |            |               |
| Test Condition:                   | Normal                       |                        |            |               |
| Barom. Pressure:                  | 29.03                        |                        |            |               |
| Pstack:                           | -0.005                       | iwg                    |            |               |
| Pstack:                           | 29.03                        | "Hg                    |            |               |
| MW Wet:                           | 28.85                        | lb/lb-mole             |            |               |
| MW Dry:                           | 28.94                        | lb/lb-mole             |            |               |
| <b>Moisture</b>                   |                              |                        |            |               |
| Moisture Content:                 | 0.86 %                       | From WbDb              |            |               |
| <b>Fuel Gas Composistion Data</b> |                              |                        |            |               |
| O <sub>2</sub> :                  | 21.29 %                      | From canister analysis |            |               |
| CO <sub>2</sub> :                 | 1.92 %                       | From canister analysis |            |               |
| N <sub>2</sub> :                  | 75.93 %                      | From canister analysis |            |               |
| CH <sub>4</sub> :                 | 0.14 %                       | From canister analysis |            |               |
| <b>METHOD 2.1 DATA</b>            |                              |                        |            |               |
| Point                             | dP<br>(in. H <sub>2</sub> O) | sqrt(dP)               | Temp<br>°F | Vel.<br>(fps) |
| 1                                 | 0.007                        | 0.0837                 | 79         | 4.81          |
| 2                                 | 0.009                        | 0.0949                 | 79         | 5.46          |
| 3                                 | 0.008                        | 0.0894                 | 79         | 5.14          |
| 4                                 | 0.009                        | 0.0949                 | 79         | 5.46          |
| 5                                 | 0.008                        | 0.0894                 | 79         | 5.14          |
| 6                                 | 0.007                        | 0.0837                 | 79         | 4.81          |
| 1                                 | 0.006                        | 0.0775                 | 79         | 4.46          |
| 2                                 | 0.009                        | 0.0949                 | 79         | 5.46          |
| 3                                 | 0.010                        | 0.1000                 | 79         | 5.75          |
| 4                                 | 0.011                        | 0.1049                 | 79         | 6.03          |
| 5                                 | 0.006                        | 0.0775                 | 79         | 4.46          |
| 6                                 | 0.005                        | 0.0707                 | 79         | 4.07          |
| Average                           | 0.0078                       | 0.0884                 | 79         | 5.09          |
| Flow Rate:                        | 240                          | wacfm                  |            |               |
| Flow Rate:                        | 224                          | scfm                   |            |               |
| Flow Rate:                        | 222                          | dscfm                  |            |               |

**DATA AND WORKSHEET**  
**RUN NUMBER 1**

| <b>TEST CONSTANTS</b>             |                              |                        |            |               |
|-----------------------------------|------------------------------|------------------------|------------|---------------|
| Station:                          | Chiquita Canyon Landfill     |                        |            |               |
| Unit:                             | Zeeco                        |                        |            |               |
| Performed By:                     | 3/20/2025                    |                        |            |               |
| Cp:                               | 0.84                         |                        |            |               |
| T <sub>ref</sub> :                | 60                           | °F                     |            |               |
| Stack Area:                       | 0.785                        | ft <sup>2</sup>        |            |               |
| <b>TEST VARIABLES</b>             |                              |                        |            |               |
| Start Date:                       | 3/20/25                      |                        |            |               |
| Start/End Time:                   | 9:35                         | 10:05                  |            |               |
| Test Condition:                   | Normal                       |                        |            |               |
| Barom. Pressure:                  | 29.03                        |                        |            |               |
| Pstack:                           | -2.80                        | iwg                    |            |               |
| Pstack:                           | 28.83                        | "Hg                    |            |               |
| MW Wet:                           | 31.65                        | lb/lb-mole             |            |               |
| MW Dry:                           | 32.27                        | lb/lb-mole             |            |               |
| <b>Moisture</b>                   |                              |                        |            |               |
| Moisture Content:                 | 4.36 %                       | From WbDb              |            |               |
| <b>Fuel Gas Composistion Data</b> |                              |                        |            |               |
| O <sub>2</sub> :                  | 6.75 %                       | From canister analysis |            |               |
| CO <sub>2</sub> :                 | 36.30 %                      | From canister analysis |            |               |
| N <sub>2</sub> :                  | 29.74 %                      | From canister analysis |            |               |
| CH <sub>4</sub> :                 | 36.3 %                       | From canister analysis |            |               |
| <b>METHOD 2.1 DATA</b>            |                              |                        |            |               |
| Point                             | dP<br>(in. H <sub>2</sub> O) | sqrt(dP)               | Temp<br>°F | Vel.<br>(fps) |
| 1                                 | 0.270                        | 0.5196                 | 165        | 30.84         |
| 2                                 | 0.280                        | 0.5292                 | 165        | 31.40         |
| 3                                 | 0.300                        | 0.5477                 | 165        | 32.50         |
| 4                                 | 0.300                        | 0.5477                 | 165        | 32.50         |
| 5                                 | 0.280                        | 0.5292                 | 165        | 31.40         |
| 6                                 | 0.260                        | 0.5099                 | 165        | 30.26         |
| 1                                 | 0.280                        | 0.5292                 | 165        | 31.40         |
| 2                                 | 0.270                        | 0.5196                 | 165        | 30.84         |
| 3                                 | 0.280                        | 0.5292                 | 165        | 31.40         |
| 4                                 | 0.240                        | 0.4899                 | 165        | 29.07         |
| 5                                 | 0.250                        | 0.5000                 | 165        | 29.67         |
| 6                                 | 0.230                        | 0.4796                 | 165        | 28.46         |
| Average                           | 0.2696                       | 0.5192                 | 165        | 30.81         |
| Flow Rate:                        | 1,452                        | wacfm                  |            |               |
| Flow Rate:                        | 1,164                        | scfm                   |            |               |
| Flow Rate:                        | 1,113                        | dscfm                  |            |               |

**DATA AND WORKSHEET**  
**RUN NUMBER 1**

| <b>TEST CONSTANTS</b>             |                              |                        |            |       |
|-----------------------------------|------------------------------|------------------------|------------|-------|
| Station:                          | Chiquita Canyon Landfill     |                        |            |       |
| Unit:                             | Flare Station Pre-H2S        |                        |            |       |
| Performed By:                     | 3/20/2025                    |                        |            |       |
| Cp:                               | 0.84                         |                        |            |       |
| T <sub>ref</sub> :                | 60                           | °F                     |            |       |
| Stack Area:                       | 3.142                        | ft <sup>2</sup>        |            |       |
| <b>TEST VARIABLES</b>             |                              |                        |            |       |
| Start Date:                       | 3/20/25                      |                        |            |       |
| Start/End Time:                   | 10:10                        | 10:40                  |            |       |
| Test Condition:                   | Normal                       |                        |            |       |
| Barom. Pressure:                  | 29.03                        |                        |            |       |
| Pstack:                           | -0.02                        | iwg                    |            |       |
| Pstack:                           | 29.03                        | "Hg                    |            |       |
| MW Wet:                           | 29.39                        | lb/lb-mole             |            |       |
| MW Dry:                           | 29.71                        | lb/lb-mole             |            |       |
| <b>Moisture</b>                   |                              |                        |            |       |
| Moisture Content:                 | 2.68 %                       | From WbDb              |            |       |
| <b>Fuel Gas Composistion Data</b> |                              |                        |            |       |
| O <sub>2</sub> :                  | 4.04 %                       | From canister analysis |            |       |
| CO <sub>2</sub> :                 | 42.98 %                      | From canister analysis |            |       |
| N <sub>2</sub> :                  | 17.50 %                      | From canister analysis |            |       |
| CH <sub>4</sub> :                 | 28.78 %                      | From canister analysis |            |       |
| <b>METHOD 2.1 DATA</b>            |                              |                        |            |       |
| Point                             | dP<br>(in. H <sub>2</sub> O) | Temp<br>sqrt(dP)       | Vel.<br>°F | (fps) |
| 1                                 | 0.026                        | 0.1612                 | 90         | 9.28  |
| 2                                 | 0.025                        | 0.1581                 | 90         | 9.10  |
| 3                                 | 0.028                        | 0.1673                 | 90         | 9.63  |
| 4                                 | 0.027                        | 0.1643                 | 90         | 9.46  |
| 5                                 | 0.029                        | 0.1703                 | 90         | 9.80  |
| 6                                 | 0.028                        | 0.1673                 | 90         | 9.63  |
| 7                                 | 0.031                        | 0.1761                 | 90         | 10.13 |
| 8                                 | 0.030                        | 0.1732                 | 90         | 9.97  |
| 1                                 | 0.033                        | 0.1817                 | 90         | 10.46 |
| 2                                 | 0.032                        | 0.1789                 | 90         | 10.30 |
| 3                                 | 0.033                        | 0.1817                 | 90         | 10.46 |
| 4                                 | 0.032                        | 0.1789                 | 90         | 10.30 |
| 5                                 | 0.037                        | 0.1924                 | 90         | 11.07 |
| 6                                 | 0.035                        | 0.1871                 | 90         | 10.77 |
| 7                                 | 0.038                        | 0.1949                 | 90         | 11.22 |
| 8                                 | 0.039                        | 0.1975                 | 90         | 11.37 |
| Average                           | 0.0313                       | 0.1769                 | 90         | 10.18 |
| Flow Rate:                        | 1,920                        | wacfm                  |            |       |
| Flow Rate:                        | 1,761                        | scfm                   |            |       |
| Flow Rate:                        | 1,714                        | dscfm                  |            |       |

**DATA AND WORKSHEET**  
**RUN NUMBER 1**

| <b>TEST CONSTANTS</b>                            |                              |            |               |  |
|--|------------------------------|------------|---------------|--|
| Station: Chiquita Canyon Landfill                |                              |            |               |  |
| Unit: Flare Station Post-H2S                     |                              |            |               |  |
| Performed By: 3/20/2025                          |                              |            |               |  |
| Cp: 0.84   |                              |            |               |  |
| T <sub>ref</sub> : 60 °F                         |                              |            |               |  |
| Stack Area: 3.142 ft <sup>2</sup>                |                              |            |               |  |
| <b>TEST VARIABLES</b>                            |                              |            |               |  |
| Start Date: 3/20/25                              |                              |            |               |  |
| Start/End Time: 10:10 10:40                      |                              |            |               |  |
| Test Condition: Normal                           |                              |            |               |  |
| Barom. Pressure: 29.03                           |                              |            |               |  |
| Pstack: 5.20 iwg                                 |                              |            |               |  |
| Pstack: 29.41 "Hg                                |                              |            |               |  |
| MW Wet: 29.41 lb/lb-mole                         |                              |            |               |  |
| MW Dry: 29.72 lb/lb-mole                         |                              |            |               |  |
| <b>Moisture</b>                                  |                              |            |               |  |
| Moisture Content: 2.64 % From WbDb               |                              |            |               |  |
| <b>Fuel Gas Composistion Data</b>                |                              |            |               |  |
| O <sub>2</sub> : 3.64 % From canister analysis   |                              |            |               |  |
| CO <sub>2</sub> : 43.53 % From canister analysis |                              |            |               |  |
| N <sub>2</sub> : 18.76 % From canister analysis  |                              |            |               |  |
| CH <sub>4</sub> : 25.95 % From canister analysis |                              |            |               |  |
| <b>METHOD 2.1 DATA</b>                           |                              |            |               |  |
| Point  | dP<br>(in. H <sub>2</sub> O) | Temp<br>°F | Vel.<br>(fps) |  |
| 1  | 0.031                        | 90         | 10.06         |  |
| 2  | 0.027                        | 90         | 9.39          |  |
| 3  | 0.025                        | 90         | 9.04          |  |
| 4  | 0.029                        | 90         | 9.73          |  |
| 5  | 0.028                        | 90         | 9.57          |  |
| 6  | 0.027                        | 90         | 9.39          |  |
| 7  | 0.029                        | 90         | 9.73          |  |
| 8  | 0.030                        | 90         | 9.90          |  |
| 1  | 0.025                        | 90         | 9.04          |  |
| 2  | 0.029                        | 90         | 9.73          |  |
| 3  | 0.031                        | 90         | 10.06         |  |
| 4  | 0.034                        | 90         | 10.54         |  |
| 5  | 0.033                        | 90         | 10.38         |  |
| 6  | 0.036                        | 90         | 10.85         |  |
| 7  | 0.034                        | 90         | 10.54         |  |
| 8  | 0.031                        | 90         | 10.06         |  |
| Average  | 0.0299                       | 90         | 9.88          |  |
| Flow Rate: 1,862 wacfm                           |                              |            |               |  |
| Flow Rate: 1,731 scfm                            |                              |            |               |  |
| Flow Rate: 1,685 dscfm                           |                              |            |               |  |

## FLUE GAS VELOCITY DATA AND WORKSHEET

CLIENT: W/C SCS

PERFORMED BY: SS, KT

BAR. PRESSURE: 29.03

DP INDICATOR ID: ADM 800 #9

DP INDICATOR TYPE: Electronic

LOCATION/UNIT: CHIQUITA

TEST DATE: 3/20/25

TC READOUT ID: PTC 43

TC ID: W(B58) DB

TUBE ID: 145 Cp:

TANK Farm 6

DP INDICATOR TYPE: ELECTRONIC PITOT TUBE ID: 145 Cp: 0.84

ZERO

LEVEL: ✓ LEA

CHECK PRE-  POS

✓ BA

LANCE CH

ECK WE

## WEIGHT

— 1 —









## FLUE GAS VELOCITY DATA AND WORKSHEET

CLIENT: W/C SCS

LOCATION/UNIT: CHIQUITA TANK FARM 7B

PERFORMED BY: JS KT

TEST DATE: 3/20/25

BAR. PRESSURE: 29.03

TC READOUT ID: PTC 43

DP INDICATOR ID: ADM 350#9

TC ID: DB

DP INDICATOR TYPE: ELECTRONIC

PITOT TUBE ID: 146

Cp: 0.84

ZERO: ✓

LEVEL: ✓

LEAK CHECK PRE- ✓

POST- ✓

BALANCE CHECK WEIGHT ✓

| Run #:               | Ps:                                  | Run #:               | Ps:                   | Run #:                               | Ps:      |              |                                      |          |
|----------------------|--------------------------------------|----------------------|-----------------------|--------------------------------------|----------|--------------|--------------------------------------|----------|
| Start:               | Stop:                                | Start:               | Stop:                 | Start:                               | Stop:    |              |                                      |          |
| Sample Point         | Vel. Head<br>inches H <sub>2</sub> O | Temp, °F             | Excl.<br>Sample Point | Vel. Head<br>inches H <sub>2</sub> O | Temp, °F | Sample Point | Vel. Head<br>inches H <sub>2</sub> O | Temp, °F |
| 1                    | 0.007                                | 79                   | 6                     |                                      |          |              |                                      |          |
| 2                    | 0.009                                | 79                   | 6                     |                                      |          |              |                                      |          |
| 3                    | 0.008                                | 79                   | 5                     |                                      |          |              |                                      |          |
| 4                    | 0.009                                | 79                   | 1                     |                                      |          |              |                                      |          |
| 5                    | 0.008                                | 79                   | 0                     |                                      |          |              |                                      |          |
| 6                    | 0.007                                | 79                   | 1                     |                                      |          |              |                                      |          |
| 7                    | 0.006                                | 79                   | 4                     |                                      |          |              |                                      |          |
| 8                    | 0.009                                | 79                   | 2                     |                                      |          |              |                                      |          |
| 9                    | 0.010                                | 79                   | 1                     |                                      |          |              |                                      |          |
| 10                   | 0.011                                | 79                   | 3                     |                                      |          |              |                                      |          |
| 11                   | 0.006                                | 79                   | 5                     |                                      |          |              |                                      |          |
| 12                   | 0.005                                | 79                   | 1                     |                                      |          |              |                                      |          |
| Heated Line Temp. °F | N/A                                  | Heated Line Temp. °F |                       | Heated Line Temp. °F.                |          |              |                                      |          |
| Chiller Temp. °C     |                                      | Chiller Temp. °C     |                       | Chiller Temp. °C                     |          |              |                                      |          |



## FLUE GAS VELOCITY DATA AND WORKSHEET

CLIENT: W/C SCS

PERFORMED BY:  KT

PERI STIMED BY: 201  
BAR. PRESSURE: 29.02

DP INDICATOR ID: A9M

DP INDICATOR TYPE: EST 2021

ZERO:  LEVEL:  LEAK:

Score

LOCATION/UNIT: CHIQUITA PLANE STATION PRE #25  
TEST DATE: 1/26/02

TEST DATE: 3/20/25

TC READOUT ID: 75643

TC ID: 1246

UBE ID: 1 TL

RE-  POST-

RE 1001

RE 1001

Cp: 0.84

Op. 3 1

BRUNNEN

Run #: 1  
Start: 1010

Ps: 7020  
Step: 1040

Run #: \_\_\_\_\_

Ps: \_\_\_\_\_

Run #: \_\_\_\_\_

1

CLIENT: W/C SCS

## FLUE GAS VELOCITY DATA AND WORKSHEET

CLIENT: W/C 305

LOCATION/UNIT: CHIQUITA FLARE STATION Post H2S

PERFORMED BY: ST/CT

TEST DATE: 3/20/25

BAR. PRESSURE: 29

TC READOUT ID: 146

DP INDICATOR ID: ADM 850 #9

TC ID: 146

DP INDICATOR TYPE: Electron

TUBE ID: 146

## ZERO:

LEVEL: \_\_\_\_\_

LEAK CHECK PRE-  POST-

**BALANCE CHECK WEIGHT**

Heated Line Temp. °F

Heated Line Temp. °F

Heated Line Temp. °F.

Chiller Temp. °C

Chiller Temp. °C

Chiller Temp. °C

## **Appendix A.3**

### **Organics and Sulfur Field and Laboratory Data**

## LEACHATE TANK HEADSPACE SAMPLING DATA

Client/Facility: CHIQUITA Date: 3/20/25

Unit/Location: TANK FARM 6 Performed By: ST/KT

Barometric Pressure 29.03 Ambient Temperature 78°

### SUMMA CANISTER DATA

| Test No.              |       | 1     |        |
|-----------------------|-------|-------|--------|
| Canister ID           |       | 51383 |        |
|                       |       | Time  | Vacuum |
| Pre-Test Leak Check   | Start | 0740  | 30     |
| Pre-Test Leak Check   | Stop  | 0750  | 30     |
| Sample Collection     | Start | 0815  | 30     |
|                       | 10    | 0825  | 21     |
|                       | 20    | 0835  | 12     |
| End →                 | 30    | 0845  | 5      |
|                       |       |       |        |
|                       |       |       |        |
|                       |       |       |        |
| Sample Collection     | Stop  |       |        |
| Post -Test Leak Check | Start | 1050  | 5      |
| Post -Test Leak Check | Stop  | 1100  | 5      |

### FLOWRATE DATA

Diameter: 6.0"

Upstream: 78"

Downstream: 48"

Flow Rate: —

Wet bulb: 61

Dry bulb: 81

### TEDLAR BAG DATA

Start: N/A

Stop: N/A

Bag ID: —

## LEACHATE TANK HEADSPACE SAMPLING DATA

Client/Facility: CHIQUITA Date: 3/20/25

Unit/Location: TANK FARM 9A Performed By: ST/KT

Barometric Pressure 29.03 Ambient Temperature 78°

### SUMMA CANISTER DATA

|                       |       |        |    |
|-----------------------|-------|--------|----|
| Test No.              | 1     |        |    |
| Canister ID           | 49442 |        |    |
|                       | Time  | Vacuum |    |
| Pre-Test Leak Check   | Start | 0740   | 30 |
| Pre-Test Leak Check   | Stop  | 0750   | 30 |
| Sample Collection     | Start | 0855   | 30 |
|                       | 10    | 0905   | 22 |
|                       | 20    | 0915   | 13 |
| →END                  | 30    | 0925   | 5  |
|                       |       |        |    |
|                       |       |        |    |
|                       |       |        |    |
| Sample Collection     | Stop  |        |    |
| Post -Test Leak Check | Start | 1050   | 5  |
| Post-Test Leak Check  | Stop  | 1100   | 5  |

### FLOWRATE DATA

Diameter: 12"

Upstream: 96"

Downstream: 96"

Flow Rate: —

Wet bulb: 81.7855

Dry bulb: 78

### TEDLAR BAG DATA

Start: N/A

Stop: N/A

Bag ID:

## LEACHATE TANK HEADSPACE SAMPLING DATA

Client/Facility: CHIQUITA Date: 3/20/25  
 Unit/Location: TANK Farm 93 Performed By: ST/KT  
 Barometric Pressure 29.03 Ambient Temperature 78°

### SUMMA CANISTER DATA

| Test No.              |       | 1     |        |
|-----------------------|-------|-------|--------|
| Canister ID           |       | 48469 |        |
|                       |       | Time  | Vacuum |
| Pre-Test Leak Check   | Start | 0740  | 30     |
| Pre-Test Leak Check   | Stop  | 0750  | 30     |
| Sample Collection     | Start | 0858  | 30     |
|                       |       | 10    | 0905   |
|                       |       | 20    | 0915   |
| end →                 | 30    | 0925  | 5      |
|                       |       |       |        |
|                       |       |       |        |
|                       |       |       |        |
| Sample Collection     | Stop  |       |        |
| Post -Test Leak Check | Start | 1050  | 5      |
| Post -Test Leak Check | Stop  | 1100  | 5      |

### FLOWRATE DATA

Diameter: 12"  
 Upstream: 96"  
 Downstream: 96"  
 Flow Rate: —  
 Wet bulb: 55  
 Dry bulb: 76

### TEDLAR BAG DATA

Start: —  
 Stop: N/A  
 Bag ID: —

## LEACHATE TANK HEADSPACE SAMPLING DATA

Client/Facility: CHEMQUITA Date: 3/20/25  
 Unit/Location: TANK FARM 2 Performed By: ST/KT  
 Barometric Pressure 29.03 Ambient Temperature 78°

### SUMMA CANISTER DATA

| Test No.              |       | 1            |        |
|-----------------------|-------|--------------|--------|
| Canister ID           |       | 46911        |        |
|                       |       | Time         | Vacuum |
| Pre-Test Leak Check   | Start | 0740         | 32     |
| Pre-Test Leak Check   | Stop  | 0750         | 32     |
| Sample Collection     | Start | 0700         | 32     |
|                       | 10    | 0910         | 23     |
|                       | 20    | 0920         | 14     |
| End →                 | 30    | 0930         | 5      |
|                       |       |              |        |
|                       |       |              |        |
|                       |       |              |        |
| Sample Collection     | Stop  |              |        |
| Post -Test Leak Check | Start | 1050<br>1040 | 5      |
| Post-Test Leak Check  | Stop  | 1100<br>1050 | 5      |

(60)  
m/s

### FLOWRATE DATA

Diameter: 6"  
 Upstream: 48"  
 Downstream: 48"  
 Flow Rate: —  
 Wet bulb: 54  
 Dry bulb: 77

### TEDLAR BAG DATA

Start: N/A  
 Stop: N/A  
 Bag ID: —

## LEACHATE TANK HEADSPACE SAMPLING DATA

Client/Facility: CH, QUITA Date: 3/20/25

Unit/Location: TANK FARM 7A Performed By: ST / KT

Barometric Pressure 29.27 Ambient Temperature 28°

### SUMMA CANISTER DATA

| Test No.              |       | 1     |        |
|-----------------------|-------|-------|--------|
| Canister ID           |       | 47728 |        |
|                       |       | Time  | Vacuum |
| Pre-Test Leak Check   | Start | 0740  | 30     |
| Pre-Test Leak Check   | Stop  | 0750  | 30     |
| Sample Collection     | Start | 0938  | 30     |
|                       |       | 10    | 22     |
|                       |       | 20    | 14     |
| Ends                  | 30    | 1005  | 5      |
|                       |       |       |        |
|                       |       |       |        |
|                       |       |       |        |
| Sample Collection     | Stop  |       |        |
| Post -Test Leak Check | Start | 1050  | 5      |
| Post-Test Leak Check  | Stop  | 1100  | 5      |

### FLOWRATE DATA

Diameter: 12"

Upstream: 74"

Downstream: 94"

Flow Rate: —

Wet bulb: 57

Dry bulb: 77

### TEDLAR BAG DATA

Start: —

Stop: N/A

Bag ID: —

## LEACHATE TANK HEADSPACE SAMPLING DATA

Client/Facility: CHIQUITA Date: 3/20/25

Unit/Location: TANK FARM 1B Performed By: ST/KT

Barometric Pressure 29.03 Ambient Temperature 78°

### SUMMA CANISTER DATA

| Test No.              | 1     |        |    |
|-----------------------|-------|--------|----|
| Canister ID           | 48864 |        |    |
|                       | Time  | Vacuum |    |
| Pre-Test Leak Check   | Start | 0740   | 30 |
| Pre-Test Leak Check   | Stop  | 0750   | 30 |
| Sample Collection     | Start | 0935   | 30 |
|                       | 10    | 0945   | 21 |
|                       | 20    | 0955   | 13 |
| end                   | 30    | 1005   | 5  |
|                       |       |        |    |
|                       |       |        |    |
|                       |       |        |    |
|                       |       |        |    |
| Sample Collection     | Stop  |        |    |
| Post -Test Leak Check | Start | 1050   | 5  |
| Post-Test Leak Check  | Stop  | 1100   | 5  |
|                       |       |        |    |

### FLOWRATE DATA

Diameter: 12"

Upstream: 180'

Downstream: 180'

Flow Rate: —

Wet bulb: 57

Dry bulb: 79

### TEDLAR BAG DATA

Start: N/A

Stop: N/A

Bag ID: —

## LEACHATE TANK HEADSPACE SAMPLING DATA

Client/Facility: CHIQUITA Date: 3/20/25  
 Unit/Location: ZEECO Performed By: ST/KT  
 Barometric Pressure 29.03 Ambient Temperature 78°

### SUMMA CANISTER DATA

| Test No.              |       | 1     |        |
|-----------------------|-------|-------|--------|
| Canister ID           |       | 51125 |        |
|                       |       | Time  | Vacuum |
| Pre-Test Leak Check   | Start | 0740  | 30     |
| Pre-Test Leak Check   | Stop  | 0750  | 30     |
| Sample Collection     | Start | 0935  | 30     |
|                       |       | 10    | 0945   |
|                       |       | 20    | 0955   |
| end →                 | 30    | 1005  | 5      |
|                       |       |       |        |
|                       |       |       |        |
|                       |       |       |        |
| Sample Collection     | Stop  |       |        |
| Post -Test Leak Check | Start | 1050  | 5      |
| Post-Test Leak Check  | Stop  | 1100  | 5      |

### FLOWRATE DATA

Diameter: 12"  
 Upstream: 180"  
 Downstream: 180"  
 Flow Rate: —  
 Wet bulb: 100  
 Dry bulb: 165

### TEDLAR BAG DATA

Start: —  
 Stop: N/A  
 Bag ID: —

## LEACHATE TANK HEADSPACE SAMPLING DATA

Client/Facility: CHIQUITA Date: 3/20/25

Unit/Location: EVANE STATION PRE H2P Performed By: ST/KT

Barometric Pressure 29.03 Ambient Temperature 78°

### SUMMA CANISTER DATA

| Test No.              | 1     |        |    |
|-----------------------|-------|--------|----|
| Canister ID           | 49439 |        |    |
|                       | Time  | Vacuum |    |
| Pre-Test Leak Check   | Start | 0740   | 30 |
| Pre-Test Leak Check   | Stop  | 0750   | 30 |
| Sample Collection     | Start | 1010   | 30 |
|                       | 10    | 1020   | 23 |
|                       | 20    | 1030   | 13 |
| End →                 | 30    | 1040   | 5  |
|                       |       |        |    |
|                       |       |        |    |
|                       |       |        |    |
| Sample Collection     | Stop  |        |    |
| Post -Test Leak Check | Start | 1050   | 5  |
| Post-Test Leak Check  | Stop  | 1100   | 5  |

### FLOWRATE DATA

Diameter: 24"

Upstream: 180"

Downstream: 180"

Flow Rate: —

Wet bulb: 26

Dry bulb: 90

### TEDLAR BAG DATA

Start: N/A

Stop: N/A

Bag ID:

## LEACHATE TANK HEADSPACE SAMPLING DATA

Client/Facility: CHIQUITA Date: 3/20/25

Unit/Location: FLAME STATION Post H2S Performed By: SJ/LT

Barometric Pressure 29.03 Ambient Temperature 78°

### SUMMA CANISTER DATA

| Test No.              |       | 1     |        |
|-----------------------|-------|-------|--------|
| Canister ID           |       | 46611 |        |
|                       |       | Time  | Vacuum |
| Pre-Test Leak Check   | Start | 0740  | 30     |
| Pre-Test Leak Check   | Stop  | 0750  | 30     |
| Sample Collection     | Start | 1010  | 30     |
|                       | 10    | 1020  | 23     |
|                       | 20    | 1030  | 13     |
| Post-Test             | 30    | 1040  | 5      |
|                       |       |       |        |
|                       |       |       |        |
|                       |       |       |        |
| Sample Collection     | Stop  |       |        |
| Post -Test Leak Check | Start | 1050  | 5      |
| Post-Test Leak Check  | Stop  | 1100  | 5      |

### FLOWRATE DATA

Diameter: 24"

Upstream: 180"

Downstream: 180"

Flow Rate: —

Wet bulb: 76

Dry bulb: 70

### TEDLAR BAG DATA

Start: N/A

Stop: N/A

Bag ID: —



**AtmAA** Inc.

5107 Douglas Fir Rd., Calabasas, CA 91302 • (818) 223-3277

specialized air assessment laboratory  
atmaa.com

## LABORATORY ANALYSIS REPORT

Permanent Gases Analysis in Silco Canister Samples by Method ASTM D1946-90

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Project No.: PROJ-053154

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

### ANALYSIS DESCRIPTION


*Permanent gases were measured by thermal conductivity detection/gas chromatography (TCD/GC), ASTM D1946-90.*

| AtmAA Lab No.: | 20795-31    | 20795-32     | 20795-33     |
|----------------|-------------|--------------|--------------|
| Sample I.D.:   | Tank Farm 6 | Tank Farm 9A | Tank Farm 9B |

| Components     | (Concentration in %,v) |       |       |
|----------------|------------------------|-------|-------|
| Nitrogen       | 77.59                  | 74.80 | 77.27 |
| Oxygen         | 21.82                  | 21.17 | 21.88 |
| Methane        | <0.14                  | 0.75  | <0.14 |
| Carbon dioxide | <0.14                  | 2.64  | <0.14 |

*The reported oxygen concentration includes any argon present in the sample. Calibration is based on a standard atmosphere containing 20.95% oxygen and 0.93% argon.*

*The accuracy of permanent gas analysis by TCD/GC is +/- 2%, actual results are reported. Actual analysis results are reported on a "wet" basis.*



*Brian W. Fung*  
Laboratory Director

**QUALITY ASSURANCE SUMMARY**  
**(Repeat Analyses)**

Project Location: Chiquita Landfill  
 Date Received: March 20, 2025  
 Date Analyzed: March 21, 2025

| Components     | Sample ID   | Repeat Analysis |        | Mean Conc. | % RPD |
|----------------|-------------|-----------------|--------|------------|-------|
|                |             | Run #1          | Run #2 |            |       |
| Nitrogen       | Tank Farm 6 | 77.98           | 77.19  | 77.59      | 1.0   |
| Oxygen         | Tank Farm 6 | 21.86           | 21.77  | 21.82      | 0.41  |
| Methane        | Tank Farm 6 | <0.14           | <0.14  | ---        | ---   |
| Carbon dioxide | Tank Farm 6 | <0.14           | <0.14  | ---        | ---   |

*Three Silco canister samples, laboratory numbers 20795-(31-33), were analyzed for permanent gases. Agreement between repeat analyses is a measure of precision and is shown above in the column "% RPD". The average % RPD for 2 repeat measurements from three Silco canister samples is 0.72%.*





AtmAA Inc.

5107 Douglas Fir Rd., Calabasas, CA 91302 • (818) 223-3277

specialized air assessment laboratory  
atmaa.com

## LABORATORY ANALYSIS REPORT

### Speciated Hydrocarbons Analysis in Silco Canister Samples

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Project No.: PROJ-053154

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

Laboratory Temp: 73.5 °F

Barometric Pressure: 29.95 inHg

### ANALYSIS DESCRIPTION

Hydrocarbon speciation analysis was performed by flame ionization detection/gas chromatography (FID/GC), modified EPA-18. Methane was measured by thermal conductivity detection/gas chromatography (TCD/GC), ASTM D1946-90

| AtmAA Lab No.:<br>Sample ID: | 20795-31<br>Tank Farm 6 | 20795-32<br>Tank Farm 9A | 20795-33<br>Tank Farm 9B |
|------------------------------|-------------------------|--------------------------|--------------------------|
|------------------------------|-------------------------|--------------------------|--------------------------|

| Component | (Concentration in ppmv, component) |       |       |
|-----------|------------------------------------|-------|-------|
| Methane   | 300                                | 7500  | 26.4  |
| Ethene    | <0.30                              | 6.48  | <0.20 |
| Acetylene | <0.30                              | <0.30 | <0.20 |
| Ethane    | <0.30                              | 7.12  | <0.20 |

Non-methane hydrocarbons  
analysis by carbon  
number grouping

|     |       |      |       |
|-----|-------|------|-------|
| C3  | <0.10 | 22.3 | <0.10 |
| C4  | 70.0  | 75.5 | 31.9  |
| C5  | 60.0  | 71.3 | 29.5  |
| C6  | 42.0  | 96.3 | 21.7  |
| C7  | 7.57  | 36.0 | 5.18  |
| C8  | 7.29  | 29.4 | 4.69  |
| C9  | 4.90  | 29.0 | 8.17  |
| C10 | 9.27  | 26.5 | 23.1  |
| C11 | 1.28  | 5.35 | 7.17  |
| C12 | 0.65  | 3.12 | 6.87  |
| C13 | 0.24  | 2.03 | 9.36  |
| C14 | <0.06 | 0.51 | 2.16  |

|       |                          |      |      |
|-------|--------------------------|------|------|
|       | (Concentration in ppmvC) |      |      |
| TNMHC | 1105                     | 2473 | 1096 |

TNMHC - total non-methane hydrocarbons as ppmvC.  
Actual analysis results are reported on a "wet" basis.


Brian W. Fung  
Laboratory Director

**QUALITY ASSURANCE SUMMARY**  
*(Repeat Analyses)*

Project Location: Chiquita Landfill  
 Date Received: March 20, 2025  
 Date Analyzed: March 21, 2025

| Component  | Sample ID   | Repeat Analysis |        | Mean Conc. | % RPD |
|--|-------------|-----------------|--------|------------|-------|
|  |             | Run #1          | Run #2 |            |       |
| Methane  | Tank Farm 6 | 254             | 254    | 254        | 0.08  |
| Ethene   | Tank Farm 6 | <0.30           | <0.30  | <0.30      | ---   |
| Acetylene  | Tank Farm 6 | <0.30           | <0.30  | <0.30      | ---   |
| Ethane   | Tank Farm 6 | <0.30           | <0.30  | <0.30      | ---   |
| <u>non-methane hydrocarbons analysis by carbon number grouping</u> |             |                 |        |            |       |
| C3   | Tank Farm 6 | <0.10           | <0.10  | <0.10      | ---   |
| C4   | Tank Farm 6 | 70.0            | 69.9   | 70.0       | 0.09  |
| C5   | Tank Farm 6 | 60.0            | 60.1   | 60.0       | 0.17  |
| C6   | Tank Farm 6 | 42.0            | 41.9   | 42.0       | 0.26  |
| C7   | Tank Farm 6 | 7.70            | 7.45   | 7.57       | 3.3   |
| C8   | Tank Farm 6 | 7.44            | 7.13   | 7.29       | 4.2   |
| C9   | Tank Farm 6 | 4.86            | 4.95   | 4.90       | 1.7   |
| C10  | Tank Farm 6 | 9.17            | 9.37   | 9.27       | 2.1   |
| C11  | Tank Farm 6 | 1.08            | 1.48   | 1.28       | 31    |
| C12  | Tank Farm 6 | 0.61            | 0.69   | 0.65       | 12    |
| C13  | Tank Farm 6 | 0.24            | 0.25   | 0.24       | 4.5   |
| C14  | Tank Farm 6 | <0.06           | <0.06  | <0.06      | ---   |
| (Concentration in ppmvC)   |             |                 |        |            |       |
| TNMHC  | Tank Farm 6 | 1103            | 1107   | 1105       | 0.32  |

*Three Silco canister samples, laboratory numbers 20795-(31-33), were analyzed for hydrocarbon speciation, EPA Method 18. Agreement between repeat analyses is a measure of precision and is shown above in the column "% RPD". The average % RPD for 12 repeat measurements from three Silco canister samples is 5.0%.*





**AtmAA** Inc.

5107 Douglas Fir Rd., Calabasas, CA 91302 • (818) 223-3277

specialized air assessment laboratory  
atmaa.com

## LABORATORY ANALYSIS REPORT

### Hydrogen Sulfide and Reduced Sulfur Compounds Analysis in Silco Canister Sample by SCAQMD Method 307.91

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Project No.: PROJ-053154

Date Received: March 20, 2025

Date Analyzed: March 20, 2025

## ANALYSIS DESCRIPTION

*Total sulfur analysis measured by gas chromatography with sulfur chemiluminescence detector (SCD), SCAQMD 307.91.*

| AtmAA Lab No.:<br>Sample I.D.:                    | 20795-31<br>Tank Farm 6        | 20795-32<br>Tank Farm 9A | 20795-33<br>Tank Farm 9B |
|---|--------------------------------|--------------------------|--------------------------|
| <u>Components</u>                                 | <i>(Concentration in ppmv)</i> |                          |                          |
| Hydrogen sulfide                                  | <0.10                          | 10.5                     | <0.10                    |
| Carbonyl sulfide                                  | <0.10                          | <0.10                    | <0.10                    |
| Methyl mercaptan                                  | 0.12                           | 14.6                     | <0.10                    |
| Ethyl mercaptan                                   | <0.10                          | 0.22                     | <0.10                    |
| Dimethyl sulfide                                  | 3.54                           | 49.9                     | 1.76                     |
| Carbon disulfide                                  | <0.10                          | <0.10                    | <0.10                    |
| i-Propyl mercaptan                                | <0.10                          | 0.17                     | <0.10                    |
| t-Butyl mercaptan                                 | <0.10                          | <0.10                    | <0.10                    |
| n-Propyl mercaptan                                | <0.10                          | <0.10                    | <0.10                    |
| s-Butyl mercaptan                                 | <0.10                          | 0.76                     | <0.10                    |
| i-Butyl mercaptan                                 | <0.10                          | <0.10                    | <0.10                    |
| Dimethyl disulfide                                | <0.10                          | 0.30                     | <0.10                    |
| Tetrahydrothiophene                               | <0.10                          | 0.38                     | <0.10                    |
| Unidentified sulfurs                              | <0.10                          | 2.18                     | <0.10                    |
| <i>(Concentration in ppmv, as H<sub>2</sub>S)</i> |                                |                          |                          |
| Total Sulfur                                      | 3.66                           | 79.24                    | 1.76                     |

  
\_\_\_\_\_  
Brian W. Fung  
Laboratory Director

**QUALITY ASSURANCE SUMMARY**  
*(Repeat Analyses)*

Project Location: Chiquita Landfill

Date Received: March 20, 2025

Date Analyzed: March 20, 2025

| Components              | Sample ID    | Repeat Analysis |        | Mean Conc. | % RPD |
|-------------------------|--------------|-----------------|--------|------------|-------|
|                         |              | Run #1          | Run #2 |            |       |
| (Concentration in ppmv) |              |                 |        |            |       |
| Hydrogen sulfide        | Tank Farm 6  | <0.10           | <0.10  | ---        | ---   |
|                         | Tank Farm 9A | 10.6            | 10.4   | 10.5       | 1.9   |
|                         | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |
| Carbonyl sulfide        | Tank Farm 6  | <0.10           | <0.10  | ---        | ---   |
|                         | Tank Farm 9A | <0.10           | <0.10  | ---        | ---   |
|                         | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |
| Methyl mercaptan        | Tank Farm 6  | 0.12            | 0.12   | 0.12       | 0.00  |
|                         | Tank Farm 9A | 14.6            | 14.5   | 14.6       | 0.69  |
|                         | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |
| Ethyl mercaptan         | Tank Farm 6  | <0.10           | <0.10  | ---        | ---   |
|                         | Tank Farm 9A | 0.22            | 0.22   | 0.22       | 0.00  |
|                         | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |
| Dimethyl sulfide        | Tank Farm 6  | 3.55            | 3.52   | 3.54       | 0.85  |
|                         | Tank Farm 9A | 50.3            | 49.5   | 49.9       | 1.6   |
|                         | Tank Farm 9B | 1.77            | 1.74   | 1.76       | 1.7   |
| Carbon disulfide        | Tank Farm 6  | <0.10           | <0.10  | ---        | ---   |
|                         | Tank Farm 9A | <0.10           | <0.10  | ---        | ---   |
|                         | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |
| i-Propyl mercaptan      | Tank Farm 6  | <0.10           | <0.10  | ---        | ---   |
|                         | Tank Farm 9A | 0.17            | 0.16   | 0.17       | 6.1   |
|                         | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |
| t-Butyl mercaptan       | Tank Farm 6  | <0.10           | <0.10  | ---        | ---   |
|                         | Tank Farm 9A | <0.10           | <0.10  | ---        | ---   |
|                         | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |
| n-Propyl mercaptan      | Tank Farm 6  | <0.10           | <0.10  | ---        | ---   |
|                         | Tank Farm 9A | <0.10           | <0.10  | ---        | ---   |
|                         | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |
| s-Butyl mercaptan       | Tank Farm 6  | <0.10           | <0.10  | ---        | ---   |
|                         | Tank Farm 9A | 0.76            | 0.75   | 0.76       | 1.3   |
|                         | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |



QUALITY ASSURANCE SUMMARY  
(Repeat Analyses)  
(continued)

| Components           | Sample ID    | Repeat Analysis |        | Mean Conc. | % RPD |
|----------------------|--------------|-----------------|--------|------------|-------|
|                      |              | Run #1          | Run #2 |            |       |
| i-Butyl mercaptan    | Tank Farm 6  | <0.10           | <0.10  | ---        | ---   |
|                      | Tank Farm 9A | <0.10           | <0.10  | ---        | ---   |
|                      | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |
| Dimethyl disulfide   | Tank Farm 6  | <0.10           | <0.10  | ---        | ---   |
|                      | Tank Farm 9A | 0.31            | 0.29   | 0.30       | 6.7   |
|                      | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |
| Tetrahydrothiophene  | Tank Farm 6  | <0.10           | <0.10  | ---        | ---   |
|                      | Tank Farm 9A | 0.38            | 0.37   | 0.38       | 2.7   |
|                      | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |
| Unidentified sulfurs | Tank Farm 6  | <0.10           | <0.10  | ---        | ---   |
|                      | Tank Farm 9A | 2.19            | 2.16   | 2.18       | 1.4   |
|                      | Tank Farm 9B | <0.10           | <0.10  | ---        | ---   |

*Three Silco canister samples, laboratory numbers 20795-(31-33), were analyzed for total sulfur compounds. Agreement between repeat analyses is a measure of precision and is shown above in the column "% RPD". The average % RPD for 12 repeat measurements from three Silco canister samples is 2.1%.*



## Calculated values for Specific Volume, BTU, and F (factor)

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

AtmAA Lab #: 20795-31

Sample ID: Tank Farm 6

Specific volume, BTU, and F-factor are calculated using normalized laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TNMHC, and sulfur compounds in equations that include gross/net heating and specific gas volume values taken from the GPA-2145 Midstream Standard. Heating value factor is a calculated according to ASTM 3588-98 (14.696 psia and 60°F).

| Component  | Mole % | Wt %   | C,H,O,N,S, | Wt.%         |
|--|--------|--------|------------|--------------|
| Methane  | 0.00   | 0.00   | Carbon     | 0.05         |
| Carbon dioxide                                       | 0.00   | 0.00   | Hydrogen   | 0.01         |
| Nitrogen   | 78.04  | 75.45  | Oxygen     | 23.21        |
| Oxygen   | 21.01  | 23.21  | Nitrogen   | 75.46        |
| Argon  | 0.93   | 1.28   | Argon      | 1.28         |
| Hydrogen   | 0.00   | 0.00   | Sulfur     | 0.00         |
| (CH <sub>2</sub> ) <sub>n</sub>                      | 0.020  | 0.06   |            |              |
| Specific Volume                                      |        | 13.091 |            |              |
| BTU/ft <sup>3</sup> (Dry @60F, 14.696 psia)          |        | 0.8850 | (HHV)      | 0.8189 (LHV) |
| BTU/ft <sup>3</sup> (Water Saturated @ 0.25636 psia) |        | 0.8695 | (HHV)      | 0.8046 (LHV) |
| BTU/lb (Dry @60F, 14.696 psia)                       |        | 11.59  | (HHV)      | 10.72 (LHV)  |
| Compressibility Factor (@60F, 14.696 psia)           |        | 0.9996 |            |              |
| Wobbe Index  |        | 0.8907 |            |              |
| Specific Gravity                                     |        | 0.9871 |            |              |

| Component      | Specific volume<br>reference values * |
|----------------|---------------------------------------|
| Methane        | 23.7 (ft <sup>3</sup> /lb)            |
| Carbon dioxide | 8.62                                  |
| Nitrogen       | 13.5                                  |
| Oxygen         | 11.9                                  |
| Argon          | 9.52                                  |
| Hydrogen       | 188.2                                 |

\* reference, Rev. 2016, GPA-2145 Midstream Standard, Selected Hydrocarbons 60°F



## Calculated values for Specific Volume, BTU, and F (factor)

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

AtmAA Lab #: 20795-32

Sample ID: Tank Farm 9A

Specific volume, BTU, and F-factor are calculated using normalized laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TNMHC, and sulfur compounds in equations that include gross/net heating and specific gas volume values taken from the GPA-2145 Midstream Standard. Heating value factor is calculated according to ASTM 3588-98 (14.696 psia and 60°F).

| Component  | Mole %        | Wt %         | C,H,O,N,S, Wt.% |              |
|--|---------------|--------------|-----------------|--------------|
| Methane  | 0.75          | 0.41         | Carbon          | 1.50         |
| Carbon dioxide                                       | 2.66          | 3.99         | Hydrogen        | 0.12         |
| Nitrogen   | 75.25         | 71.95        | Oxygen          | 25.19        |
| Oxygen   | 20.39         | 22.29        | Nitrogen        | 71.95        |
| Argon  | 0.90          | 1.24         | Argon           | 1.24         |
| Hydrogen<br>(CH <sub>2</sub> ) <sub>n</sub>          | 0.00<br>0.041 | 0.00<br>0.12 | Sulfur          | 0.00         |
| Specific Volume                                      |               | 12.948       |                 |              |
| BTU/ft <sup>3</sup> (Dry @60F, 14.696 psia)          |               | 9.596        | (HHV)           | 8.691 (LHV)  |
| BTU/ft <sup>3</sup> (Water Saturated @ 0.25636 psia) |               | 9.429        | (HHV)           | 8.540 (LHV)  |
| BTU/lb (Dry @60F, 14.696 psia)                       |               | 124.25       | (HHV)           | 112.53 (LHV) |
| F <sub>d</sub> (factor)                              |               | 9895         |                 |              |
| F <sub>w</sub> (factor)                              |               | 11805        |                 |              |
| F <sub>c</sub> (factor)                              |               | 3874         |                 |              |
| Compressibility Factor (@60F, 14.696 psia)           |               | 0.9996       |                 |              |
| Wobbe Index  |               | 9.6014       |                 |              |
| Specific Gravity                                     |               | 0.9989       |                 |              |

| Component      | Specific volume<br>reference values * |
|----------------|---------------------------------------|
| Methane        | 23.7 (ft <sup>3</sup> /lb)            |
| Carbon dioxide | 8.62                                  |
| Nitrogen       | 13.5                                  |
| Oxygen         | 11.9                                  |
| Argon          | 9.52                                  |
| Hydrogen       | 188.2                                 |

\* reference, Rev. 2016, GPA-2145 Midstream Standard, Selected Hydrocarbons 60°F



## Calculated values for Specific Volume, BTU, and F (factor)

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

AtmAA Lab #: 20795-33

Sample ID: Tank Farm 9B

Specific volume, BTU, and F-factor are calculated using normalized laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TNMHC, and sulfur compounds in equations that include gross/net heating and specific gas volume values taken from the GPA-2145 Midstream Standard. Heating value factor is calculated according to ASTM 3588-98 (14.696 psia and 60°F).

| Component  | Mole % | Wt %   | C,H,O,N,S | Wt.%  |
|--|--------|--------|-----------|-------|
| Methane  | 0.00   | 0.00   | Carbon    | 0.05  |
| Carbon dioxide                                       | 0.00   | 0.00   | Hydrogen  | 0.01  |
| Nitrogen   | 77.92  | 75.31  | Oxygen    | 23.34 |
| Oxygen   | 21.13  | 23.34  | Nitrogen  | 75.31 |
| Argon  | 0.94   | 1.29   | Argon     | 1.29  |
| Hydrogen   | 0.00   | 0.00   | Sulfur    | 0.00  |
| (CH <sub>2</sub> ) <sub>n</sub>                      | 0.015  | 0.05   |           |       |
| Specific Volume                                      |        | 13.088 |           |       |
| BTU/ft <sup>3</sup> (Dry @60F, 14.696 psia)          | 0.8666 | (HHV)  | 0.8034    | (LHV) |
| BTU/ft <sup>3</sup> (Water Saturated @ 0.25636 psia) | 0.8515 | (HHV)  | 0.7894    | (LHV) |
| BTU/lb (Dry @60F, 14.696 psia)                       | 11.34  | (HHV)  | 10.52     | (LHV) |
| Compressibility Factor (@60F, 14.696 psia)           | 0.9996 |        |           |       |
| Wobbe Index  |        | 0.8715 |           |       |
| Specific Gravity                                     |        | 0.9888 |           |       |

| Component      | Specific volume<br>reference values * |
|----------------|---------------------------------------|
| Methane        | 23.7 (ft <sup>3</sup> /lb)            |
| Carbon dioxide | 8.62                                  |
| Nitrogen       | 13.5                                  |
| Oxygen         | 11.9                                  |
| Argon          | 9.52                                  |
| Hydrogen       | 188.2                                 |

\* reference, Rev. 2016, GPA-2145 Midstream Standard, Selected Hydrocarbons 60°F





**AtmAA** Inc.

5107 Douglas Fir Rd., Calabasas, CA 91302 • (818) 223-3277

specialized air assessment laboratory  
atmaa.com

## LABORATORY ANALYSIS REPORT

Permanent Gases Analysis in Silco Canister Samples by Method ASTM D1946-90

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Project No.: PROJ-053154

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

### ANALYSIS DESCRIPTION


*Permanent gases were measured by thermal conductivity detection/gas chromatography (TCD/GC), ASTM D1946-90.*

| AtmAA Lab No.: | 20795-34    | 20795-35     | 20795-36     |
|----------------|-------------|--------------|--------------|
| Sample I.D.:   | Tank Farm 2 | Tank Farm 7A | Tank Farm 7B |

| Components     | (Concentration in %,v) |       |       |
|----------------|------------------------|-------|-------|
| Nitrogen       | 74.00                  | 76.26 | 75.93 |
| Oxygen         | 20.66                  | 21.52 | 21.29 |
| Methane        | <0.14                  | <0.14 | <0.14 |
| Carbon dioxide | 2.30                   | <0.14 | 1.92  |

*The reported oxygen concentration includes any argon present in the sample. Calibration is based on a standard atmosphere containing 20.95% oxygen and 0.93% argon.*

*The accuracy of permanent gas analysis by TCD/GC is +/- 2%, actual results are reported. Actual analysis results are reported on a "wet" basis.*



*Brian W. Fung*  
Laboratory Director



AtmAA Inc.

5107 Douglas Fir Rd., Calabasas, CA 91302 • (818) 223-3277

specialized air assessment laboratory  
atmaa.com

## LABORATORY ANALYSIS REPORT

### Speciated Hydrocarbons Analysis in Silco Canister Samples

Report Date: April 14, 2025  
Client: Montrose AQS  
Project Location: Chiquita Landfill  
Project No.: PROJ-053154  
Date Received: March 20, 2025  
Date Analyzed: March 21, 2025  
Laboratory Temp: 73.5 °F  
Barometric Pressure: 29.95 inHg

### ANALYSIS DESCRIPTION

Hydrocarbon speciation analysis was performed by flame ionization detection/gas chromatography (FID/GC), modified EPA-18. Methane was measured by thermal conductivity detection/gas chromatography (TCD/GC), ASTM D1946-90.

| AtmAA Lab No.:<br>Sample ID: | 20795-34<br>Tank Farm 2 | 20795-35<br>Tank Farm 7A | 20795-36<br>Tank Farm 7B |
|------------------------------|-------------------------|--------------------------|--------------------------|
|------------------------------|-------------------------|--------------------------|--------------------------|

| Component | (Concentration in ppmv, component) |       |       |
|-----------|------------------------------------|-------|-------|
| Methane   | 1015                               | 77.7  | 695   |
| Ethene    | <0.30                              | <0.30 | 2.90  |
| Acetylene | <0.30                              | <0.30 | <0.20 |
| Ethane    | <0.30                              | <0.30 | 2.18  |

Non-methane hydrocarbons  
analysis by carbon  
number grouping

|     |       |       |      |
|-----|-------|-------|------|
| C3  | 17.1  | <0.10 | 6.16 |
| C4  | 167   | 66.2  | 91.7 |
| C5  | 277   | 99.3  | 203  |
| C6  | 301   | 60.9  | 132  |
| C7  | 129   | 9.66  | 242  |
| C8  | 89.1  | 6.49  | 18.8 |
| C9  | 116   | 8.12  | 15.0 |
| C10 | 149   | 34.4  | 38.7 |
| C11 | 24.1  | 9.50  | 15.5 |
| C12 | 14.3  | 8.33  | 5.88 |
| C13 | 5.38  | 5.18  | 9.01 |
| C14 | <0.06 | 1.29  | 0.87 |

|       |                          |      |      |
|-------|--------------------------|------|------|
|       | (Concentration in ppmvC) |      |      |
| TNMHC | 8567                     | 1953 | 4934 |

TNMHC - total non-methane hydrocarbons as ppmvC.  
Actual analysis results are reported on a "wet" basis.

  
\_\_\_\_\_  
Brian W. Fung  
Laboratory Director



**AtmAA** Inc.

5107 Douglas Fir Rd., Calabasas, CA 91302 • (818) 223-3277

specialized air assessment laboratory  
atmaa.com

## LABORATORY ANALYSIS REPORT

### Hydrogen Sulfide and Reduced Sulfur Compounds Analysis in Silco Canister Sample by SCAQMD Method 307.91

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Project No.: PROJ-053154

Date Received: March 20, 2025

Date Analyzed: March 20, 2025

## ANALYSIS DESCRIPTION

*Total sulfur analysis measured by gas chromatography with sulfur chemiluminescence detector (SCD), SCAQMD 307.91.*

| AtmAA Lab No.:<br>Sample I.D.:                    | 20795-34<br>Tank Farm 2        | 20795-35<br>Tank Farm 7A | 20795-36<br>Tank Farm 7B |
|---|--------------------------------|--------------------------|--------------------------|
| <u>Components</u>                                 | <i>(Concentration in ppmv)</i> |                          |                          |
| Hydrogen sulfide                                  | <0.10                          | <0.10                    | 0.69                     |
| Carbonyl sulfide                                  | 0.12                           | <0.10                    | <0.10                    |
| Methyl mercaptan                                  | 1.46                           | <0.10                    | 4.45                     |
| Ethyl mercaptan                                   | <0.10                          | <0.10                    | <0.10                    |
| Dimethyl sulfide                                  | 62.3                           | 1.60                     | 28.9                     |
| Carbon disulfide                                  | <0.10                          | <0.10                    | <0.10                    |
| i-Propyl mercaptan                                | <0.10                          | <0.10                    | <0.10                    |
| t-Butyl mercaptan                                 | <0.10                          | <0.10                    | <0.10                    |
| n-Propyl mercaptan                                | 0.85                           | <0.10                    | 0.34                     |
| s-Butyl mercaptan                                 | 0.94                           | <0.10                    | 0.29                     |
| i-Butyl mercaptan                                 | <0.10                          | <0.10                    | <0.10                    |
| Dimethyl disulfide                                | 1.33                           | <0.10                    | 0.34                     |
| Tetrahydrothiophene                               | 0.93                           | <0.10                    | 0.16                     |
| Unidentified sulfurs                              | 5.14                           | 0.14                     | 1.16                     |
| <i>(Concentration in ppmv, as H<sub>2</sub>S)</i> |                                |                          |                          |
| Total Sulfur                                      | 74.38                          | 1.73                     | 36.64                    |

  
\_\_\_\_\_  
Brian W. Fung  
Laboratory Director

**QUALITY ASSURANCE SUMMARY**  
*(Repeat Analyses)*

Project Location: Chiquita Landfill

Date Received: March 20, 2025

Date Analyzed: March 20, 2025

| Components         | Sample ID    | Repeat Analysis |        | Mean Conc. | % RPD |
|--------------------|--------------|-----------------|--------|------------|-------|
|                    |              | Run #1          | Run #2 |            |       |
| Hydrogen sulfide   | Tank Farm 2  | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7A | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7B | 0.69            | 0.68   | 0.69       | 1.5   |
| Carbonyl sulfide   | Tank Farm 2  | 0.11            | 0.12   | 0.12       | 8.7   |
|                    | Tank Farm 7A | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7B | <0.10           | <0.10  | ---        | ---   |
| Methyl mercaptan   | Tank Farm 2  | 1.43            | 1.49   | 1.46       | 4.1   |
|                    | Tank Farm 7A | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7B | 4.49            | 4.41   | 4.45       | 1.8   |
| Ethyl mercaptan    | Tank Farm 2  | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7A | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7B | <0.10           | <0.10  | ---        | ---   |
| Dimethyl sulfide   | Tank Farm 2  | 61.8            | 62.8   | 62.3       | 1.61  |
|                    | Tank Farm 7A | 1.60            | 1.59   | 1.60       | 0.63  |
|                    | Tank Farm 7B | 28.9            | 28.9   | 28.9       | 0.17  |
| Carbon disulfide   | Tank Farm 2  | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7A | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7B | <0.10           | <0.10  | ---        | ---   |
| i-Propyl mercaptan | Tank Farm 2  | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7A | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7B | <0.10           | <0.10  | ---        | ---   |
| t-Butyl mercaptan  | Tank Farm 2  | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7A | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7B | <0.10           | <0.10  | ---        | ---   |
| n-Propyl mercaptan | Tank Farm 2  | 0.85            | 0.85   | 0.85       | 0.00  |
|                    | Tank Farm 7A | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7B | 0.34            | 0.34   | 0.34       | 0.00  |
| s-Butyl mercaptan  | Tank Farm 2  | 0.94            | 0.94   | 0.94       | 0.00  |
|                    | Tank Farm 7A | <0.10           | <0.10  | ---        | ---   |
|                    | Tank Farm 7B | 0.29            | 0.29   | 0.29       | 0.00  |

**QUALITY ASSURANCE SUMMARY**  
*(Repeat Analyses)*  
*(continued)*

| Components           | Sample ID    | Repeat Analysis |        | Mean Conc. | % RPD |
|----------------------|--------------|-----------------|--------|------------|-------|
|                      |              | Run #1          | Run #2 |            |       |
| i-Butyl mercaptan    | Tank Farm 2  | <0.10           | <0.10  | ---        | ---   |
|                      | Tank Farm 7A | <0.10           | <0.10  | ---        | ---   |
|                      | Tank Farm 7B | <0.10           | <0.10  | ---        | ---   |
| Dimethyl disulfide   | Tank Farm 2  | 1.32            | 1.33   | 1.33       | 0.75  |
|                      | Tank Farm 7A | <0.10           | <0.10  | ---        | ---   |
|                      | Tank Farm 7B | 0.34            | 0.34   | 0.34       | 0.00  |
| Tetrahydrothiophene  | Tank Farm 2  | 0.92            | 0.94   | 0.93       | 2.2   |
|                      | Tank Farm 7A | <0.10           | <0.10  | ---        | ---   |
|                      | Tank Farm 7B | 0.17            | 0.15   | 0.16       | 13    |
| Unidentified sulfurs | Tank Farm 2  | 5.10            | 5.17   | 5.14       | 1.4   |
|                      | Tank Farm 7A | 0.14            | 0.13   | 0.14       | 7.4   |
|                      | Tank Farm 7B | 1.16            | 1.16   | 1.16       | 0.00  |

*Three Silco canister samples, laboratory numbers 20795-(34-36), were analyzed for total sulfur compounds. Agreement between repeat analyses is a measure of precision and is shown above in the column "% RPD". The average % RPD for 18 repeat measurements from three Silco canister samples is 2.4%.*



## Calculated values for Specific Volume, BTU, and F (factor)

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

AtmAA Lab #: 20795-34

Sample ID: Tank Farm 2

Specific volume, BTU, and F-factor are calculated using normalized laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TNMHC, and sulfur compounds in equations that include gross/net heating and specific gas volume values taken from the GPA-2145 Midstream Standard. Heating value factor is calculated according to ASTM 3588-98 (14.696 psia and 60°F).

| Component  | Mole %        | Wt %         | C,H,O,N,S, Wt.% |             |
|--|---------------|--------------|-----------------|-------------|
| Methane  | 0.00          | 0.00         | Carbon          | 1.33        |
| Carbon dioxide                                       | 2.37          | 3.55         | Hydrogen        | 0.07        |
| Nitrogen   | 76.22         | 72.62        | Oxygen          | 24.75       |
| Oxygen   | 20.38         | 22.18        | Nitrogen        | 72.62       |
| Argon  | 0.90          | 1.23         | Argon           | 1.23        |
| Hydrogen<br>(CH <sub>2</sub> ) <sub>n</sub>          | 0.00<br>0.133 | 0.00<br>0.43 | Sulfur          | 0.00        |
| Specific Volume                                      |               | 12.900       |                 |             |
| BTU/ft <sup>3</sup> (Dry @60F, 14.696 psia)          |               | 6.949        | (HHV)           | 6.439 (LHV) |
| BTU/ft <sup>3</sup> (Water Saturated @ 0.25636 psia) |               | 6.828        | (HHV)           | 6.326 (LHV) |
| BTU/lb (Dry @60F, 14.696 psia)                       |               | 89.64        | (HHV)           | 83.06 (LHV) |
| Compressibility Factor (@60F, 14.696 psia)           |               | 0.9996       |                 |             |
| Wobbe Index  |               | 6.941        |                 |             |
| Specific Gravity                                     |               | 1.0023       |                 |             |

| Component      | Specific volume<br>reference values * |
|----------------|---------------------------------------|
| Methane        | 23.7 (ft <sup>3</sup> /lb)            |
| Carbon dioxide | 8.62                                  |
| Nitrogen       | 13.5                                  |
| Oxygen         | 11.9                                  |
| Argon          | 9.52                                  |
| Hydrogen       | 188.2                                 |

\* reference, Rev. 2016, GPA-2145 Midstream Standard, Selected Hydrocarbons 60°F



## Calculated values for Specific Volume, BTU, and F (factor)

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

AtmAA Lab #: 20795-35

Sample ID: Tank Farm 7A

Specific volume, BTU, and F-factor are calculated using normalized laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TNMHC, and sulfur compounds in equations that include gross/net heating and specific gas volume values taken from the GPA-2145 Midstream Standard. Heating value factor is a calculated according to ASTM 3588-98 (14.696 psia and 60°F).

| Component  | Mole % | Wt %   | C,H,O,N,S | Wt. %       |
|--|--------|--------|-----------|-------------|
| Methane  | 0.00   | 0.00   | Carbon    | 0.08        |
| Carbon dioxide                                       | 0.00   | 0.00   | Hydrogen  | 0.02        |
| Nitrogen   | 77.97  | 75.34  | Oxygen    | 23.27       |
| Oxygen   | 21.07  | 23.27  | Nitrogen  | 75.34       |
| Argon  | 0.93   | 1.29   | Argon     | 1.29        |
| Hydrogen   | 0.00   | 0.00   | Sulfur    | 0.00        |
| (CH <sub>2</sub> ) <sub>n</sub>                      | 0.032  | 0.10   |           |             |
| Specific Volume                                      |        | 13.086 |           |             |
| BTU/ft <sup>3</sup> (Dry @60F, 14.696 psia)          |        | 1.576  | (HHV)     | 1.460 (LHV) |
| BTU/ft <sup>3</sup> (Water Saturated @ 0.25636 psia) |        | 1.549  | (HHV)     | 1.435 (LHV) |
| BTU/lb (Dry @60F, 14.696 psia)                       |        | 20.63  | (HHV)     | 19.11 (LHV) |
| Compressibility Factor (@60F, 14.696 psia)           |        | 0.9996 |           |             |
| Wobbe Index  |        | 1.586  |           |             |
| Specific Gravity                                     |        | 0.9884 |           |             |

| Component      | Specific volume<br>reference values * |
|----------------|---------------------------------------|
| Methane        | 23.7 (ft <sup>3</sup> /lb)            |
| Carbon dioxide | 8.62                                  |
| Nitrogen       | 13.5                                  |
| Oxygen         | 11.9                                  |
| Argon          | 9.52                                  |
| Hydrogen       | 188.2                                 |

\* reference, Rev. 2016, GPA-2145 Midstream Standard, Selected Hydrocarbons 60°F



## Calculated values for Specific Volume, BTU, and F (factor)

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

AtmAA Lab #: 20795-36

Sample ID: Tank Farm 7B

Specific volume, BTU, and F-factor are calculated using normalized laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TNMHC, and sulfur compounds in equations that include gross/net heating and specific gas volume values taken from the GPA-2145 Midstream Standard. Heating value factor is calculated according to ASTM 3588-98 (14.696 psia and 60°F).

| Component  | Mole % | Wt %   | C,H,O,N,S, Wt.% |             |
|--|--------|--------|-----------------|-------------|
| Methane  | 0.00   | 0.00   | Carbon          | 1.00        |
| Carbon dioxide                                       | 1.94   | 2.91   | Hydrogen        | 0.04        |
| Nitrogen   | 76.53  | 73.16  | Oxygen          | 24.56       |
| Oxygen   | 20.55  | 22.45  | Nitrogen        | 73.16       |
| Argon  | 0.91   | 1.24   | Argon           | 1.24        |
| Hydrogen   | 0.00   | 0.00   | Sulfur          | 0.00        |
| (CH <sub>2</sub> ) <sub>n</sub>                      | 0.079  | 0.24   |                 |             |
| Specific Volume                                      |        | 12.945 |                 |             |
| BTU/ft <sup>3</sup> (Dry @60F, 14.696 psia)          |        | 3.928  | (HHV)           | 3.638 (LHV) |
| BTU/ft <sup>3</sup> (Water Saturated @ 0.25636 psia) |        | 3.859  | (HHV)           | 3.575 (LHV) |
| BTU/lb (Dry @60F, 14.696 psia)                       |        | 50.84  | (HHV)           | 47.10 (LHV) |
| Compressibility Factor (@60F, 14.696 psia)           |        | 0.9996 |                 |             |
| Wobbe Index  |        | 3.929  |                 |             |
| Specific Gravity                                     |        | 0.9993 |                 |             |

| Component      | Specific volume<br>reference values * |
|----------------|---------------------------------------|
| Methane        | 23.7 (ft <sup>3</sup> /lb)            |
| Carbon dioxide | 8.62                                  |
| Nitrogen       | 13.5                                  |
| Oxygen         | 11.9                                  |
| Argon          | 9.52                                  |
| Hydrogen       | 188.2                                 |

\* reference, Rev. 2016, GPA-2145 Midstream Standard, Selected Hydrocarbons 60°F





**AtmAA** Inc.

5107 Douglas Fir Rd., Calabasas, CA 91302 • (818) 223-3277

specialized air assessment laboratory  
atmaa.com

### LABORATORY ANALYSIS REPORT

#### Permanent Gases Analysis in Silco Canister Samples by Method ASTM D1946-90

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Project No.: PROJ-053154

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

#### ANALYSIS DESCRIPTION

*Permanent gases were measured by thermal conductivity detection/gas chromatography (TCD/GC), ASTM D1946-90.*

| AtmAA Lab No.: | 20795-37    | 20795-38              | 20795-39               |
|----------------|-------------|-----------------------|------------------------|
| Sample I.D.:   | Zeeco Inlet | Flare Station Pre H2S | Flare Station Post H2S |

#### Components *(Concentration in %,v)*

|                |       |       |       |
|----------------|-------|-------|-------|
| Nitrogen       | 29.74 | 17.50 | 18.76 |
| Oxygen         | 6.75  | 4.04  | 3.64  |
| Methane        | 22.39 | 28.78 | 25.95 |
| Carbon dioxide | 36.30 | 42.98 | 43.53 |
| Hydrogen       | 1.82  | 2.84  | 3.38  |

*The reported oxygen concentration includes any argon present in the sample. Calibration is based on a standard atmosphere containing 20.95% oxygen and 0.93% argon.*

*The accuracy of permanent gas analysis by TCD/GC is +/- 2%, actual results are reported. Actual analysis results are reported on a "wet" basis.*

Brian W. Fung  
Laboratory Director

**QUALITY ASSURANCE SUMMARY**  
*(Repeat Analyses)*

Project Location: Chiquita Landfill  
 Date Received: March 20, 2025  
 Date Analyzed: March 21, 2025

| Components                     | Sample ID   | Repeat Analysis |        | Mean Conc. | % RPD |
|--------------------------------|-------------|-----------------|--------|------------|-------|
|                                |             | Run #1          | Run #2 |            |       |
| <i>(Concentration in %, v)</i> |             |                 |        |            |       |
| Nitrogen                       | Zeeco Inlet | 29.78           | 29.69  | 29.74      | 0.30  |
| Oxygen                         | Zeeco Inlet | 6.75            | 6.74   | 6.75       | 0.15  |
| Methane                        | Zeeco Inlet | 22.47           | 22.30  | 22.39      | 0.76  |
| Carbon dioxide                 | Zeeco Inlet | 36.30           | 36.30  | 36.30      | 0.00  |
| Hydrogen                       | Zeeco Inlet | 1.78            | 1.85   | 1.82       | 3.9   |

*Three Silco canister samples, laboratory numbers 20795-(37-39), were analyzed for permanent gases. Agreement between repeat analyses is a measure of precision and is shown above in the column "% RPD". The average % RPD for 5 repeat measurements from three Silco canister samples is 1.0%.*





**AtmAA** Inc.

5107 Douglas Fir Rd., Calabasas, CA 91302 • (818) 223-3277

specialized air assessment laboratory  
atmaa.com

**LABORATORY ANALYSIS REPORT**

**Speciated Hydrocarbons Analysis in Silco Canister Samples**

Report Date: April 14, 2025  
Client: Montrose AQS  
Project Location: Chiquita Landfill  
Project No.: PROJ-053154  
Date Received: March 20, 2025  
Date Analyzed: March 21, 2025  
Laboratory Temp: 73.5 °F  
Barometric Pressure: 29.95 inHg

**ANALYSIS DESCRIPTION**

Hydrocarbon speciation analysis was performed by flame ionization detection/gas chromatography (FID/GC), modified EPA-18. Methane was measured by thermal conductivity detection/gas chromatography (TCD/GC), ASTM D1946-90.

| AtmAA Lab No.: | 20795-37    | 20795-38              | 20795-39               |
|----------------|-------------|-----------------------|------------------------|
| Sample ID:     | Zeeco Inlet | Flare Station Pre H2S | Flare Station Post H2S |

| Component | (Concentration in ppmv, component) |        |        |
|-----------|------------------------------------|--------|--------|
| Methane   | 223900                             | 287800 | 259500 |
| Ethene    | <0.30                              | <0.30  | <0.20  |
| Acetylene | <0.30                              | <0.30  | <0.20  |
| Ethane    | 48.4                               | 55.9   | 59.9   |

**Non-methane hydrocarbons  
analysis by carbon  
number grouping**

|     |      |      |      |
|-----|------|------|------|
| C3  | 211  | 223  | 221  |
| C4  | 1040 | 1422 | 1872 |
| C5  | 1240 | 1324 | 1703 |
| C6  | 939  | 952  | 2251 |
| C7  | 294  | 1110 | 708  |
| C8  | 211  | 341  | 510  |
| C9  | 221  | 321  | 464  |
| C10 | 227  | 311  | 168  |
| C11 | 47.5 | 49.1 | 18.6 |
| C12 | 17.0 | 28.9 | 12.6 |
| C13 | 10.4 | 11.2 | 5.94 |
| C14 | 1.98 | 0.68 | 2.02 |

|       | (Concentration in ppmvC) |       |       |
|-------|--------------------------|-------|-------|
| TNMHC | 25622                    | 36332 | 45638 |

*TNMHC - total non-methane hydrocarbons as ppmvC.  
Actual analysis results are reported on a "wet" basis.*

Brian W. Fung  
Laboratory Director

**QUALITY ASSURANCE SUMMARY**  
*(Repeat Analyses)*

Project Location: Chiquita Landfill  
 Date Received: March 20, 2025  
 Date Analyzed: March 21, 2025

| Component  | Sample ID   | Repeat Analysis |        | Mean Conc. | % RPD |
|--|-------------|-----------------|--------|------------|-------|
|  |             | Run #1          | Run #2 |            |       |
| Methane  | Zeeco Inlet | 224700          | 223000 | 223850     | 0.76  |
| Ethene   | Zeeco Inlet | <0.30           | <0.30  | <0.30      | ---   |
| Acetylene  | Zeeco Inlet | <0.30           | <0.30  | <0.30      | ---   |
| Ethane   | Zeeco Inlet | 48.2            | 48.7   | 48.4       | 1.0   |
| <u>non-methane hydrocarbons analysis by carbon number grouping</u> |             |                 |        |            |       |
| C3   | Zeeco Inlet | 215             | 207    | 211        | 3.5   |
| C4   | Zeeco Inlet | 1106            | 974    | 1040       | 13    |
| C5   | Zeeco Inlet | 1312            | 1168   | 1240       | 12    |
| C6   | Zeeco Inlet | 977             | 901    | 939        | 8.2   |
| C7   | Zeeco Inlet | 295             | 293    | 294        | 0.85  |
| C8   | Zeeco Inlet | 213             | 210    | 211        | 1.1   |
| C9   | Zeeco Inlet | 223             | 220    | 221        | 1.2   |
| C10  | Zeeco Inlet | 233             | 221    | 227        | 5.5   |
| C11  | Zeeco Inlet | 48.1            | 47.0   | 47.5       | 2.3   |
| C12  | Zeeco Inlet | 16.6            | 17.3   | 17.0       | 4.3   |
| C13  | Zeeco Inlet | 10.4            | 10.3   | 10.4       | 0.77  |
| C14  | Zeeco Inlet | 1.96            | 2.00   | 1.98       | 2.1   |
| (Concentration in ppmvC)   |             |                 |        |            |       |
| TNMHC  | Zeeco Inlet | 26582           | 24663  | 25622      | 7.5   |

Three Silco canister samples, laboratory numbers 20795-(37-39), were analyzed for hydrocarbon speciation, EPA Method 18. Agreement between repeat analyses is a measure of precision and is shown above in the column "% RPD". The average % RPD for 15 repeat measurements from three Silco canister samples is 4.2%.





**AtmAA** Inc.

5107 Douglas Fir Rd., Calabasas, CA 91302 • (818) 223-3277

specialized air assessment laboratory  
atmaa.com

## LABORATORY ANALYSIS REPORT

### Hydrogen Sulfide and Reduced Sulfur Compounds Analysis in Silco Canister Sample by SCAQMD Method 307.91

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Project No.: PROJ-053154


Date Received: March 20, 2025

Date Analyzed: March 20, 2025

## ANALYSIS DESCRIPTION

*Total sulfur analysis measured by gas chromatography with sulfur chemiluminescence detector (SCD), SCAQMD 307.91.*

| Components                                   | AtmAA Lab No.:<br>Sample I.D.: | 20795-37<br>Zeeco Inlet | 20795-38<br>Flare Station Pre H2S | 20795-39<br>Flare Station Post H2S |
|--|--------------------------------|-------------------------|-----------------------------------|------------------------------------|
|  | (Concentration in ppmv)        |                         |                                   |                                    |
| Hydrogen sulfide                             | 209                            | 301                     | <0.40                             |                                    |
| Carbonyl sulfide                             | 0.71                           | 1.07                    | 0.98                              |                                    |
| Methyl mercaptan                             | 104                            | 170                     | <0.40                             |                                    |
| Ethyl mercaptan                              | 1.64                           | 2.43                    | <0.40                             |                                    |
| Dimethyl sulfide                             | 284                            | 502                     | 495                               |                                    |
| Carbon disulfide                             | <0.40                          | <0.40                   | 0.45                              |                                    |
| i-Propyl mercaptan                           | 1.72                           | 3.28                    | <0.40                             |                                    |
| t-Butyl mercaptan                            | <0.40                          | <0.40                   | <0.40                             |                                    |
| n-Propyl mercaptan                           | 4.31                           | 7.01                    | 7.57                              |                                    |
| s-Butyl mercaptan                            | 4.98                           | 9.24                    | 9.27                              |                                    |
| i-Butyl mercaptan                            | <0.40                          | <0.40                   | <0.40                             |                                    |
| Dimethyl disulfide                           | 0.99                           | 2.22                    | 57.0                              |                                    |
| Tetrahydrothiophene                          | 2.07                           | 3.87                    | 4.51                              |                                    |
| Unidentified sulfurs                         | 10.3                           | 16.4                    | 87.3                              |                                    |
| (Concentration in ppmv, as H <sub>2</sub> S) |                                |                         |                                   |                                    |
| Total Sulfur                                 | 624.2                          | 1019.7                  | 719.4                             |                                    |

  
\_\_\_\_\_  
Brian W. Fung  
Laboratory Director

**QUALITY ASSURANCE SUMMARY**  
*(Repeat Analyses)*

Project Location: Chiquita Landfill

Date Received: March 20, 2025

Date Analyzed: March 20, 2025

| Components                     | Sample ID              | Repeat Analysis |        | Mean Conc. | % RPD |
|--------------------------------|------------------------|-----------------|--------|------------|-------|
|                                |                        | Run #1          | Run #2 |            |       |
| <i>(Concentration in ppmv)</i> |                        |                 |        |            |       |
| Hydrogen sulfide               | Zeeco Inlet            | 213             | 205    | 209        | 3.8   |
|                                | Flare Station Pre H2S  | 299             | 302    | 301        | 1.0   |
|                                | Flare Station Post H2S | <0.40           | <0.40  | ---        | ---   |
| Carbonyl sulfide               | Zeeco Inlet            | 0.70            | 0.71   | 0.71       | 1.4   |
|                                | Flare Station Pre H2S  | 1.07            | 1.07   | 1.07       | 0.00  |
|                                | Flare Station Post H2S | 1.00            | 0.95   | 0.98       | 5.1   |
| Methyl mercaptan               | Zeeco Inlet            | 106             | 102    | 104        | 3.8   |
|                                | Flare Station Pre H2S  | 169             | 171    | 170        | 1.2   |
|                                | Flare Station Post H2S | <0.40           | <0.40  | ---        | ---   |
| Ethyl mercaptan                | Zeeco Inlet            | 1.67            | 1.61   | 1.64       | 3.7   |
|                                | Flare Station Pre H2S  | 2.39            | 2.47   | 2.43       | 3.29  |
|                                | Flare Station Post H2S | <0.40           | <0.40  | ---        | ---   |
| Dimethyl sulfide               | Zeeco Inlet            | 289             | 278    | 284        | 3.9   |
|                                | Flare Station Pre H2S  | 500             | 503    | 502        | 0.60  |
|                                | Flare Station Post H2S | 511             | 479    | 495        | 6.5   |
| Carbon disulfide               | Zeeco Inlet            | <0.40           | <0.40  | ---        | ---   |
|                                | Flare Station Pre H2S  | <0.40           | <0.40  | ---        | ---   |
|                                | Flare Station Post H2S | 0.45            | 0.44   | 0.45       | 2.2   |
| i-Propyl mercaptan             | Zeeco Inlet            | 1.73            | 1.70   | 1.72       | 1.7   |
|                                | Flare Station Pre H2S  | 3.28            | 3.27   | 3.28       | 0.31  |
|                                | Flare Station Post H2S | <0.40           | <0.40  | ---        | ---   |
| t-Butyl mercaptan              | Zeeco Inlet            | <0.40           | <0.40  | ---        | ---   |
|                                | Flare Station Pre H2S  | <0.40           | <0.40  | ---        | ---   |
|                                | Flare Station Post H2S | <0.40           | <0.40  | ---        | ---   |
| n-Propyl mercaptan             | Zeeco Inlet            | 4.40            | 4.21   | 4.31       | 4.4   |
|                                | Flare Station Pre H2S  | 6.96            | 7.06   | 7.01       | 1.4   |
|                                | Flare Station Post H2S | 7.80            | 7.34   | 7.57       | 6.1   |
| s-Butyl mercaptan              | Zeeco Inlet            | 5.04            | 4.92   | 4.98       | 2.4   |
|                                | Flare Station Pre H2S  | 9.23            | 9.25   | 9.24       | 0.22  |
|                                | Flare Station Post H2S | 9.54            | 8.99   | 9.27       | 5.9   |



**QUALITY ASSURANCE SUMMARY**  
*(Repeat Analyses)*  
*(continued)*

| Components                     | Sample ID              | Repeat Analysis |        | Mean Conc. | % RPD |
|--------------------------------|------------------------|-----------------|--------|------------|-------|
|                                |                        | Run #1          | Run #2 |            |       |
| <i>(Concentration in ppmv)</i> |                        |                 |        |            |       |
| i-Butyl mercaptan              | Zeeco Inlet            | <0.40           | <0.40  | ---        | ---   |
|                                | Flare Station Pre H2S  | <0.40           | <0.40  | ---        | ---   |
|                                | Flare Station Post H2S | <0.40           | <0.40  | ---        | ---   |
| Dimethyl disulfide             | Zeeco Inlet            | 1.02            | 0.96   | 0.99       | 6.1   |
|                                | Flare Station Pre H2S  | 2.20            | 2.24   | 2.22       | 1.8   |
|                                | Flare Station Post H2S | 58.7            | 55.2   | 57.0       | 6.1   |
| Tetrahydrothiophene            | Zeeco Inlet            | 2.07            | 2.06   | 2.07       | 0.48  |
|                                | Flare Station Pre H2S  | 3.86            | 3.88   | 3.87       | 0.52  |
|                                | Flare Station Post H2S | 4.56            | 4.46   | 4.51       | 2.2   |
| Unidentified sulfurs           | Zeeco Inlet            | 10.1            | 10.5   | 10.3       | 3.8   |
|                                | Flare Station Pre H2S  | 15.9            | 16.9   | 16.4       | 6.4   |
|                                | Flare Station Post H2S | 89.9            | 84.7   | 87.3       | 6.0   |

*Three Silco canister samples, laboratory numbers 20795-(37-39), were analyzed for total sulfur compounds. Agreement between repeat analyses is a measure of precision and is shown above in the column "% RPD". The average % RPD for 30 repeat measurements from three Silco canister samples is 3.1%.*



## Calculated values for Specific Volume, BTU, and F (factor)

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

AtmAA Lab #: 20795-37


Sample ID: Zeeco Inlet

Specific volume, BTU, and F-factor are calculated using normalized laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TNMHC, and sulfur compounds in equations that include gross/net heating and specific gas volume values taken from the GPA-2145 Midstream Standard. Heating value factor is calculated according to ASTM 3588-98 (14.696 psia and 60°F). The F-factor is calculated according to the equation in EPA Method 19.

| Component  | Mole %        | Wt %         | C,H,O,N,S, Wt.% |             |
|--|---------------|--------------|-----------------|-------------|
| Methane  | 22.97         | 11.78        | Carbon          | 24.11       |
| Carbon dioxide                                       | 37.25         | 52.40        | Hydrogen        | 3.28        |
| Nitrogen   | 30.51         | 27.32        | Oxygen          | 44.88       |
| Oxygen   | 6.63          | 6.78         | Nitrogen        | 27.32       |
| Argon  | 0.29          | 0.38         | Argon           | 0.38        |
| Hydrogen<br>(CH <sub>2</sub> ) <sub>n</sub>          | 1.86<br>0.463 | 0.12<br>1.21 | Sulfur          | 0.02        |
| Specific Volume                                      |               | 12.126       |                 |             |
| BTU/ft <sup>3</sup> (Dry @60F, 14.696 psia)          |               | 259.1        | (HHV)           | 233.5 (LHV) |
| BTU/ft <sup>3</sup> (Water Saturated @ 0.25636 psia) |               | 254.5        | (HHV)           | 229.4 (LHV) |
| BTU/lb (Dry @60F, 14.696 psia)                       |               | 3141         | (HHV)           | 2831 (LHV)  |
| F <sub>d</sub> (factor)                              |               | 10194        |                 |             |
| F <sub>w</sub> (factor)                              |               | 12210        |                 |             |
| F <sub>c</sub> (factor)                              |               | 2464         |                 |             |
| Compressibility Factor (@60F, 14.696 psia)           |               | 0.9978       |                 |             |
| Wobbe Index  |               | 249.60       |                 |             |
| Specific Gravity                                     |               | 1.0772       |                 |             |

| Component      | Specific volume<br>reference values * |                       |
|----------------|---------------------------------------|-----------------------|
| Methane        | 23.7                                  | (ft <sup>3</sup> /lb) |
| Carbon dioxide | 8.62                                  |                       |
| Nitrogen       | 13.5                                  |                       |
| Oxygen         | 11.9                                  |                       |
| Argon          | 9.52                                  |                       |
| Hydrogen       | 188.2                                 |                       |

\* reference, Rev. 2016, GPA-2145 Midstream Standard, Selected Hydrocarbons 60°F



## Calculated values for Specific Volume, BTU, and F (factor)

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

AtmAA Lab #: 20795-38

Sample ID: Flare Station Pre H2S

Specific volume, BTU, and F-factor are calculated using normalized laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TNMHC, and sulfur compounds in equations that include gross/net heating and specific gas volume values taken from the GPA-2145 Midstream Standard. Heating value factor is a calculated according to ASTM 3588-98 (14.696 psia and 60°F). The F-factor is calculated according to the equation in EPA Method 19.

| Component  | Mole %        | Wt %         | C,H,O,N,S, Wt.% |             |
|--|---------------|--------------|-----------------|-------------|
| Methane  | 29.74         | 15.19        | Carbon          | 29.85       |
| Carbon dioxide                                       | 44.41         | 62.39        | Hydrogen        | 4.27        |
| Nitrogen   | 18.08         | 16.17        | Oxygen          | 49.46       |
| Oxygen   | 4.00          | 4.08         | Nitrogen        | 16.17       |
| Argon  | 0.18          | 0.23         | Argon           | 0.23        |
| Hydrogen<br>(CH <sub>2</sub> ) <sub>n</sub>          | 2.93<br>0.635 | 0.19<br>1.72 | Sulfur          | 0.03        |
| Specific Volume                                      |               | 12.100       |                 |             |
| BTU/ft <sup>3</sup> (Dry @60F, 14.696 psia)          |               | 339.8        | (HHV)           | 306.2 (LHV) |
| BTU/ft <sup>3</sup> (Water Saturated @ 0.25636 psia) |               | 333.9        | (HHV)           | 300.8 (LHV) |
| BTU/lb (Dry @60F, 14.696 psia)                       |               | 4112         | (HHV)           | 3705 (LHV)  |
| F <sub>d</sub> (factor)                              |               | 9907         |                 |             |
| F <sub>w</sub> (factor)                              |               | 11910        |                 |             |
| F <sub>c</sub> (factor)                              |               | 2330         |                 |             |
| Compressibility Factor (@60F, 14.696 psia)           |               | 0.9972       |                 |             |
| Wobbe Index  |               | 327.0        |                 |             |
| Specific Gravity                                     |               | 1.0797       |                 |             |

| Component      | Specific volume<br>reference values * |
|----------------|---------------------------------------|
| Methane        | 23.7 (ft <sup>3</sup> /lb)            |
| Carbon dioxide | 8.62                                  |
| Nitrogen       | 13.5                                  |
| Oxygen         | 11.9                                  |
| Argon          | 9.52                                  |
| Hydrogen       | 188.2                                 |

\* reference, Rev. 2016, GPA-2145 Midstream Standard, Selected Hydrocarbons 60°F



## Calculated values for Specific Volume, BTU, and F (factor)

Report Date: April 14, 2025

Client: Montrose AQS

Project Location: Chiquita Landfill

Date Received: March 20, 2025

Date Analyzed: March 21, 2025

AtmAA Lab #: 20795-39


Sample ID: Flare Station Post H2S


Specific volume, BTU, and F-factor are calculated using normalized laboratory analysis results for methane, carbon dioxide, nitrogen, oxygen, TNMHC, and sulfur compounds in equations that include gross/net heating and specific gas volume values taken from the GPA-2145 Midstream Standard. Heating value factor is a calculated according to ASTM 3588-98 (14.696 psia and 60°F). The F-factor is calculated according to the equation in EPA Method 19.

| Component  | Mole % | Wt %  | C,H,O,N,S, | Wt.%  |
|--|--------|-------|------------|-------|
| Methane  | 27.01  | 13.63 | Carbon     | 29.17 |
| Carbon dioxide                                       | 45.32  | 62.88 | Hydrogen   | 3.98  |
| Nitrogen   | 19.53  | 17.25 | Oxygen     | 49.40 |
| Oxygen   | 3.63   | 3.66  | Nitrogen   | 17.25 |
| Argon  | 0.16   | 0.20  | Argon      | 0.20  |
| Hydrogen   | 3.52   | 0.22  | Sulfur     | 0.00  |
| $(\text{CH}_2)_n$                                    | 0.832  | 2.15  |            |       |
| Specific Volume                                      |        | 11.95 |            |       |
| BTU/ft <sup>3</sup> (Dry @60F, 14.696 psia)          | 322.0  | (HHV) | 290.2      | (LHV) |
| BTU/ft <sup>3</sup> (Water Saturated @ 0.25636 psia) | 316.4  | (HHV) | 285.2      | (LHV) |
| BTU/lb (Dry @60F, 14.696 psia)                       | 3848   | (HHV) | 3469       | (LHV) |
| $F_d$ (factor)                                       | 10088  |       |            |       |
| $F_w$ (factor)                                       | 12086  |       |            |       |
| $F_c$ (factor)                                       | 2433   |       |            |       |
| Compressibility Factor (@60F, 14.696 psia)           | 0.9972 |       |            |       |
| Wobbe Index  | 307.8  |       |            |       |
| Specific Gravity                                     | 1.0943 |       |            |       |

| Component      | Specific volume<br>reference values * |
|----------------|---------------------------------------|
| Methane        | 23.7 (ft <sup>3</sup> /lb)            |
| Carbon dioxide | 8.62                                  |
| Nitrogen       | 13.5                                  |
| Oxygen         | 11.9                                  |
| Argon          | 9.52                                  |
| Hydrogen       | 188.2                                 |

\* reference, Rev. 2016, GPA-2145 Midstream Standard, Selected Hydrocarbons 60°F





AtmAA Inc.

5107 Douglas Fir Rd., Calabasas, CA 91302 • (818) 223-3277

specialized air assessment laboratory

atmaa.com

LABORATORY ANALYSIS REPORT

SCAQMD Rule 1150.1 Components Analysis in Silco Canister Samples

Report Date: April 14, 2025

Client: Montrose AQS

Project Name: Chiquita Landfill

Project No.: PROJ-053154

Date Received: March 20, 2025

Date Analyzed: March 20-21, 2025

| AtmAA Lab No.:          | 20795-31    | 20795-32     | 20795-33     |
|-------------------------|-------------|--------------|--------------|
| Sample I.D.:            | Tank Farm 6 | Tank Farm 9A | Tank Farm 9B |
| (Concentration in ppbv) |             |              |              |

Components

|                       |      |       |      |
|-----------------------|------|-------|------|
| Hydrogen sulfide      | <100 | 10500 | <100 |
| Benzene               | 765  | 15400 | 358  |
| Benzyl chloride       | <30  | <30   | <30  |
| Chlorobenzene         | <25  | <25   | <25  |
| Dichlorobenzenes*     | <40  | <40   | <40  |
| 1,1-dichloroethane    | <30  | <30   | <30  |
| 1,2-dichloroethane    | <30  | <30   | <30  |
| 1,1-dichloroethylene  | <30  | <30   | <30  |
| Dichloromethane       | <60  | <60   | <60  |
| 1,2-dibromoethane     | <15  | <15   | <15  |
| Perchloroethylene     | <15  | <15   | <15  |
| Carbon tetrachloride  | <35  | <35   | <35  |
| Toluene               | 58.3 | 905   | 59.0 |
| 1,1,1-trichloroethane | <20  | <20   | <20  |
| Trichloroethene       | <20  | <20   | <20  |
| Chloroform            | <20  | <20   | <20  |
| Vinyl chloride        | <20  | <20   | <20  |
| m+p-xylenes           | 36.1 | 309   | 49.5 |
| o-xylene              | <25  | 105   | <25  |


Toxic air contaminants (TAC) compounds were analyzed by GC/MS, EPA TO-15.

Hydrogen sulfide was analyzed by SCD/GC, SCAQMD 307.91.

\* total amount containing meta, para, and ortho isomers



Brian W. Fung  
Laboratory Director



AtmAA Inc.

5107 Douglas Fir Rd., Calabasas, CA 91302 • (818) 223-3277

specialized air assessment laboratory

atmaa.com

LABORATORY ANALYSIS REPORT

SCAQMD Rule 1150.1 Components Analysis in Silco Canister Samples

Report Date: April 14, 2025

Client: Montrose AQS

Project Name: Chiquita Landfill

Project No.: PROJ-053154

Date Received: March 20, 2025

Date Analyzed: March 20-21, 2025

| AtmAA Lab No.:          | 20795-34    | 20795-35     | 20795-36     |
|-------------------------|-------------|--------------|--------------|
| Sample I.D.:            | Tank Farm 2 | Tank Farm 7A | Tank Farm 7B |
| (Concentration in ppbv) |             |              |              |

Components

|                       |       |      |      |
|-----------------------|-------|------|------|
| Hydrogen sulfide      | <100  | <100 | 685  |
| Benzene               | 23650 | 421  | 6500 |
| Benzyl chloride       | <45   | <45  | <45  |
| Chlorobenzene         | 53.3  | <40  | <40  |
| Dichlorobenzenes*     | 214   | <60  | <60  |
| 1,1-dichloroethane    | <45   | <45  | <45  |
| 1,2-dichloroethane    | 51.6  | <45  | <45  |
| 1,1-dichloroethylene  | <45   | <45  | <45  |
| Dichloromethane       | <100  | <100 | <100 |
| 1,2-dibromoethane     | <25   | <25  | <25  |
| Perchloroethylene     | <25   | <25  | <25  |
| Carbon tetrachloride  | <60   | <60  | <60  |
| Toluene               | 3190  | 96.0 | 409  |
| 1,1,1-trichloroethane | <35   | <35  | <35  |
| Trichloroethene       | <35   | <35  | <35  |
| Chloroform            | <35   | <35  | <35  |
| Vinyl chloride        | <35   | <35  | <35  |
| m+p-xylenes           | 1535  | 71.6 | 156  |
| o-xylene              | 569   | <40  | 65.4 |

Toxic air contaminants (TAC) compounds were analyzed by GC/MS, EPA TO-15.

Hydrogen sulfide was analyzed by SCD/GC, SCAQMD 307.91.

\* total amount containing meta, para, and ortho isomers

Brian W. Fung  
Laboratory Director



**AtmAA** Inc.

5107 Douglas Fir Rd., Calabasas, CA 91302 • (818) 223-3277

specialized air assessment laboratory  
atmaa.com

**LABORATORY ANALYSIS REPORT**

**SCAQMD Rule 1150.1 Components Analysis in Silco Canister Samples**

Report Date: April 18, 2025

Client: Montrose AQS

Project Name: Chiquita Landfill

Project No.: PROJ-053154

Date Received: March 20, 2025

Date Analyzed: March 20-21, 2025

| AtmAA Lab No.:          | 20795-37    | 20795-38              | 20795-39               |
|-------------------------|-------------|-----------------------|------------------------|
| Sample I.D.:            | Zeeco Inlet | Flare Station Pre H2S | Flare Station Post H2S |
| (Concentration in ppbv) |             |                       |                        |

Components

|                       |        |        |        |
|-----------------------|--------|--------|--------|
| Hydrogen sulfide      | 209000 | 300500 | <400   |
| Benzene               | 81900  | 127000 | 116000 |
| Benzyl chloride       | <5000  | <5000  | <5000  |
| Chlorobenzene         | <4500  | <4500  | <4500  |
| Dichlorobenzenes*     | <6500  | <6500  | <6500  |
| 1,1-dichloroethane    | <5000  | <5000  | <5000  |
| 1,2-dichloroethane    | <5000  | <5000  | <5000  |
| 1,1-dichloroethylene  | <5000  | <5000  | <5000  |
| Dichloromethane       | <11000 | <11000 | <11000 |
| 1,2-dibromoethane     | <3000  | <3000  | <3000  |
| Perchloroethylene     | <3000  | <3000  | <3000  |
| Carbon tetrachloride  | <6000  | <6000  | <6000  |
| Toluene               | 8910   | 12400  | 11800  |
| 1,1,1-trichloroethane | <4000  | <4000  | <4000  |
| Trichloroethene       | <4000  | <4000  | <4000  |
| Chloroform            | <4000  | <4000  | <4000  |
| Vinyl chloride        | <4000  | <4000  | <4000  |
| m+p-xylenes           | 4580   | 5360   | 5440   |
| o-xylene              | <4500  | <4500  | <4500  |

Toxic air contaminants (TAC) compounds were analyzed by GC/MS, EPA TO-15.

Hydrogen sulfide was analyzed by SCD/GC, SCAQMD 307.91.

\* total amount containing meta, para, and ortho isomers



Brian W. Fung  
Laboratory Director

**QUALITY ASSURANCE SUMMARY**  
*(Repeat Analyses)*

Project Name: Chiquita Landfill  
 Date Received: March 20, 2025  
 Date Analyzed: March 20-21, 2025

| Components              | Sample ID   | Repeat Analysis |        | Mean Conc. | % RPD |
|-------------------------|-------------|-----------------|--------|------------|-------|
|                         |             | Run #1          | Run #2 |            |       |
| (Concentration in ppbv) |             |                 |        |            |       |
| Hydrogen sulfide        | Tank Farm 2 | <100            | <100   | ---        | ---   |
| Benzene                 | Tank Farm 2 | 24500           | 22800  | 23650      | 7.2   |
| Benzyl chloride         | Tank Farm 2 | <45             | <45    | ---        | ---   |
| Chlorobenzene           | Tank Farm 2 | 53.4            | 53.2   | 53.3       | 0.38  |
| Dichlorobenzenes        | Tank Farm 2 | 207             | 221    | 214        | 6.5   |
| 1,1-dichloroethane      | Tank Farm 2 | <45             | <45    | ---        | ---   |
| 1,2-dichloroethane      | Tank Farm 2 | 52.0            | 51.2   | 51.6       | 1.6   |
| 1,1-dichloroethylene    | Tank Farm 2 | <45             | <45    | ---        | ---   |
| Dichloromethane         | Tank Farm 2 | <100            | <100   | ---        | ---   |
| 1,2-dibromoethane       | Tank Farm 2 | <25             | <25    | ---        | ---   |
| Perchloroethylene       | Tank Farm 2 | <25             | <25    | ---        | ---   |
| Carbon tetrachloride    | Tank Farm 2 | <60             | <60    | ---        | ---   |
| Toluene                 | Tank Farm 2 | 3280            | 3100   | 3190       | 5.6   |
| 1,1,1-trichloroethane   | Tank Farm 2 | <35             | <35    | ---        | ---   |
| Trichloroethene         | Tank Farm 2 | <35             | <35    | ---        | ---   |
| Chloroform              | Tank Farm 2 | <35             | <35    | ---        | ---   |
| Vinyl chloride          | Tank Farm 2 | <35             | <35    | ---        | ---   |
| m+p-xylenes             | Tank Farm 2 | 1540            | 1530   | 1535       | 0.65  |
| o-xylene                | Tank Farm 2 | 576             | 562    | 569        | 2.5   |

Nine Silco canister samples, laboratory numbers 20795-(31-39), were analyzed for SCAQMD Rule 1150.1 components. Agreement between repeat analyses is a measure of precision and is shown above in the column "% RPD". The average % RPD for 7 repeat measurements from nine Silco canister samples is 3.5%.




W002AS


## CHAIN OF CUSTODY RECORD

|   |                            |   |               |                                       |  |  |  |  |  |         |                 |
|---|----------------------------|---|---------------|---------------------------------------|--|--|--|--|--|---------|-----------------|
| Client/Project Name:<br><b>Montrose AQS</b><br>Project Number:<br><b>Plot 7</b> |                            | Project Location:<br><b>CHQUITA LANDFILL</b><br>Purchase Order Number:<br><b></b> |               | ANALYSES REQUESTED                    |  |  |  |  |  |         |                 |
| Sample: (Signature)<br><b>Plot 7</b>  |                            | Turnaround Times:<br>Standard 10 day<br>Expedited: 24hr / 48hr / 72hr / 5 day     |               |                                       |  |  |  |  |  |         |                 |
| Client Sample Identification  | Type of Sample Canister ID | AtmAA Lab Number  | Sampling Date | Sampling Time                         |  |  |  |  |  |         | Special Remarks |
| TANK FARM 6   | 51383                      | 20795-31  | 3/20/25       | 0845                                  |  |  |  |  |  |         | # 6028          |
| TANK FARM 9A  | 49442                      | -32   |               | 0855                                  |  |  |  |  |  |         | # 564           |
| TANK FARM 9B  | 48469                      | -33   |               | 0855                                  |  |  |  |  |  |         | # 54%           |
| TANK FARM 2   | 46911                      | -34   |               | 0900                                  |  |  |  |  |  |         | # 537           |
| TANK FARM 7A  | 47728                      | -35   |               | 0935                                  |  |  |  |  |  |         | # 566           |
| TANK FARM 7B  | 48864                      | -36   |               | 0935                                  |  |  |  |  |  |         | # 562           |
| ZEECO INLET   | 51125                      | -37   |               | 0935                                  |  |  |  |  |  |         | # 601           |
| Relinquished by: (Signature)  |                            | Date  | Time          | Received by: (Signature)              |  |  |  |  |  | Date    | Time            |
|   |                            | 3/20/25   |               |                                       |  |  |  |  |  |         |                 |
| Relinquished by: (Signature)  |                            | Date  | Time          | Received by: (Signature)              |  |  |  |  |  | Date    | Time            |
|   |                            |   |               |                                       |  |  |  |  |  |         |                 |
| Relinquished by: (Signature)  |                            | Date  | Time          | Received for Laboratory: (Signature)  |  |  |  |  |  | Date    | Time            |
|   |                            | 3/20/25   |               |                                       |  |  |  |  |  | 3/20/25 | 11:55           |
| Company Info:   |                            | Send Report to:   |               | Analytical Laboratory                 |  |  |  |  |  |         |                 |
| Company: <b>Montrose</b>  |                            | Company: <b>Montrose</b>  |               | AtmAA Inc.                            |  |  |  |  |  |         |                 |
| Street Address: <b>621 E. ST. ANDREW</b>  |                            | Street Address: <b>621 E. ST. ANDREW</b>  |               | 23917 Craftsman Rd.                   |  |  |  |  |  |         |                 |
| City/State/Zip: <b>SPRING AREA</b>  |                            | City/State/Zip: <b>SPRING AREA</b>  |               | Calabasas, CA 91302                   |  |  |  |  |  |         |                 |
| Telephone No.: <b>422-6077 6313</b>   |                            | Project Manager: <b>ROTE SANDJUN</b>  |               | TEL: (818) 223-3277                   |  |  |  |  |  |         |                 |
| Email Address: <b>psangwane@montrose.com</b>                                    |                            |   |               | Email Address: <b>info@atmama.com</b> |  |  |  |  |  |         |                 |

— 200 —

**CHAIN OF CUSTODY RECORD**

| CHAIN OF CUSTODY RECORD  |                |                                      |                  |               |   |                 |
|--|----------------|--------------------------------------|------------------|---------------|---|-----------------|
| Client/Project Name:   |                | ANALYSES REQUESTED                   |                  |               |   |                 |
| MONTROSE AQ5   |                | Oilfield Landfill                    |                  |               |   |                 |
| Project Number:  |                | Purchase Order Number:               |                  |               |   |                 |
| Project Manager: <i>Project J</i>  |                |                                      |                  |               |   |                 |
| Sampler: <i>Project J</i>  |                |                                      |                  |               |   |                 |
| Turnaround Times: Standard 10 day<br>Expedited: 24hr / 48hr / 72hr / 5 day |                |                                      |                  |               |   |                 |
| Client Sample Identification   | Type of Sample | Canister ID                          | AtmAA Lab Number | Sampling Date | Sampling Time   | Special Remarks |
| TRAILER STATION POSTH2S  | 49439          | 20195-38                             | 3/20/25          | 1010          |   | # 581           |
| FLAESTATE# POSTH2S   | 46611          | -39                                  | N                | 1010          |   | # 516           |
| Relinquished by: <i>Project J</i>  |                | Date: <u>3/20/25</u>                 |                  | Time          | Received by: (Signature)  | Date Time       |
| Relinquished by: (Signature)   |                | Date                                 |                  | Time          | Received by: (Signature)  | Date Time       |
| Relinquished by: (Signature)   |                | Date                                 |                  | Time          | Received for Laboratory by: (Signature)   | Date Time       |
| Company Info: <input type="text"/>   |                | Send Report to:                      |                  |               | AtmAA Inc.  |                 |
| Company: <input type="text"/>  |                | Company: <input type="text"/>        |                  |               | 23917 Craftsman Rd.   |                 |
| Street Address: <input type="text"/>                                       |                | Street Address: <input type="text"/> |                  |               | Calabasas, CA 91302   |                 |
| City/State/Zip: <input type="text"/>                                       |                | City/State/Zip: <input type="text"/> |                  |               | TEL: (818) 223-3277   |                 |
| Telephone No: <input type="text"/>   |                | Telephone No: <input type="text"/>   |                  |               | Email Address: <input type="text"/>   |                 |
|  |                |                                      |                  |               |  |                 |



W002AS-053154-RT-7193

85 of 120

## **Appendix A.4 Quality Assurance Data**

### Barometric Pressure Determination

Date: 03/20/25

Time: 7:30

Data By: SJ, KT

Reference:

<https://forecast.weather.gov/MapClick.php?lat=33.6873&lon=118.66712&zoom=4&model=gfs&product=precip>

Lat: 34.42972°N Lon: 118.66712°W Elev: 1278.0ft.

|  |                   |
|--|-------------------|
| Reference Barometer ID                                 | DEL VALLE (DLVC1) |
| Reference Barometer Location                           |                   |
| Reference Barometer Other Info.                        |                   |
| Reference Barometer Indication, corrected to sea level |                   |
| Reference Barometer Reference Elevation                | 30.03             |
| Reference Barometer Actual Pressure                    | 1278              |
| Test Barometer Location/Site                           | Chiquita Canyon   |
| Location/Site Elevation                                | 997               |
| Location/Site Barometric Pressure                      | 29.03             |
| Sampling Location Height (above/below site elevation)  | 1                 |
| Sampling Location Barometric Pressure                  | 29.03             |



## THERMOCOUPLE CALIBRATION

Thermocouple ID: TC-WB  
Date: 1/3/2025  
Performed By: JS/JS/JL

Calibrated Digital Temperature Readout ID: PTC-69  
T1 Reference Thermometer ID: 2788  
T2 Reference Thermometer ID: 2736  
T3 Reference Thermometer ID: 0514-1120

| T/C<br>I.D.<br>TC-WB | Readout<br>I.D. | T/C - Readout<br>°F |           |           |         | Reference Thermometer<br>°F |           |           |         | Difference |         |
|----------------------|-----------------|---------------------|-----------|-----------|---------|-----------------------------|-----------|-----------|---------|------------|---------|
|                      |                 | Reading 1           | Reading 2 | Reading 3 | Average | Reading 1                   | Reading 2 | Reading 3 | Average | °F         | %, (°R) |
| T3 (~ 370 F)         | PTC-69          | 367                 | 367       | 367       | 367     | 370                         | 370       | 370       | 370     | 3.0        | 0.4%    |
| T2 (~ 212 F)         | PTC-69          | 215                 | 215       | 215       | 215     | 212                         | 212       | 212       | 212     | 3.0        | 0.4%    |
| T1 (~ 32 F)          | PTC-69          | 33                  | 33        | 33        | 33      | 32                          | 32        | 32        | 32      | 1.0        | 0.2%    |

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



## THERMOCOUPLE CALIBRATION

Thermocouple ID: TC-DB  
Date: 1/3/2025  
Performed By: JS/JS/JL

Calibrated Digital Temperature Readout ID: PTC-69  
T1 Reference Thermometer ID: 2788  
T2 Reference Thermometer ID: 2736  
T3 Reference Thermometer ID: 0514-1120

| T/C<br>I.D.<br>TC-DB | Readout<br>I.D. | T/C - Readout<br>°F |           |           |         | Reference Thermometer<br>°F |           |           |         | Difference |         |
|----------------------|-----------------|---------------------|-----------|-----------|---------|-----------------------------|-----------|-----------|---------|------------|---------|
|                      |                 | Reading 1           | Reading 2 | Reading 3 | Average | Reading 1                   | Reading 2 | Reading 3 | Average | °F         | %, (°R) |
| T3 (~ 370 F)         | PTC-69          | 371                 | 371       | 371       | 371     | 370                         | 370       | 370       | 370     | 1.0        | 0.1%    |
| T2 (~ 212 F)         | PTC-69          | 215                 | 215       | 215       | 215     | 212                         | 212       | 212       | 212     | 3.0        | 0.4%    |
| T1 (~ 32 F)          | PTC-69          | 32                  | 32        | 32        | 32      | 32                          | 32        | 32        | 32      | 0.0        | 0.0%    |

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



## THERMOCOUPLE CALIBRATION

Thermocouple ID: 145  
Date: 1/3/2025  
Performed By: JS/JS/JL

Calibrated Digital Temperature Readout ID: PTC-69  
T1 Reference Thermometer ID: 2788  
T2 Reference Thermometer ID: 2736  
T3 Reference Thermometer ID: 0514-1120

| T/C<br>I.D.  | Readout<br>I.D. | T/C - Readout<br>°F |           |           |         | Reference Thermometer<br>°F |           |           |         | Difference |         |
|--------------|-----------------|---------------------|-----------|-----------|---------|-----------------------------|-----------|-----------|---------|------------|---------|
|              |                 | Reading 1           | Reading 2 | Reading 3 | Average | Reading 1                   | Reading 2 | Reading 3 | Average | °F         | %, (°R) |
| T3 (~ 370 F) | PTC-69          | 368                 | 368       | 368       | 368     | 370                         | 370       | 370       | 370     | 2.0        | 0.2%    |
| T2 (~ 212 F) | PTC-69          | 212                 | 212       | 212       | 212     | 212                         | 212       | 212       | 212     | 0.0        | 0.0%    |
| T1 (~ 32 F)  | PTC-69          | 33                  | 33        | 33        | 33      | 32                          | 32        | 32        | 32      | 1.0        | 0.2%    |

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



## THERMOCOUPLE CALIBRATION

Thermocouple ID: 146  
Date: 1/3/2025  
Performed By: JS/JS/JL

Calibrated Digital Temperature Readout ID: PTC-69  
T1 Reference Thermometer ID: 2788  
T2 Reference Thermometer ID: 2736  
T3 Reference Thermometer ID: 0514-1120

| T/C<br>I.D.<br>146 | Readout<br>I.D. | T/C - Readout<br>°F |           |           |         | Reference Thermometer<br>°F |           |           |         | Difference |         |
|--------------------|-----------------|---------------------|-----------|-----------|---------|-----------------------------|-----------|-----------|---------|------------|---------|
|                    |                 | Reading 1           | Reading 2 | Reading 3 | Average | Reading 1                   | Reading 2 | Reading 3 | Average | °F         | %, (°R) |
| T3 (~ 370 F)       | PTC-69          | 366                 | 366       | 366       | 366     | 370                         | 370       | 370       | 370     | 4.0        | 0.5%    |
| T2 (~ 212 F)       | PTC-69          | 212                 | 212       | 212       | 212     | 212                         | 212       | 212       | 212     | 0.0        | 0.0%    |
| T1 (~ 32 F)        | PTC-69          | 34                  | 34        | 34        | 34      | 32                          | 32        | 32        | 32      | 2.0        | 0.4%    |

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



## DIGITAL TEMPERATURE READOUT CALIBRATION

Digital Temperature Readout ID: PTC-43  
Readout Description: Handheld  
Date: 1/3/2025  
Performed By: JS, JS, JI

Calibrated Thermocouple ID: TC-Cal  
T1 Reference Thermometer ID: 2788  
T2 Reference Thermometer ID: 2736  
T3 Reference Thermometer ID: 0514-1120

| T/C<br>I.D.<br>TC-Cal | Readout<br>I.D. | T/C - Readout<br>°F |           |           |         | Reference Thermometer<br>°F |           |           |         | Difference |         |
|-----------------------|-----------------|---------------------|-----------|-----------|---------|-----------------------------|-----------|-----------|---------|------------|---------|
|                       |                 | Reading 1           | Reading 2 | Reading 3 | Average | Reading 1                   | Reading 2 | Reading 3 | Average | °F         | %, (°R) |
| T3 (~ 370 F)          | PTC-43          | 370                 | 370       | 370       | 370     | 370                         | 370       | 370       | 370     | 0.0        | 0.0%    |
| T2 (~212 F)           | PTC-43          | 213                 | 213       | 213       | 213     | 212                         | 212       | 212       | 212     | 1.0        | 0.1%    |
| T1 (~ 32 F)           | PTC-43          | 32                  | 32        | 32        | 32      | 32                          | 32        | 32        | 32      | 0.0        | 0.0%    |

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)

### Thermocouple Source Readings


| T/C Source<br>S/N | T/C - Readout<br>°F |           |           |         | T/C Source<br>°F |           |           |         | Difference |         |      |
|-------------------|---------------------|-----------|-----------|---------|------------------|-----------|-----------|---------|------------|---------|------|
|                   | Reading 1           | Reading 2 | Reading 3 | Average | Reading 1        | Reading 2 | Reading 3 | Average | °F         | %, (°R) |      |
| T4 (~650 F)       | 129462              | 648       | 648       | 648     | 648              | 650       | 650       | 650     | 650        | 2.0     | 0.2% |
| T3 (~370 F)       | 129462              | 370       | 370       | 370     | 370              | 370       | 370       | 370     | 370        | 0.0     | 0.0% |
| T2 (~212 F)       | 129462              | 212       | 212       | 212     | 212              | 212       | 212       | 212     | 212        | 0.0     | 0.0% |
| T1 (~32 F)        | 129462              | 32        | 32        | 32      | 32               | 32        | 32        | 32      | 32         | 0.0     | 0.0% |

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



## S Type Pitot Tube Dimensional Calibration Record



| Pilot ID | Acceptability Criteria                                | Acceptability Criteria                                 |               | Acceptability Criteria |               | Acceptability Criteria |               | Acceptability Criteria |               | Acceptability Criteria |               | Acceptability Criteria |  |
|----------|---|--|---------------|------------------------|---------------|------------------------|---------------|------------------------|---------------|------------------------|---------------|------------------------|--|
|          |   | Date   | Calibrated By | Date                   | Calibrated By | Date                   | Calibrated By | Date                   | Calibrated By | Date                   | Calibrated By | Date                   | Calibrated By  |
| 145      | z < 1/8"  | w < 1/32"  | Yes           | "3/16" < Dt < 3/8"     | n/a           | n/a                    | n/a           | n/a                    | n/a           | n/a                    | n/a           | n/a                    | 1.05 Dt < P < 1.5 Dt   |
| 146      | Side View, Impact openings Properly aligned, z < 1/8" | Side View, Impact openings Properly aligned, w < 1/32" | Pb = Pb       | Tubing Diameter, dt    | M1            | M2                     | M3            | M4                     | M5            | M6                     | M6            | M6                     | Average Face Opening Plane Angle, offset from perpendicular to transverse axis |

Notes:

# DIFFERENTIAL PRESSURE CALIBRATION

Semi-annual

Display ID: ADM 9  
 Description: Air Data Multimeter (ADM 850)  
 Serial Number: M14140  
 Calibration Date: 1/31/2025

Reference Device ID: Microtector  
 Reference Serial Number: S270  
 Calibrated By: K. Thomas

| Calibration Range<br>Scale: 0 - 0.050<br>inches H <sub>2</sub> O |       | Run 1<br>Measured Value<br>(inches W.C.) |  | Run 1<br>Reference Value<br>(inches W.C.) |  | Absolute Value |  | Individual Run Results<br>% Difference |       | Pass/ Fail |  |
|--|-------|--|--|---|--|----------------|--|--|-------|------------|--|
| Target 20%   | 0.010 | 0.010                                    |  | 0.010                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |
| Target 40%   | 0.020 | 0.020                                    |  | 0.020                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |
| Target 60%   | 0.030 | 0.030                                    |  | 0.030                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |
| Target 80%   | 0.040 | 0.040                                    |  | 0.040                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |
| Target 100%  | 0.050 | 0.050                                    |  | 0.050                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |

| Calibration Range<br>Scale: 0 - 0.050<br>inches H <sub>2</sub> O |       | Run 2<br>Measured Value<br>(inches W.C.) |  | Run 2<br>Reference Value<br>(inches W.C.) |  | Absolute Value |  | Individual Run Results<br>% Difference |       | Pass/ Fail |  |
|--|-------|--|--|---|--|----------------|--|--|-------|------------|--|
| Target 20%   | 0.010 | 0.010                                    |  | 0.010                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |
| Target 40%   | 0.020 | 0.020                                    |  | 0.020                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |
| Target 60%   | 0.030 | 0.030                                    |  | 0.030                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |
| Target 80%   | 0.040 | 0.040                                    |  | 0.040                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |
| Target 100%  | 0.050 | 0.050                                    |  | 0.050                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |

| Calibration Range<br>Scale: 0 - 0.050<br>inches H <sub>2</sub> O |       | Run 3<br>Measured Value<br>(inches W.C.) |  | Run 3<br>Reference Value<br>(inches W.C.) |  | Absolute Value |  | Individual Run Results<br>% Difference |       | Pass/ Fail |  |
|--|-------|--|--|---|--|----------------|--|--|-------|------------|--|
| Target 20%   | 0.010 | 0.010                                    |  | 0.010                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |
| Target 40%   | 0.020 | 0.020                                    |  | 0.020                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |
| Target 60%   | 0.030 | 0.030                                    |  | 0.030                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |
| Target 80%   | 0.040 | 0.040                                    |  | 0.040                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |
| Target 100%  | 0.050 | 0.050                                    |  | 0.050                                     |  | 0.0000         |  | 0.00%                                  | 0.00% | Pass       |  |

Criteria: Each individual measured value within + or - 5.0% of reference value.  
 Percent difference of three run average within 5.0 %.

MONROE

| Average results for three runs |           |
|--------------------------------|-----------|
| % Difference                   | Pass/Fail |

# DIFFERENTIAL PRESSURE CALIBRATION

Semi-annual

Display ID: ADM 9  
 Description: Air Data Multimeter (ADM 850)  
 Serial Number: M14140  
 Calibration Date: 1/31/2025

Reference Device ID: Microtector  
 Reference Serial Number: S270  
 Calibrated By: K. Thomas

| Calibration Range |  | Run 1                         |                | Run 2                                     |                | Run 3                                     |                | Individual Run Results |            |
|-------------------|--|-------------------------------|----------------|---|----------------|---|----------------|------------------------|------------|
| Scale:            | Measured Value (inches H <sub>2</sub> O) | Reference Value (inches W.C.) | Absolute Value | Reference Value (inches H <sub>2</sub> O) | Absolute Value | Reference Value (inches H <sub>2</sub> O) | Absolute Value | % Difference           | Pass/ Fail |
| Target 20%        | 0.020                                    | 0.020                         | 0.0000         | 0.020                                     | 0.0000         | 0.020                                     | 0.0000         | 0.00%                  | Pass       |
| Target 40%        | 0.040                                    | 0.040                         | 0.0000         | 0.040                                     | 0.0000         | 0.040                                     | 0.0000         | 0.00%                  | Pass       |
| Target 60%        | 0.060                                    | 0.059                         | 0.0010         | 0.060                                     | 0.0010         | 0.060                                     | 0.0010         | 1.67%                  | Pass       |
| Target 80%        | 0.080                                    | 0.079                         | 0.0010         | 0.080                                     | 0.0010         | 0.080                                     | 0.0010         | 1.25%                  | Pass       |
| Target 100%       | 0.100                                    | 0.100                         | 0.0000         | 0.100                                     | 0.0000         | 0.100                                     | 0.0000         | 0.00%                  | Pass       |

Criteria: Each individual measured value within + or - 5.0% of reference value.  
 Percent difference of three run average within 5.0 %.



# DIFFERENTIAL PRESSURE CALIBRATION

Semi-annual

Display ID: ADM 9

Description: Air Data Multimeter (ADM 850)

Serial Number: M14140

Calibration Date: 1/3/2025


Reference Device ID: Microtector

Reference Serial Number: S270

Calibrated By: K. Thomas

| Calibration Range |                              | Run 1                         |                | Run 2                         |                | Run 3                         |                | Individual Run Results |              | Average results for three runs |           |
|-------------------|------------------------------|-------------------------------|----------------|-------------------------------|----------------|-------------------------------|----------------|------------------------|--------------|--------------------------------|-----------|
| Scale:            | Measured Value (inches W.C.) | Reference Value (inches W.C.) | Absolute Value | Reference Value (inches W.C.) | Absolute Value | Reference Value (inches W.C.) | Absolute Value | % Difference           | % Difference | % Difference                   | Pass/Fail |
| Target 20%        | 0.200                        | 0.200                         | 0.0000         | 0.200                         | 0.0000         | 0.200                         | 0.0000         | 0.00%                  | 0.00%        | 0.00%                          | Pass      |
| Target 40%        | 0.400                        | 0.401                         | 0.0010         | 0.400                         | 0.0010         | 0.400                         | 0.0010         | 0.25%                  | 0.25%        | 0.25%                          | Pass      |
| Target 60%        | 0.600                        | 0.602                         | 0.0020         | 0.600                         | 0.0020         | 0.600                         | 0.0020         | 0.33%                  | 0.33%        | 0.33%                          | Pass      |
| Target 80%        | 0.800                        | 0.800                         | 0.0000         | 0.800                         | 0.0000         | 0.800                         | 0.0000         | 0.00%                  | 0.00%        | 0.00%                          | Pass      |
| Target 100%       | 1.000                        | 1.000                         | 0.0000         | 1.000                         | 0.0000         | 1.000                         | 0.0000         | 0.00%                  | 0.00%        | 0.00%                          | Pass      |

Criteria: Each individual measured value within + or - 5.0% of reference value.  
Percent difference of three run average within 5.0 %.



# DIFFERENTIAL PRESSURE CALIBRATION

Semi-annual

Display ID: ADM 9  
 Description: Air Data Multimeter (ADM 850)  
 Serial Number: M14140  
 Calibration Date: 1/13/2025

Reference Device ID: Dwyer 0 - 10" Manometer  
 Reference Serial Number: CC-2  
 Calibrated By: K. Thomas

| Calibration Range |  | Run 1                         |                | Individual Run Results |            |
|-------------------|--|-------------------------------|----------------|------------------------|------------|
| Scale:            | Measured Value (inches H <sub>2</sub> O) | Reference Value (inches W.C.) | Absolute Value | % Difference           | Pass/ Fail |
| Target 20%        | 2.000                                    | 1.955                         | 2.000          | 2.25%                  | Pass       |
| Target 40%        | 4.000                                    | 4.015                         | 4.000          | 0.37%                  | Pass       |
| Target 60%        | 6.000                                    | 6.010                         | 6.000          | 0.17%                  | Pass       |
| Target 80%        | 8.000                                    | 8.045                         | 8.000          | 0.56%                  | Pass       |
| Target 100%       | 10.000                                   | 10.100                        | 10.000         | 1.00%                  | Pass       |

| Calibration Range |  | Run 2                         |                | Individual Run Results |            |
|-------------------|--|-------------------------------|----------------|------------------------|------------|
| Scale:            | Measured Value (inches H <sub>2</sub> O) | Reference Value (inches W.C.) | Absolute Value | % Difference           | Pass/ Fail |
| Target 20%        | 2.000                                    | 1.995                         | 2.000          | 0.25%                  | Pass       |
| Target 40%        | 4.000                                    | 4.035                         | 4.000          | 0.88%                  | Pass       |
| Target 60%        | 6.000                                    | 6.095                         | 6.000          | 1.58%                  | Pass       |
| Target 80%        | 8.000                                    | 8.055                         | 8.000          | 0.69%                  | Pass       |
| Target 100%       | 10.000                                   | 10.100                        | 10.000         | 1.00%                  | Pass       |

| Calibration Range |  | Run 3                         |                | Individual Run Results |            |
|-------------------|--|-------------------------------|----------------|------------------------|------------|
| Scale:            | Measured Value (inches H <sub>2</sub> O) | Reference Value (inches W.C.) | Absolute Value | % Difference           | Pass/ Fail |
| Target 20%        | 2.000                                    | 1.990                         | 2.000          | 0.50%                  | Pass       |
| Target 40%        | 4.000                                    | 4.090                         | 4.000          | 2.25%                  | Pass       |
| Target 60%        | 6.000                                    | 6.095                         | 6.000          | 1.58%                  | Pass       |
| Target 80%        | 8.000                                    | 8.040                         | 8.000          | 0.50%                  | Pass       |
| Target 100%       | 10.000                                   | 10.050                        | 10.000         | 0.50%                  | Pass       |

| Average results for three runs |           |      |
|--------------------------------|-----------|------|
| % Difference                   | Pass/Fail | Pass |
| 0.94%                          |           |      |

Criteria: Each individual measured value within + or - 5.0% of reference value.  
 Percent difference of three run average within 5.0 %.



## **APPENDIX B**

## **GENERAL EMISSIONS CALCULATIONS**

## GENERAL EMISSIONS CALCULATIONS

### I. Stack Gas Velocity

A. Stack gas molecular weight, lb/lb-mole

$$MW_{dry} = 0.44 * \% CO_2 + 0.32 * \% O_2 + 0.28 * \% N_2$$

$$MW_{wet} = MW_{dry} * (1 - B_{wo}) + 18 * B_{wo}$$

B. Absolute stack pressure, iwg

$$P_s = P_{bar} + \frac{P_{sg}}{13.6}$$

C. Stack gas velocity, ft/sec

$$V_s = 2.9 * C_p * \sqrt{\Delta P} * \sqrt{T_s} * \sqrt{\frac{29.92 * 28.95}{P_s * MW_{wet}}}$$

### II. Moisture

A. Sample gas volume, dscf

$$V_{mstd} = 0.03342 * V_m * \left( P_{bar} + \frac{\Delta H}{13.6} \right) * \frac{T_{ref}}{T_m} * Y_d$$

B. Water vapor volume, scf

$$V_{wstd} = 0.0472 * V_{ic} * \frac{T_{ref}}{528^{\circ}R}$$

C. Moisture content, dimensionless

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

### III. Stack Gas Volumetric Flow Rate

A. Actual stack gas volumetric flow rate, wacfm

$$Q = V_s * A_s * 60$$

B. Standard stack gas flow rate, dscfm

$$Q_{sd} = Q * (1 - B_{wo}) * \frac{T_{ref}}{T_s} * \frac{P_s}{29.92}$$

Nomenclature:

|                |   |   |
|----------------|---|---|
| $A_s$          | = | stack area, ft <sup>2</sup>   |
| $B_{wo}$       | = | flue gas moisture content, dimensionless  |
| $C_{12\%CO_2}$ | = | particulate grain loading, gr/dscf corrected to 12% CO <sub>2</sub>                               |
| $C$            | = | particulate grain loading, gr/dscf  |
| $C_p$          | = | pitot calibration factor, dimensionless   |
| $D_n$          | = | nozzle diameter, inches   |
| $F$            | = | fuel F-Factor, dscf/MMBtu @ 0% O <sub>2</sub>   |
| $H$            | = | orifice differential pressure, iwg  |
| $I$            | = | % isokinetics   |
| $M_n$          | = | mass of collected particulate, mg   |
| $M_i$          | = | mass emission rate of specie i, lb/hr   |
| $MW$           | = | molecular weight of flue gas, lb/lb-mole  |
| $M_{wi}$       | = | molecular weight of specie i:<br>SO <sub>2</sub> : 64<br>NO <sub>x</sub> : 46<br>CO: 28<br>HC: 16 |
| $t$            | = | sample time, minutes  |
| $\Delta P$     | = | average velocity head, iwg = $(\sqrt{\Delta P})^2$  |
| $P_{bar}$      | = | barometric pressure, inches Hg  |
| $P_s$          | = | stack absolute pressure, inches Hg  |
| $P_{sg}$       | = | stack static pressure, iwb  |
| $Q$            | = | wet stack flow rate at actual conditions, wacfm   |
| $Q_{sd}$       | = | dry standard stack flow rate, dscfm   |
| $SV$           | = | specific molar volume of an ideal gas at standard conditions, ft <sup>3</sup> /lb-mole            |
| $T_m$          | = | meter temperature, °R   |
| $T_{ref}$      | = | reference temperature, °R   |
| $T_s$          | = | stack temperature, °R   |
| $V_s$          | = | stack gas velocity, ft/sec  |
| $V_{lc}$       | = | volume of liquid collected in impingers, ml   |
| $V_m$          | = | uncorrected dry meter volume, dcf   |
| $V_{mstd}$     | = | dry meter volume at standard conditions, dscf   |
| $V_{wstd}$     | = | volume of water vapor at standard conditions, scf   |
| $Y_d$          | = | meter calibration coefficient   |

## **APPENDIX C**

## **QUALITY ASSURANCE**

## **Appendix C.1**

### **Quality Assurance Program Summary**

## QUALITY ASSURANCE PROGRAM SUMMARY

As part of Montrose Air Quality Services, LLC (Montrose) ASTM D7036-04 certification, Montrose is committed to providing emission related data which is complete, precise, accurate, representative, and comparable. Montrose quality assurance program and procedures are designed to ensure that the data meet or exceed the requirements of each test method for each of these items. The quality assurance program consists of the following items:

- Assignment of an Internal QA Officer
- Development and use of an internal QA Manual
- Personnel training
- Equipment maintenance and calibration
- Knowledge of current test methods
- Chain-of-custody
- QA reviews of test programs

Assignment of an Internal QA Officer: Montrose has assigned an internal QA Officer who is responsible for administering all aspects of the QA program.

Internal Quality Assurance Manual: Montrose has prepared a QA Manual according to the requirements of ASTM D7036-04 and guidelines issued by EPA. The manual documents and formalizes all of Montrose's QA efforts. The manual is revised upon periodic review and as Montrose adds capabilities. The QA manual provides details on the items provided in this summary.

Personnel Testing and Training: Personnel testing and training is essential to the production of high quality test results. Montrose training programs include:

- A requirement for all technical personnel to read and understand the test methods performed
- A requirement for all technical personnel to read and understand the Montrose QA manual
- In-house testing and training
- Quality Assurance meetings
- Third party testing where available
- Maintenance of training records.

Equipment Maintenance and Calibration: All laboratory and field equipment used as a part of Montrose's emission measurement programs is maintained according to manufacturer's recommendations. A summary of the major equipment maintenance schedules is summarized in Table 1. In addition to routine maintenance, calibrations are performed on all sampling equipment according to the procedures outlined in the applicable test method. The calibration intervals and techniques for major equipment components is summarized in Table 2. The calibration technique may vary to meet regulatory agency requirements.

Knowledge of Current Test Methods: Montrose maintains current copies of EPA, ARB, and SCAQMD Source Test Manuals and Rules and Regulations.

**Chain-of-Custody:** Montrose maintains chain-of-custody documentation on all data sheets and samples. Samples are stored in a locked area accessible only to Montrose source test personnel. Data sheets are kept in the custody of the originator, program manager, or in locked storage until return to Montrose office. Electronic field data is duplicated for backup on secure storage media. The original data sheets are used for report preparation and any additions are initialed and dated.

**QA Reviews:** Periodic field, laboratory, and report reviews are performed by the in-house QA coordinator. Periodically, test plans are reviewed to ensure proper test methods are selected and reports are reviewed to ensure that the methods were followed and any deviations from the methods are justified and documented.

### **ASTM D7036-04 Required Information**

#### Uncertainty Statement

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one Qualified Individual (QI) as defined in D7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is presented in the report appendices.

#### Performance Data

Performance data are available for review.

#### Qualified Personnel

A qualified individual (QI), defined by performance on a third party or internal test on the test methods, is present on each test event.

#### Plant Entry and Safety Requirements

##### **Plant Entry**

All test personnel are required to check in with the guard at the entrance gate or other designated area. Specific details are provided by the facility and project manager.

## **Safety Requirements**

All personnel shall have the following personal protective equipment (PPE) and wear them where designated:

- Hard Hat
- Safety Glasses
- Steel Toe Boots
- Hearing Protection
- Gloves
- High Temperature Gloves (if required)
- Flame Resistant Clothing (if required)

The following safety measures are followed:

- Good housekeeping
- SDS for all on-site hazardous materials
- Confine selves to necessary areas (stack platform, mobile laboratory, CEMS data acquisition system, control room, administrative areas)
- Knowledge of evacuation procedures

Each facility will provide plant specific safety training.

**TABLE 1**  
**EQUIPMENT MAINTENANCE SCHEDULE**

| Equipment                  | Acceptance Limits  | Frequency of Service           | Methods of Service   |
|----------------------------|--|--------------------------------|--|
| Pumps                      | 1. Absence of leaks<br>2. Ability to draw manufacturers required vacuum and flow | As recommended by manufacturer | 1. Visual inspection<br>2. Clean<br>3. Replace parts<br>4. Leak check                          |
| Flow Meters                | 1. Free mechanical movement  | As recommended by manufacturer | 1. Visual inspection<br>2. Clean<br>3. Calibrate   |
| Sampling Instruments       | 1. Absence of malfunction<br>2. Proper response to zero span gas                 | As recommended by manufacturer | As recommended by manufacturer   |
| Integrated Sampling Tanks  | 1. Absence of leaks  | Depends on nature of use       | 1. Steam clean<br>2. Leak check  |
| Mobile Van Sampling System | 1. Absence of leaks  | Depends on nature of use       | 1. Change filters<br>2. Change gas dryer<br>3. Leak check<br>4. Check for system contamination |
| Sampling Lines             | 1. Sample degradation less than 2%   | After each test series         | 1. Blow dry, inert gas through line until dry  |

**TABLE 2**  
**MAJOR SAMPLING EQUIPMENT CALIBRATION REQUIREMENTS**

| Sampling Equipment                                   | Calibration Frequency          | Calibration Procedure   | Acceptable Calibration Criteria              |
|--|--------------------------------|---|--|
| Continuous Analyzers                                 | Before and After Each Test Day | 3-point calibration error test                                    | < 2% of analyzer range                       |
| Continuous Analyzers                                 | Before and After Each Test Run | 2-point sample system bias check                                  | < 5% of analyzer range                       |
| Continuous Analyzers                                 | After Each Test Run            | 2-point analyzer drift determination                              | < 3% of analyzer range                       |
| CEMS System  | Beginning of Each Day          | leak check  | < 1 in. Hg decrease in 5 min. at > 20 in. Hg |
| Continuous Analyzers                                 | Semi-Annually                  | 3-point linearity   | < 1% of analyzer range                       |
| NO <sub>x</sub> Analyzer                             | Daily                          | NO <sub>2</sub> -> NO converter efficiency                        | > 90%  |
| Differential Pressure Gauges (except for manometers) | Semi-Annually                  | Correction factor based on 5-point comparison to standard         | ± 5%   |
| Differential Pressure Gauges (except for manometers) | Bi-Monthly                     | 3-point comparison to standard, no correction factor              | ± 5%   |
| Barometer  | Semi-Annually                  | Adjusted to mercury-in-glass or National Weather Service Station  | ± 0.1 inches Hg                              |
| Dry Gas Meter  | Semi-Annually                  | Calibration check at 4 flow rates using a NIST traceable standard | ± 2%   |
| Dry Gas Meter  | Bi-Monthly                     | Calibration check at 2 flow rates using a NIST traceable standard | ± 2% of semi-annual factor                   |
| Dry Gas Meter Orifice                                | Annually                       | 4-point calibration for ΔH@                                       | --   |
| Temperature Sensors                                  | Semi-Annually                  | 3-point calibration vs. NIST traceable standard                   | ± 1.5%                                       |

Note: Calibration requirements that meet applicable regulatory agency requirements are used.

## **Appendix C.2 SCAQMD and STAC Certifications**

SCS Engineers – Chiquita Canyon Landfill  
2025 1<sup>st</sup> Quarter Leachate and Condensate Vapor Sampling



September 26, 2024

Mr. John Peterson  
Montrose Air Quality Services, LLC  
1631 E. Saint Andrew Place  
Santa Ana, CA 92705

Subject: LAP Approval Notice  
Reference # 96LA1220

Dear Mr. Peterson:

We have completed our review of Montrose Air Quality Services' revised renewal application, which was submitted as notification of Montrose's recent acquisition of AirKinetics, Inc. under the South Coast AQMD Laboratory Approval Program (LAP). We are pleased to inform you that your firm is approved for the period beginning September 30, 2024, and ending September 30, 2025, for the following methods, subject to the requirements in the LAP Conditions For Approval Agreement and conditions listed in the attachment to this letter:

South Coast AQMD Methods 1-4  
South Coast AQMD Methods 10.1 and 100.1  
South Coast AQMD Methods 5.1, 5.2, 5.3, 6.1 (Sampling and Analysis)  
South Coast AQMD Methods 25.1 and 25.3 (Sampling)  
Rule 1121/ 1146.2 Protocol  
Rule 1420/1420.1/1420.2 – (Lead) Source and Ambient Sampling  
USEPA CTM-030 and ASTM D6522-00

Your LAP approval to perform nitrogen oxide emissions compliance testing for Rule 1121/ 1146.2 Protocols includes satellite facilities located at:

|  |   |  |
|--|---|--|
| McKenna Boiler<br>1510 North Spring Street<br>Los Angeles, CA 90012                              | Noritz America Corp.<br>11160 Grace Avenue<br>Fountain Valley, CA 92708               | Ajax Boiler, Inc.<br>2701 S. Harbor Blvd.<br>Santa Ana, CA 92704 |
| VA Laundry Bldg., Greater LA Healthcare Sys.<br>508 Constitution Avenue<br>Los Angeles, CA 90049 | So Cal Gas – Engr Analysis Ctr, Bldg H<br>8101 Rosemead Blvd<br>Pico Rivera, CA 90660 |  |

Thank you for participating in the LAP. Your cooperation helps us to achieve the goal of the LAP: to maintain high standards of quality in the sampling and analysis of source emissions. You may direct any questions or information to LAP Coordinator, Colin Eckerle. He may be reached by telephone at (909) 396-2476, or via e-mail at ceckerle@aqmd.gov.

Sincerely,

*D. Sarkar*

Dipankar Sarkar  
Program Supervisor  
Source Test Engineering

DS:CE  
Attachment  
240926 LapRenewal.doc



American Association for Laboratory Accreditation

## Accredited Air Emission Testing Body

A2LA has accredited

## MONROSE AIR QUALITY SERVICES

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 27<sup>th</sup> day of February 2024.

Vice President, Accreditation Services  
For the Accreditation Council  
Certificate Number 3925.01  
Valid to February 28, 2026



*This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.*

## **Appendix C.3 Individual QI Certifications**

**CERTIFICATE OF COMPLETION**

Pedro SanJuan

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

**SCAQMD Methods 1.1, 1.2, 2.1, 2.2, 2.3, 3.1, & 4.1**

**Certificate Number:** 002-2022-50

*Tate Strickler*

Tate Strickler, VP – Quality Systems

DATE OF ISSUE: 02/28/2022

DATE OF EXPIRATION: 02/27/2027

**CERTIFICATE OF COMPLETION**

Pedro SanJuan

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

**SCAQMD Methods 25.1, 25.3 & 307-91**

**Certificate Number:** 002-2022-52

*Tate Strickler*

Tate Strickler, VP – Quality Systems

DATE OF ISSUE: 02/28/2022

DATE OF EXPIRATION: 02/27/2027



**CERTIFICATE OF COMPLETION**

**Pedro SanJuan**

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

**EPA Methods 3C, TO-8, TO-12 and TO-15**

**Certificate Number: 002-2023-48**

*Tate Strickler*

Tate Strickler, VP – Quality Systems

DATE OF ISSUE: 11/01/2023

DATE OF EXPIRATION: 10/31/2028

**MONTROSE**  
ENVIRONMENTAL



## **Appendix C.4**

### **Statement of No Conflict of Interest**

**STATEMENT OF NO CONFLICT OF INTEREST AS AN INDEPENDENT TESTING LABORATORY**

*(To be completed by authorized source testing firm representative and included in source test report)*

The following facility and equipment were tested by my source testing firm and are the subjects of this statement:

|                    |   |
|--------------------|---|
| Facility ID:       | 119219  |
| Date(s) Tested:    | March 20, 2025                                      |
| Facility Name:     | Chiquita Canyon Landfill                            |
| Equipment Address: | 29201 Henry Mayo Drive<br>Castaic, California 91384 |
| Equipment Tested:  | Leachate and Condensate Sampling System             |

I state, as its legally authorized representative, that the source testing firm of:

Source Test Firm: Montrose Air Quality Services, LLC  
Business Address: 1631 E. St. Andrew Pl.  
Santa Ana, California 92705

is an "Independent Testing Laboratory" as defined in ***District Rule 304(k)***:

*For the purposes of this Rule, when an independent testing laboratory is used for the purposes of establishing compliance with District rules or to obtain a District permit to operate, it must meet all of the following criteria:*

- (1) *The testing laboratory shall have no financial interest in the company or facility being tested, or in the parent company, or any subsidiary thereof -*
- (2) *The company or facility being tested, or parent company or any subsidiary thereof, shall have no financial interest in the testing laboratory;*
- (3) *Any company or facility responsible for the emission of significant quantities of pollutants to the atmosphere, or parent company or any subsidiary thereof shall have no financial interest in the testing laboratory; and*
- (4) *The testing laboratory shall not be in partnership with, own or be owned by, in part or in full, the contractor who has provided or installed equipment (basic or control), or monitoring systems, or is providing maintenance for installed equipment or monitoring systems, for the company being tested.*

Furthermore, I state that any contracts or agreements entered into by my source testing firm and the facility referenced above, or its designated contractor(s), either verbal or written, are not contingent upon the outcome of the source testing, or the source testing information provided to the SCAQMD.

Signature: \_\_\_\_\_ Date: 4/18/2025

Pete SanJuan \_\_\_\_\_ Client Project Manager \_\_\_\_\_ (714) 279-6777 \_\_\_\_\_ 4/18/2025  
(Name) \_\_\_\_\_ (Title) \_\_\_\_\_ (Phone) \_\_\_\_\_ (Date)

## **APPENDIX D FACILITY PERMIT**



## FACILITY PERMIT TO OPERATE CHIQUITA CANYON LLC

### PERMIT TO CONSTRUCT/OPERATE

Permit No. G66132  
A/N 613131

#### Equipment Description:

Modification of an existing Landfill Gas Condensate and Leachate Collection/Storage System consisting of:

1. Condensate storage tank, 5,000-gallon capacity, at Canyon B.
2. Condensate storage tank, 10,000-gallon capacity, at Primary Canyon.
3. Condensate storage tanks, three (3), each 6,650-gallon capacity, at flare station.
4. Leachate collection tanks, up to (4), each 10,000-gallon capacity, and one 1,600-gallon capacity, with associated sump pump and transfer pumps.

By removal of:

1. One 1,600-gallon capacity leachate collection tank [under Item 4].

By addition of:

1. One 10,000-gallon capacity leachate collection tank [to Item 4].

#### Conditions:

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.  
[Rule 204]
2. This equipment shall be properly maintained and kept in good operating condition at all times  
[Rule 204]
3. This equipment shall be operated and maintained by personnel properly trained in its operation.  
[Rule 204]
4. This equipment shall be vented to air pollution control equipment which is in full operation and has been issued a valid Permit to Construct or Operate by the South Coast AQMD.  
[Rule 1303(a)(1)-BACT]
5. This equipment shall be used only for the storage of landfill gas condensate and leachate collection.  
[Rule 204]
6. All connectors, valves and openings shall be properly sealed or closed at all times to prevent landfill gas condensate vapors from entering into the atmosphere unless disposal of the condensate/leachate is taking place or during maintenance or repairs.  
[Rule 204]



## **FACILITY PERMIT TO OPERATE CHIQUITA CANYON LLC**

7. Any breakdown or malfunction of the landfill gas condensate/leachate storage system shall be reported to South Coast AQMD within one hour after occurrence, or within one hour of the time personnel knew or reasonably should have known of its occurrence, per Rule 430 requirements, and remedial measures shall be undertaken to correct the problem and prevent further emissions into the atmosphere in a timely manner.  
[Rule 430]
8. The operator shall keep and maintain adequate records for this equipment to verify compliance with the conditions of this permit. These records shall be prepared in a format which is acceptable to the South Coast AQMD. Records shall be kept for at least five years and made available to South Coast AQMD personnel upon request.  
[Rule 204]
9. This permit shall expire if construction of this equipment is not complete within one year from the date of issuance of this permit unless an extension is granted by the Executive Officer.  
[Rule 204]

## **THIS IS THE LAST PAGE OF THIS DOCUMENT**

If you have any questions, please contact one of the following individuals by email or phone.

Name: Mr. Pete SanJuan  
Title: Client Project Manager  
Region: West  
Email: [PSanjuan@montrose-env.com](mailto:PSanjuan@montrose-env.com)  
Phone: (714) 279-6777

Name: Mr. Matt McCune  
Title: Regional Vice President  
Region: West  
Email: [MMccune@montrose-env.com](mailto:MMccune@montrose-env.com)  
Phone: (714) 279-6777