

MONTHLY SUMMARY OF REVISED TOTAL COLIFORM RULE DISTRIBUTION SYSTEM MONITORING

(For public water systems serving more than 400 service connections OR 1,000 persons, OR wholesaler systems)

(Includes triggered source monitoring for Groundwater Rule compliance)

System Name: Santa Clara Valley Water District	System Number: 4310027
Sampling Period: Month: August	Year: 2025

	Number Required	Number Collected	Number Total Coliform Positives	Number E.Coli Positives
1. Routine Samples (see note 1) :	164	214	0	0
2. Repeat Samples following samples that are Total Coliform POSITIVE and E.coli NEGATIVE (see notes 2, 10 and 11) :		0	0	0
3. Repeat Samples following routine samples that are Total Coliform POSITIVE and E. coli POSITIVE (see notes 2, 3, 10 and 11) :		0	0	0
4. Coliform Treatment Technique (TT) Trigger Exceedance % and E.coli /MCL Computation for Total Coliform/E.Coli Positive Samples				
a. Totals (sum of columns) :	164	214	0	
b. If 40 or more samples are collected in the month, determine percent of samples that are Total Coliform positive. ([total number positive / total number collected] x 100):		0.00	%	
c. Did the system violate the E.coli MCL (see note 2 through 5)?			<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
Did the system trigger... a LEVEL 2 Assessment TT?			<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
(See notes 2, 3, 4, 5 and 6 for trigger info)				
If Yes, see note 8 below.				
... a LEVEL 1 Assessment TT?			<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
(See notes 7 for trigger info)				
If Yes, see note 9 below.				
5. Triggered Source Samples per Groundwater Rule (see notes 12 and 13)		0	0	0
6. Invalidated Samples (note what samples, if any, were invalidated; why they were invalidated; who authorized the invalidation; and when replacement samples were collected. Attach additional sheets, if necessary.)				

7. Summary Completed By:

Name/Signature: KIM NGUYEN / Kim Nguyen for Surjit Saini	Title: Surjit Saini Laboratory Manager	Date: 9/10/25
--	--	-------------------------

NOTES AND INSTRUCTIONS:

1. Routine samples include:
 - a) Samples required pursuant to 22 CCR Section 64423 and any additional samples required by an approved routine sample siting plan established pursuant to 22 CCR Section 6442
 - b) Extra samples for systems with high source water turbidities that are using surface water or groundwater under direct influence of surface water and do not practice filtration in compliance with regulations;
- Notes 2-5 (boxed entries) are E. coli MCL violations and require immediate notification to the Division (22 CCR, Section 64426.1):**
2. Any E.coli positive repeat following a total coliform positive sample.
3. Any total coliform positive repeat, following an E.coli positive routine sample.
4. Failure to take all required repeat samples following an E. coli positive routine sample.
5. Failure to test for E. coli when any repeat sample tests positive for total coliform
6. Note: Second Level 1 treatment technique trigger in a rolling 12-month period.
- 7. Level 1 Coliform Treatment Technique (TT) Triggers:**
 - a. For systems collecting less than 40 samples, if two or more samples are total coliform positive, then the TT is violated and a Level 1 Assessment is required
 - b. For systems collecting 40 or more samples, if more than 5.0 percent of samples collected are total coliform positive, then the TT is violated and a Level 1 Assessment is required.
 - c. If a trigger is exceeded as a result of a total coliform positive repeat sample, the system must notify the Division by the end of business day, section 64424(c)**
8. Contact the Division as soon as practical to arrange for the division to conduct a Level 2 Assessment of the water system. The water system shall complete a Level 2 Assessment and submit it to the Division within 30 days of learning of the trigger exceedance.
9. Conduct a Level 1 Assessment in accordance with as soon as practical that covers the minimum elements (22, CCR, Section 64426.8 (a), (2). Submit the report to the Division within 30 days of learning of the trigger exceedance.
10. Positive results and their associated repeat samples must be tracked on the Coliform Monitoring Worksheet
11. Repeat samples must be collected within 24 hours of being notified of the positive results. . At least 3 repeat samples must be collected for each total coliform positive sample.
12. For systems subject to the Groundwater Rule: Positive results and the associated triggered source samples are to be tracked on the Coliform Monitoring Worksheet.
13. For triggered sample(s) required as a result of a total coliform routine positive sample, an E.coli positive triggered sample (boxed entry) **requires immediate notification to the Division, Tier 1 public notification, and corrective action.**



Valley Water
Clean Water • Healthy Environment • Proud People™

Valley Water System # 4310027

Report for: Penitencia, Rinconada, Santa Teresa Water Treatment Plants

Start: 8/1/2025 End: 8/31/2025

Primary Standards - Mandatory Health-Related Standards

	PWTP Influent	PWTP Treated	RWTP Influent	RWTP Treated	STWTP Influent	STWTP Treated	DLR	MCL	2nd MCL	NL	Units
Aluminum	100	ND	64	ND	58	64	50	1000	200	NS	ug/L
Antimony	ND	ND	ND	ND	ND	ND	6	6	NS	NS	ug/L
Arsenic	2	ND	2	ND	2	ND	2	10	NS	NS	ug/L
Barium	ND	ND	ND	ND	ND	ND	100	1000	NS	NS	ug/L
Beryllium	ND	ND	ND	ND	ND	ND	1	4	NS	NS	ug/L
Bromate	NT	4.09	NT	NT	NT	3.67	1	10	NS	NS	ug/L
Cadmium	ND	ND	ND	ND	ND	ND	1	5	NS	NS	ug/L
Chromium	ND	ND	ND	ND	ND	ND	10	50	NS	NS	ug/L
Fluoride	ND	0.80	ND	ND	ND	0.70	0.1	2	NS	NS	mg/L
Hexavalent Chromium	ND	ND	ND	ND	ND	ND	0.1	10	NS	NS	ug/L
Mercury	ND	ND	ND	ND	ND	ND	1	2	NS	NS	ug/L
Nickel	ND	ND	ND	ND	ND	ND	10	100	NS	NS	ug/L
Nitrate as Nitrogen	ND	ND	ND	ND	ND	ND	0.4	10	NS	NS	mg/L
Nitrite as Nitrogen	ND	ND	ND	ND	ND	ND	0.4	1	NS	NS	mg/L
Perchlorate	ND	ND	ND	ND	ND	ND	1	6	NS	NS	ug/L
Selenium	ND	ND	ND	ND	ND	ND	5	50	NS	NS	ug/L
Thallium	ND	ND	ND	ND	ND	ND	1	2	NS	NS	ug/L
Dibromoacetic Acid	NT	1.2	NT	7.2	NT	3.1	1	NS	NS	NS	ug/L
Dichloroacetic Acid	NT	6.4	NT	6.7	NT	2.5	1	NS	NS	NS	ug/L
Monobromoacetic Acid	NT	ND	NT	1.5	NT	ND	1	NS	NS	NS	ug/L
Monochloroacetic Acid	NT	ND	NT	ND	NT	ND	2	NS	NS	NS	ug/L
Trichloroacetic Acid	NT	4.9	NT	5.9	NT	ND	1	NS	NS	NS	ug/L
Total Haloacetic Acids (5)	NT	12.6	NT	21.2	NT	5.6	NS	60	NS	NS	ug/L
Bromodichloromethane	NT	8.1	NT	12	NT	7.7	1	NS	NS	NS	ug/L
Bromoform	NT	ND	NT	4.9	NT	3.9	1	NS	NS	NS	ug/L
Chloroform	NT	13	NT	6.4	NT	4.0	1	NS	NS	NS	ug/L
Dibromochloromethane	NT	5.4	NT	16	NT	9.7	1	NS	NS	NS	ug/L
Total Trihalomethanes	NT	27	NT	39	NT	25	NS	80	NS	NS	ug/L

Secondary Standards - Aesthetic Standards

	PWTP Influent	PWTP Treated	RWTP Influent	RWTP Treated	STWTP Influent	STWTP Treated	DLR	MCL	2nd MCL	NL	Units
Apparent Color	25	<1	10	2	10	2	NS	NS	15	NS	Color Unit
Chloride	25	29	52	53	58	61	NS	NS	500	NS	mg/L
Conductivity	240	220	386	433	416	449	NS	NS	1600	NS	umhos/cm @ 25C
Copper	ND	ND	ND	ND	ND	ND	50	NS	1000	NS	ug/L
Iron	150	<20	85	<20	76	<20	NS	NS	300	NS	ug/L
Manganese	14.0	5.0	20.0	<1	20.0	<1	NS	NS	50	500	ug/L
pH	8.0	7.7	8.1	7.8	8.2	7.7	NS	NS	NS	NS	pH units
Silver	<1	<1	<1	<1	<1	<1	NS	NS	100	NS	ug/L
Sulfate	13.2	30.4	29.4	53.7	33.0	42.8	NS	NS	500	NS	mg/L
Total Dissolved Solids at 180C	142	162	234	256	250	264	NS	NS	1000	NS	mg/L
Zinc	<10	<10	<10	<10	<10	<10	NS	NS	5000	NS	ug/L



Valley Water
Protect Water • Restore Environment • Build a Better Future

Valley Water System # 4310027

Report for: Penitencia, Rinconada, Santa Teresa Water Treatment Plants

Start: 8/1/2025 End: 8/31/2025

Unregulated - With Notification Level

	PWTP Influent	PWTP Treated	RWTP Influent	RWTP Treated	STWTP Influent	STWTP Treated	DLR	MCL	2nd MCL	NL	Units
Boron	<100	<100	125	123	133	135	NS	NS	NS	1000	ug/L
Chlorate	NT	260	NT	84	NT	180	NS	NS	NS	800	ug/L
Vanadium	4.0	3.0	3.0	2.0	3.0	3.0	NS	NS	NS	50	ug/L

Unregulated - Additional Constituents Analyzed

	PWTP Influent	PWTP Treated	RWTP Influent	RWTP Treated	STWTP Influent	STWTP Treated	DLR	MCL	2nd MCL	NL	Units
Bicarbonate (as HCO3)	84	76	95	86	97	92	NS	NS	NS	NS	mg/L
Bromide	<0.1	<0.1	0.15	<0.1	0.16	<0.1	NS	NS	NS	NS	mg/L
Calcium	15.7	15.7	20.9	20.8	21.5	21.9	NS	NS	NS	NS	mg/L
Carbonate (as CO3)	<20	<20	<20	<20	<20	<20	NS	NS	NS	NS	mg/L
Hardness	77	77	101	100	103	105	NS	NS	NS	NS	mg/L
Hydroxide (as OH)	<20	<20	<20	<20	<20	<20	NS	NS	NS	NS	mg/L
Lead	ND	ND	ND	ND	ND	ND	5	NS	NS	NS	ug/L
Magnesium	9.1	9.0	11.7	11.6	12.0	12.2	NS	NS	NS	NS	mg/L
Phosphate, Ortho (as PO4)	0.18	1.07	0.20	1.05	0.23	1.02	NS	NS	NS	NS	mg/L
Potassium	1.5	1.5	2.8	2.8	3.0	3.1	NS	NS	NS	NS	mg/L
Silica	10.9	9.4	13.2	11.9	13.4	13.0	NS	NS	NS	NS	mg/L
Sodium	18.7	27.9	42.2	51.5	45.4	52.3	NS	NS	NS	NS	mg/L
Temperature	23.0	22.7	21.1	22.0	20.9	23.0	NS	NS	NS	NS	Deg C
Total Alkalinity (as CaCO3)	68	62	78	71	80	75	NS	NS	NS	NS	mg/L
Total Organic Carbon	2.70	1.10	3.17	1.53	3.27	1.63	NS	NS	NS	NS	mg/L

MCL = Maximum Contaminant Level

DLR = Detection Limit for Reporting

2ndMCL = Secondary MCL

NL = Notification Level

PWTP = Penitencia Water Treatment Plant

RWTP = Rinconada Water Treatment Plant

STWTP = Santa Teresa Water Treatment Plant

mg/L = milligrams per liter

ug/L = micrograms per liter

Deg. C = Degree Celsius

CFU/mL = colony forming units per milliliter

umhos/cm = micromhos per centimeter

NTU = nephelometric turbidity units

ND = Not Detected at or above the DLR

NR = Not Reported

NS = No Standard

NT = Not Tested