

**South Wake Land Fill
Entrance Improvements for CC#2 - Addendum No. 1
RFB# 25-071**

Clarifications:

- 1 Questions shall be submitted prior to Wednesday, 16 July at 2:00PM.
2 Project Schedule is 60 days to completion immediately following on-site Pre-Construction Meeting.
3 Wake County will hire and be responsible for handling materials testing.
4 Subgrade compaction shall be to 95%. Maximum water content in subgrade shall be 2%.
5 Base Bid is to include all work. Add alternates included in plans are to be deducts, as stated in the specifications/project manual. Final Addendum will include revised plan set cooresponding to the project manual.

[illegible]